



OFFICE OF ENFORCEMENT AND COMPLIANCE ASSURANCE

WASHINGTON, D.C. 20460

March 24, 2025

Mr. Robert Beck
President
Thelin Hearth Products, Inc.
63 Laxalt Drive
Carson City, NV 89706

Re: Renewal of Certificate of Compliance Number 254-20 for the Echo-Comstock II Pellet-Fired Freestanding Room Heater Model

Dear Mr. Beck:

I am pleased to inform Thelin Hearth Products, Inc. that the above-referenced pellet heater model has been approved for renewal of a Certificate of Compliance pursuant to the 2015 New Source Performance Standard (NSPS) for New Residential Wood Heaters, New Residential Hydronic Heaters and Forced-Air Furnaces at 40 CFR Part 60, Subpart AAA (2015 NSPS) by the United States Environmental Protection Agency. Pursuant to the 2015 NSPS, this renewal is valid through March 24, 2030. This letter serves as your pellet heater Certificate of Compliance. Please refer to the above-referenced Certificate of Compliance number in all future correspondence.

In accordance with the 2015 Wood Heater Rule at 40 CFR Part 60, § 60.533(i)(2), a manufacturer of a heater model line may apply to the EPA for renewal of the model line's Certificate of Compliance. To do so, the manufacturer may affirm in writing that the heaters in the model line continue to be similar in all material respects that would affect emissions to the representative heater submitted for testing on which the original Certificate of Compliance was based. In making such an affirmation, the manufacturer also may request a potential waiver from certification testing.

Based on a March 6, 2020,¹ test report prepared by PFS-TECO demonstrating compliance with the EPA Test Method 28R, the ASTM International Test Methods E2515 and E2779, a March 6, 2020,² Certification of Conformity by PFS-TECO and the information provided in your November 14, 2024, request for renewal of the Certificate of Compliance, the EPA has determined that the model line

¹ Revised March 19, 2024.

² Revised March 19, 2024.

continues to meet the certification requirements at § 60.533. Therefore, pursuant to §§ 60.533(i)(2) and (i)(3), the EPA is renewing the Certificate of Compliance, and in doing so, the agency is waiving certification testing for the above-referenced model. You may not advertise for sale, offer for sale, or sell heaters under this Certificate of Compliance after March 24, 2030, without applying for and being issued another Certificate of Compliance with an updated expiration date.

All pellet heaters manufactured or sold under this Certificate of Compliance must comply with the EPA labeling requirements found at § 60.536. These provisions require each pellet heater to have a permanent label affixed to it, including the month and year of manufacture, model name or number, serial number, certification test emission value, test method, standard met, and compliance certification statement.

In addition, you must comply with all applicable requirements of the regulation, including:

1. Conducting a third-party certifier-approved quality assurance program that ensures that all units within a model line are similar to the pellet heater submitted for certification testing in all respects that would affect emissions and are in compliance with the applicable emission limit, pursuant to § 60.533(m);
2. Applying for recertification whenever any change is made to the above-referenced model that affects or is presumed to affect the particulate matter emission rate for the model line, pursuant to § 60.533(k)(1);
3. Providing an owner's manual that includes the information listed in § 60.536(g)(1) with each affected pellet heater model offered for sale;
4. Placing a copy of the non-Confidential Business Information (non-CBI) certification test report on the manufacturer's website and available to the public within 30 days after the EPA issues a Certificate of Compliance, pursuant to § 60.533(b)(12). If later revised, the up-to-date non-CBI certification test report should remain posted on the manufacturer's website for as long as the model line is manufactured and offered for sale in the United States;
5. Submitting a report to the EPA every two years following the issuance of a Certificate of Compliance for each model line. This report must include the sales for each model by state and certify that no changes in the design or manufacture of this model line have been made that require recertification under § 60.533(k);
6. Retaining records and submitting reports as required at § 60.537; and
7. Submitting pellet heaters for audit testing if selected by the EPA under §§ 60.533(n)(1)(i) and (2)(i).

Failure to comply with these requirements may result in revoking this Certificate of Compliance and enforcement action, including penalties as specified under the Clean Air Act. To promote transparency

in implementing the Wood Heater Program, we request that manufacturers submit a copy of the Uniform Resource Locator (URL) or web address where the test report is posted to WoodHeaterReports@epa.gov within ten (10) days of posting.

Once we have verified that the revised test report has been posted on the manufacturer's website, the agency will continue to list the above-referenced model in the [EPA-Certified Wood Heater Database](#).

If you have any questions concerning this letter, please contact the Wood Heater Program at WoodHeaterReports@epa.gov.

Sincerely,

Loren Denton, PhD
Director
Monitoring, Assistance, and Media Programs Division
Office of Compliance
Office of Enforcement and Compliance Assurance



Certificate of Conformity

Issued to: Thelin Hearth Products
Mr. Robert Beck
63 Laxalt Dr.
Carson City, NV 89706
775-241-2586

Model: Echo-Comstock II
Effective Date: March 6, 2020
Revised Date: March 19, 2024
Report #: 20-568

Certification tests were performed by PFS-TECO located at 11785 SE Highway 212, Suite 305, Clackamas, OR 97015

PFS TECO certifies conformity to the following per 40 CFR Part 60 §60.533 (f) (A):

- The test report is complete and accurate.
- The instrumentation used for the test was properly calibrated.
- The representative model tested meets the applicable emission limits.
- The tests have been conducted per the appropriate guidelines.
- The manufacturer's Quality Control Plan has been reviewed to ensure that all production units are similar in all material respects that would affect emissions to the tested/certified model and that the units in the model line will meet all (other) applicable requirements.

PFS TECO certifies that the emissions levels as measured in the test report are in compliance with the 2020 PM emission limit of ≤ 2.0 g/hr using pellet fuel per ASTM E2779. Efficiency calculated per CSA B415.1.

The average emissions for the Echo-Comstock II pellet heater is **0.88 g/hr** with an average efficiency of **75%**. Average CO emissions are **0.15 g/min**.

Issued by: PFS TECO
1507 Matt Pass
Cottage Grove, WI 53527

Scott Drake, President and CEO



Revision History

Date: March 6, 2020 – Original Issue

Date: March 19, 2024 – The following revisions to the report were reviewed:

- Added a note on page 4 that conditioning was performed at a medium burn setting.
- Added an updated manual to Appendix B including new language on the use of improper fuels.
- Updated the data summary sheet in appendix A to include train precision expressed as a percentage, see page 21 of Non-CBI report.
- Added additional information to the run narrative section on page 8 discussing settings used during testing and the appropriateness of the burn rates that were measured.

Thelin Hearth Products

Project # 20-568

Model: Echo-Comstock II

Type: Pellet-Fired Room Heater

March 6, 2020

Revised: March 19, 2024

**ASTM E2779 Standard Test Method for
Determining Particulate Matter Emissions
from Pellet Heaters**

Contact: Mr. Robert Beck
Thelin Hearth Products
63 Laxalt Dr.
Carson City, NV 89706
775-241-2586 x105

Prepared by: Sebastian Button



**11785 SE Highway 212 – Suite 305
Clackamas, OR 97015-9050
(503) 650-0088
WWW.PFSTECO.COM**

Revision History

Date: March 6, 2020 – Original Issue

Date: March 19, 2024 – The following revisions were made per a request from EPA:

- Added a note on page 4 that conditioning was performed at a medium burn setting.
- Added an updated manual to Appendix B including new language on the use of improper fuels.
- Updated the data summary sheet in appendix A to include train precision expressed as a percentage, see page 21 of Non-CBI report.
- Added additional information to the run narrative section on page 8 discussing settings used during testing and the appropriateness of the burn rates that were measured.

Contents


| | |
|---|----|
| Affidavit | 3 |
| Introduction..... | 4 |
| Notes | 4 |
| Pellet Heater Identification and Testing..... | 5 |
| Test Procedures and Equipment | 6 |
| Results | 7 |
| Summary Table..... | 7 |
| Test Run Narrative..... | 8 |
| Run 1 | 8 |
| Test Conditions Summary..... | 8 |
| Appliance Operation and Test Settings | 8 |
| Settings & Run Notes | 8 |
| Appliance Description..... | 9 |
| Appliance Dimensions..... | 9 |
| Test Fuel Properties..... | 12 |
| Pellet Fuel Analysis..... | 13 |
| Sampling Locations and Descriptions | 14 |
| Sample Points..... | 14 |
| Sampling Methods..... | 15 |
| Analytical Methods Description | 15 |
| Calibration, Quality Control and Assurances | 15 |
| Appliance Sealing and Storage | 15 |
| Sealing Label..... | 15 |
| Sealed Unit | 16 |
| List of Appendices..... | 17 |

Affidavit

PFS-TECO was contracted by Thelin Hearth Products to provide testing services for the Echo-Comstock II Pellet-Fired Room Heater per ASTM E2779, *Determining PM Emissions from Pellet Heaters*. All testing and associated procedures were conducted at PFS-TECO's Portland Laboratory on 2/10/2020. PFS-TECO's Portland Laboratory is located at 11785 SE Highway 212 – Suite 305, Clackamas, Oregon 97015. Testing procedures followed ASTM E2779. Particulate sampling was performed per ASTM E2515, *Standard Test Method for Determination of Particulate Matter Emissions Collected by a Dilution Tunnel*.

PFS-TECO is accredited by the U.S. Environmental Protection Agency for the certification and auditing of wood heaters pursuant to subpart AAA of 40 CFR Part 60, New Source Performance Standards for Residential Wood Heaters and subpart QQQQ of 40 CFR Part 60, Standards of Performance for New Hydronic Heaters and Forced Air Furnaces, Methods 28R, 28WHH, 28 WHH-PTS, and all methods listed in Sections 60.534 and 60.5476. PFS-TECO holds EPA Accreditation Certificate Numbers 4 and 4M (mobile). PFS-TECO is accredited by IAS to ISO 17020:2012 "Criteria for Bodies Performing Inspections", and ISO 17025:2005 "Requirements for Testing Laboratories." PFS-TECO is also accredited by Standards Council of Canada to ISO 17065:2012 "Requirements for Bodies Operating Product Certification Systems."

The following people were associated with the testing, analysis and report writing associated with this project.



Sebastian Button, Laboratory Supervisor

Introduction

Theelin Hearth Products of Carson City, NV, contracted with PFS-TECO to perform EPA certification testing on the Echo-Comstock II Pellet-Fired Room Heater. All testing was performed at PFS-TECO's Portland Laboratory. Testing was performed by Mr. Sebastian Button.

Notes

- Prior to start of testing, 50 hours of conditioning was performed by PFS staff at the medium burn setting, per ASTM E2779
- Prior to start of testing, the dilution tunnel was cleaned with a steel brush.
- Front filters were changed on sample train A at one hour after the test began.
- A single, integrated test run, in accordance with ASTM E2779 was performed:
 - 1 Hour at Maximum Burn Setting
 - 2 Hours at Medium Burn Setting
 - 3 Hours at Minimum Burn Setting

Pellet Heater Identification and Testing

- Appliance Tested: ***Echo-Comstock II***
- Serial Number: ***SN 16049; PFS Tracking Number 0062***
- Manufacturer: ***Theelin Hearth Products***
- Catalyst: ***No***
- Heat exchange blower: ***Integral***
- Type: ***Pellet Stove***
- Style: ***Free Standing***
- Date Received: ***Thursday, February 06, 2020***
- Testing Period – Start: ***Monday, February 10, 2020*** Finish: ***Monday, February 10, 2020***
- Test Location: ***PFS-TECO Portland Laboratory, 11785 SE HWY 212 - Suite 305, Clackamas, OR 97015***
- Elevation: ***≈131 Feet above sea level***
- Test Technician(s): ***Sebastian Button***
- Observers: ***None***

Test Procedures and Equipment

All Sampling and analytical procedures were performed by Sebastian Button. All procedures used are directly from ASTM E2779 and ASTM E2515. See the list below for equipment used. See Appendix C submitted with this report for calibration data.

Equipment List:

| Equipment ID# | Equipment Description |
|---------------|--|
| 041 | Rice Lake 3'x3' floor scale w/digital weight indicator |
| 053 | APEX XC-60 Digital Emissions Sampling Box A |
| 054 | APEX XC-60 Digital Emissions Sampling Box B |
| 057 | California Analytical ZRE CO2/CO/O2 IR ANALYZER |
| 064 | Digital Barometer |
| 107 | Sartorius Analytical Balance |
| 109A/B | Troemner 100mg/200mg Audit Weights |
| 051 | 10 lb audit weight |
| 095 | Anemometer |
| 111 | Microtector |
| SA17187 | Gas Analyzer Calibration Span Gas |
| CC170624 | Gas Analyzer Calibration Mid Gas |

Results

The integrated test run emission rate for test Run 1 was measured to be **0.88 g/hr** with a Higher Heating Values efficiency of **75.0%** and a CO emission rate of **0.15 g/min.** The calculated first hour particulate emission rate was **0.61 g/hr.** The Thelin Hearth Products Model Echo-Comstock II Pellet-Fired Room Heater meets the 2020 PM emission standard of ≤ 2.0 g/hr per CFR 40 part 60, §60.532 (b).

Detailed individual run data can be found in Appendix A submitted with this report.

Summary Table

| EPA Application Table | | | | | | | | | | | |
|-----------------------|-----------|----------|------|----------------|----------------------|-------------------------|-------------------------|----------------------|------------------------------|---------------------------|-----------------------------------|
| Run Number | Date | Segments | | Run Time (min) | Heat Output (BTU/hr) | 1st Hr Emissions (g/hr) | Integrated Total (g/hr) | CO Emissions (g/min) | Overall CO Emissions (g/min) | Heating Efficiency (%HHV) | Overall Heating Efficiency (%HHV) |
| | | Setting | BR | | | | | | | | |
| 1 | 2/10/2020 | H | 1.86 | 60 | 26783 | 0.61 | 0.88 | 0.03 | 0.15 | 74.6% | 75.0% |
| | | M | 1.57 | 120 | 22845 | | | 0.13 | | 75.3% | |
| | | L | 1.16 | 180 | 16754 | | | 0.20 | | 74.5% | |
| | | OA | 1.42 | 360 | 20505 | | | 0.15 | | 75.0% | |

Test Run Narrative

Run 1

Run 1 was performed on 2/10/2020 as an attempted integrated test run per ASTM E2779. The overall test duration was 360 minutes. The particulate emissions rate for the integrated test run was 0.88 g/hr. The run had an overall HHV efficiency of 75.0%. The train A front filter was changed at 1 hr. The medium burn rate for this appliance was determined to be in excess of <50% of maximum, as specified by ASTM E2779 section 9.4.1.2, however the appliance meets the exception referenced in that same clause per section 9.4.1.5(2). This appliance has exactly three settings (Hi, Med, and Lo), which were the settings used for each respective segment of the test, therefore the requirements of the standard were met. All test results were appropriate and valid and the burn rate requirement for the integrated test run were achieved. There were no anomalies and all criteria were met.

Test Conditions Summary

Testing conditions for all runs fell within allowable specifications of ASTM E2779 and ASTM E2515. A summary of facility conditions, fuel burned, and run times is listed below.

| Runs | Ambient (°F) | | Relative Humidity (%) | | Average Barometric Pressure (In. Hg.) | Preburn Fuel Weight (lbs) | Test Fuel Weight (lbs) | Test Fuel Moisture (%DB) | Test Run Time (Min) |
|------|--------------|------|-----------------------|------|---------------------------------------|---------------------------|------------------------|--------------------------|---------------------|
| | Pre | Post | Pre | Post | | | | | |
| 1 | 64 | 67 | 39.7 | 32.2 | 30.30 | 4.2 | 19.2 | 2.54 | 360 |

Appliance Operation and Test Settings

The appliance was operated according to procedures as described in the Operations Manual, found in Appendix B submitted with this report. Detailed run information can be found in Appendix A submitted with this report.

Settings & Run Notes

| | Pre-Burn | Test Run |
|-------|---------------------|---|
| Run 1 | "Hi," Feed trim Max | High Segment: "Hi," Feed trim Max Medium Segment: "Med," Feed trim Max Low Segment: "Lo," Feed trim Max |

Appliance Description

Model(s): Echo-Comstock II

Additional Models Discussion: None

Appliance Type: Pellet-Fired Room Heater

Air Introduction System: Air enters the burn chamber by being pulled through the firepot, via the exhaust blower, see air flow diagram in Appendix D.

Combustion Control: Feed rate is electronically controlled via user-selectable controls.

Baffles: N/A

Flue Outlet: 3-inch exhaust outlet located on the bottom/rear of the appliance.

Appliance Dimensions

Echo-Comstock II Dimensions

| Height | Width | Depth | Firebox Volume | Weight |
|--------|-------|-------|--------------------|---------|
| 29.5" | 27" | 25.5" | N/A – Pellet Stove | 250 lbs |

Appliance design drawings can be found in Appendix D submitted with the CBI copy of this report.

Appliance Front



Appliance Left




Appliance Right



Appliance Rear



Test Fuel Properties



Test fuel used was Bear Mountain Wood Pellet Fuel, a PFI Certified Premium Pellet Brand. A sample of pellets was sent to Twin Ports Testing for analysis, see report below.

Pellet Fuel Analysis



Twin Ports Testing, Inc.
 1301 North 3rd Street
 Superior, WI 54880
 p: 715-392-7114
 p: 800-373-2562
 f: 715-392-7183
 www.twinportstesting.com

Report No: **USR:W219-0755-01**
 Issue No: **1**

Analytical Test Report

Client: PFS-TECO
 Attention: Sebastian Button
 PO No: A-Kravitz

Signed: *Stephen Sundeen*
 Stephen Sundeen
 Chemistry Laboratory Manager
 Date of Issue: 9/20/2019
THIS DOCUMENT SHALL NOT BE REPRODUCED EXCEPT IN FULL

Sample Details

Sample Log No: W219-0755-01 Sample Date: 8/30/2019
 Sample Designation: Bear Mountain Sample Time: 10:30 AM
 Sample Recognized As: Wood Pellets Arrival Date: 9/12/2019

Test Results

| | METHOD | UNITS | MOISTURE | |
|-----------------------------------|------------|----------|----------|-------------|
| | | | FREE | AS RECEIVED |
| Moisture Total | ASTM E871 | wt. % | | 2.48 |
| Ash | ASTM D1102 | wt. % | 0.24 | 0.24 |
| Volatile Matter | ASTM D3175 | wt. % | 80.80 | 78.79 |
| Fixed Carbon by Difference | ASTM D3172 | wt. % | 18.96 | 18.49 |
| Sulfur | ASTM D4239 | wt. % | 0.034 | 0.034 |
| SO ₂ | Calculated | lb/mmbtu | | 0.079 |
| Net Cal. Value at Const. Pressure | ISO 1928 | GJ/tonne | 19.02 | 18.49 |
| Gross Cal. Value at Const. Vol. | ASTM E711 | Btu/lb | 8752 | 8535 |
| Carbon | ASTM D5373 | wt. % | 49.35 | 48.12 |
| Hydrogen* | ASTM D5373 | wt. % | 6.14 | 5.99 |
| Nitrogen | ASTM D5373 | wt. % | < 0.20 | < 0.20 |
| Oxygen* | ASTM D3176 | wt. % | > 44.03 | > 42.94 |

*Note: As received values do not include hydrogen and oxygen in the total moisture.

| | | | | |
|--------------------------------|--------------|---------------------|--|----|
| Chlorine | ASTM D6721 | mg/kg | | |
| Fluorine | ASTM D3761 | mg/kg | | |
| Mercury | ASTM D6722 | mg/kg | | |
| Bulk Density | ASTM E873 | lbs/ft ³ | | |
| Fines (Less than 1/8") | TPT CH-P-06 | wt. % | | |
| Durability Index | Kansas State | PDI | | |
| Sample Above 1.50" | TPT CH-P-06 | wt. % | | |
| Maximum Length (Single Pellet) | TPT CH-P-06 | inch | | |
| Diameter, Range | TPT CH-P-05 | inch | | to |
| Diameter, Average | TPT CH-P-05 | inch | | |
| Stated Bag Weight | TPT CH-P-01 | lbs | | |
| Actual Bag Weight | TPT CH-P-01 | lbs | | |

Comments:





Results issued on this report only reflect the analysis of the sample submitted. Our reports and letters are for the exclusive and confidential use of our clients and may not be reproduced, except in their entirety, without the written approval of Twin Ports Testing. Twin Ports Testing Laboratory is accredited to the ISO/IEC 17025:2017 standard by PJLA.

Sampling Locations and Descriptions

Sample ports are located 16.5 feet downstream from any disturbances and 1 foot upstream from any disturbances. Flow rate traverse data was collected 12 feet downstream from any disturbances and 5.5 feet upstream from any disturbances. (See below).

Sample Points



Sampling Methods

ASTM E2515 was used in collecting particulate samples. The dilution tunnel is 6 inches in diameter. All sampling conditions per ASTM E2515 were followed. No alternate procedures were used.

Analytical Methods Description

All sample recovery and analysis procedures followed ASTM E2515 procedures. At the end of each test run, filters, O-Rings and probes were removed from their housings, dessicated for a minimum of 24 hours, and then weighed at 6 hour intervals to a constant weight per ASTM E2515-11 Section 10.

Calibration, Quality Control and Assurances

Calibration procedures and results were conducted per EPA Method 28R, ASTM E2515-11 and ASTM E2780-10. Test method quality control procedures (leak checks, volume meter checks, stratification checks, proportionality results) followed the procedures outlined.

Appliance Sealing and Storage

Upon completion of testing, the appliance was secured with metal strapping and the seal below was applied, the appliance was then returned to the manufacturer’s location at: 63 Lexalt Drive, Carson City, NV 89706 for archival.

Sealing Label

ATTENTION:

THIS SEAL IS NOT TO BE BROKEN WITHOUT PRIOR AUTHORIZATION FROM THE UNITED STATES ENVIRONMENTAL PROTECTION AGENCY.

THIS APPLIANCE HAS BEEN SEALED IN ACCORDANCE WITH REQUIREMENTS OF 40CFR PART 60 SUBPART AAA §60.535 (a)(2)(vii)

REPORT # _____

DATE SEALED _____

MANUFACTURER _____

MODEL # _____

Sealed Unit



List of Appendices

The following appendices have been submitted electronically in conjunction with this report:

Appendix A – Test Run Data, Technician Notes, and Sample Analysis

Appendix B – Labels and Manuals

Appendix C – Equipment Calibration Records

Appendix D – Design Drawings (CBI Report Only)

Appendix E – Manufacturer QAP (CBI Report Only)

Conditioning Data

| | |
|--------------------------------|------------------|
| Client: Thelin Hearth Products | Job #: 20-568 |
| Model: Echo II | Tracking #: 0062 |
| Date(s): 2/6/2020 - 2/9/2020 | Technician: SJB |

| Elapsed Time (hrs) | Scale Reading (lbs) | Average: | 341.7 | 67.5 | N/A |
|--------------------|---------------------|---------------------|-----------|--------------|--------------------|
| | | Weight Change (lbs) | Flue (°F) | Ambient (°F) | Catalyst Exit (°F) |
| 0 | 41.2 | - | 371 | 67 | N/A |
| 1 | 37.1 | -4.1 | 385 | 68 | N/A |
| 2 | 33.3 | -3.8 | 342 | 68 | N/A |
| 3 | 30.5 | -2.8 | 290 | 69 | N/A |
| 4 | 28.6 | -1.9 | 332 | 69 | N/A |
| 5 | 25.5 | -3.1 | 342 | 69 | N/A |
| 6 | 22.6 | -2.9 | 323 | 69 | N/A |
| 7 | 19.7 | -2.9 | 328 | 69 | N/A |
| 8 | 16.4 | -3.3 | 370 | 70 | N/A |
| 9 | 13.3 | -3.1 | 340 | 69 | N/A |
| 10 | 10.4 | -2.9 | 319 | 69 | N/A |
| 11 | 37.6 | 27.2 | 327 | 69 | N/A |
| 12 | 34.6 | -3.0 | 326 | 69 | N/A |
| 13 | 31.7 | -2.9 | 321 | 68 | N/A |
| 14 | 28.7 | -3.0 | 330 | 68 | N/A |
| 15 | 25.7 | -3.0 | 325 | 68 | N/A |
| 16 | 22.9 | -2.8 | 308 | 68 | N/A |
| 17 | 19.9 | -3.0 | 324 | 68 | N/A |
| 18 | 17.1 | -2.8 | 323 | 67 | N/A |
| 19 | 14.3 | -2.8 | 314 | 67 | N/A |
| 20 | 11.4 | -2.9 | 317 | 67 | N/A |
| 21 | 36.8 | 25.4 | 317 | 67 | N/A |
| 22 | 34.1 | -2.7 | 314 | 67 | N/A |
| 23 | 31.4 | -2.7 | 305 | 67 | N/A |
| 24 | 29.0 | -2.4 | 205 | 66 | N/A |
| 25 | 26.2 | -2.8 | 200 | 64 | N/A |
| 26 | 22.7 | -3.5 | 351 | 65 | N/A |
| 27 | 19.5 | -3.2 | 363 | 65 | N/A |
| 28 | 16.2 | -3.3 | 356 | 66 | N/A |
| 29 | 12.9 | -3.3 | 374 | 66 | N/A |
| 30 | 9.6 | -3.3 | 365 | 66 | N/A |
| 31 | 37.5 | 27.9 | 367 | 67 | N/A |
| 32 | 34.2 | -3.3 | 356 | 67 | N/A |
| 33 | 31.1 | -3.1 | 353 | 67 | N/A |
| 34 | 28.0 | -3.1 | 348 | 68 | N/A |
| 35 | 24.8 | -3.2 | 361 | 66 | N/A |
| 36 | 21.7 | -3.1 | 357 | 66 | N/A |
| 37 | 18.6 | -3.1 | 353 | 66 | N/A |
| 38 | 15.6 | -3.0 | 380 | 66 | N/A |
| 39 | 12.2 | -3.4 | 373 | 66 | N/A |
| 40 | 33.8 | 21.6 | 367 | 68 | N/A |
| 41 | 30.5 | -3.3 | 368 | 69 | N/A |
| 42 | 27.2 | -3.3 | 371 | 69 | N/A |
| 43 | 23.9 | -3.3 | 382 | 69 | N/A |
| 44 | 20.7 | -3.2 | 358 | 68 | N/A |
| 45 | 17.5 | -3.2 | 359 | 68 | N/A |
| 46 | 14.2 | -3.3 | 387 | 68 | N/A |
| 47 | 10.9 | -3.3 | 368 | 68 | N/A |
| 48 | 7.7 | -3.2 | 372 | 67 | N/A |
| 49 | 4.5 | -3.2 | 356 | 67 | N/A |
| 50 | 1.1 | -3.4 | 383 | 67 | N/A |

PELLET TEST DATA PACKET
ASTM E2779/E2515



Run 1 Data Summary

Client: Thelin Hearth Products
Model: Echo Pellet II
Job #: 20-568
Tracking #: 0062
Test Date: 2/10/2020



Techician Signature

2/13/2020

Date

TEST RESULTS - ASTM E2779 / ASTM E2515

Client: Thelin Hearth ProductsModel: Echo Pellet IIRun #: 1Job #: 20-568Tracking #: 0062Technician: SJBDate: 2/10/2020

| Burn Rate Summary | |
|-------------------------------|------|
| High Burn Rate (dry kg/hr) | 1.86 |
| Medium Burn Rate (dry kg/hr) | 1.57 |
| Low Burn Rate (dry kg/hr) | 1.16 |
| Overall Burn Rate (dry kg/hr) | 1.42 |

84.5% of High Burn Rate

62.7% of High Burn Rate

| | Ambient Sample | Sample Train A | Sample Train B | 1st Hour Filter |
|---|----------------|----------------|----------------|-----------------|
| Total Sample Volume (ft ³) | 0.000 | 52.971 | 51.022 | 8.718 |
| Average Gas Velocity in Dilution Tunnel (ft/sec) | 16.2 | | | |
| Average Gas Flow Rate in Dilution Tunnel (dscf/hr) | 10814.4 | | | |
| Average Gas Meter Temperature (°F) | 65.8 | 92.4 | 89.4 | 75.4 |
| Total Sample Volume (dscf) | 0.000 | 52.152 | 50.286 | 8.854 |
| Average Tunnel Temperature (°F) | 94.7 | | | |
| Total Time of Test (min) | 360 | | | |
| Total Particulate Catch (mg) | 0.0 | 4.4 | 3.9 | 0.5 |
| Particulate Concentration, dry-standard (g/dscf) | 0.0000000 | 0.0000844 | 0.0000776 | 0.0000565 |
| Total PM Emissions (g) | 0.00 | 5.47 | 5.03 | 0.61 |
| Particulate Emission Rate (g/hr) | 0.00 | 0.91 | 0.84 | 0.61 |
| Emissions Factor (g/kg) | - | 0.64 | 0.59 | 0.33 |
| Difference from Average Total Particulate Emissions (g) | - | 0.22 | 0.22 | - |
| Difference from Average Emissions Factor (%) | - | 4.2% | 4.2% | - |
| Difference from Average Emissions Factor (g/kg) | - | 0.03 | 0.03 | - |

| Final Average Results | |
|----------------------------------|-------|
| Total Particulate Emissions (g) | 5.25 |
| Particulate Emission Rate (g/hr) | 0.88 |
| Emissions Factor (g/kg) | 0.62 |
| HHV Efficiency (%) | 75.0% |
| LHV Efficiency (%) | 80.2% |
| CO Emissions (g/min) | 0.15 |

| Quality Checks | Requirement | Observed | Result |
|----------------------------------|---|--------------------------|----------------|
| Dual Train Precision | Each train within 7.5% of average emissions (in grams), or emission factors within 0.5 g/kg | See Above | OK |
| Filter Temps | <90 °F | 73 | OK |
| Face Velocity | < 30 ft/min | 8.8 | OK |
| Leakage Rate | Less than 4% of average sample rate | 0 cfm | OK |
| Ambient Temp | 55-90 °F | Min: 64 / Max: 68 | OK |
| Negative Probe Weight Evaluation | <5% of Total Catch | Probe Catch Not Negative | OK |
| Pro-Rate Variation | 90% of readings between 90-110%; none greater than 120% or less than 80% | See Data Tabs | OK |
| Medium Burn Rate | < 50% of High | 84.5% | Not Acceptable |

Overall Pellet Test Efficiency Results

Manufacturer: Thelin Hearth Products
Model: Echo Pellet II
Date: 02/10/20
Run: 1
Control #: 20-568
Test Duration: 360
Output Category: Integrated

Test Results in Accordance with CSA B415.1-09

| | HHV Basis | LHV Basis |
|---------------------------------|-----------|-----------|
| Overall Efficiency | 75.0% | 80.2% |
| Combustion Efficiency | 99.5% | 99.5% |
| Heat Transfer Efficiency | 75.4% | 80.6% |

| | | | |
|---------------------------|--------|--------|----------------|
| Output Rate (kJ/h) | 21,616 | 20,505 | (Btu/h) |
| Burn Rate (kg/h) | 1.42 | 3.12 | (lb/h) |
| Input (kJ/h) | 28,824 | 27,343 | (Btu/h) |

| | | | |
|----------------------------------|------|-------|---------------|
| Test Load Weight (dry kg) | 8.50 | 18.72 | dry lb |
| MC wet (%) | 2.48 | | |
| MC dry (%) | 2.54 | | |
| Particulate (g) | 5.25 | | |
| CO (g) | 54 | | |
| Test Duration (h) | 6.00 | | |

| Emissions | Particulate | CO |
|-------------------------|-------------|------|
| g/MJ Output | 0.04 | 0.42 |
| g/kg Dry Fuel | 0.62 | 6.34 |
| g/h | 0.88 | 8.97 |
| g/min | 0.01 | 0.15 |
| lb/MM Btu Output | 0.09 | 0.96 |

| | |
|-----------------------------|-------|
| Air/Fuel Ratio (A/F) | 21.78 |
|-----------------------------|-------|

VERSION:

2.2

12/14/2009

Max Burn Rate Segment Efficiency Results

Manufacturer: Thelin Hearth Products
Model: Echo Pellet II
Date: 02/10/20
Run: 1
Control #: 20-568
Test Duration: 60
Output Category: Maximum

Test Results in Accordance with CSA B415.1-09

| | HHV Basis | LHV Basis |
|---------------------------------|-----------|-----------|
| Overall Efficiency | 74.6% | 79.8% |
| Combustion Efficiency | 99.5% | 99.5% |
| Heat Transfer Efficiency | 75.0% | 80.2% |

| | | | |
|---------------------------|--------|--------|----------------|
| Output Rate (kJ/h) | 28,234 | 26,783 | (Btu/h) |
| Burn Rate (kg/h) | 1.86 | 4.10 | (lb/h) |
| Input (kJ/h) | 37,832 | 35,888 | (Btu/h) |

| | | | |
|----------------------------------|------|------|---------------|
| Test Load Weight (dry kg) | 1.86 | 4.10 | dry lb |
| MC wet (%) | 2.48 | | |
| MC dry (%) | 2.54 | | |
| Particulate (g) | N/A | | |
| CO (g) | 2 | | |
| Test Duration (h) | 1.00 | | |

| Emissions | Particulate | CO |
|-------------------------|-------------|------|
| g/MJ Output | N/A | 0.07 |
| g/kg Dry Fuel | N/A | 1.12 |
| g/h | N/A | 2.07 |
| g/min | N/A | 0.03 |
| lb/MM Btu Output | N/A | 0.17 |

| | |
|-----------------------------|-------|
| Air/Fuel Ratio (A/F) | 18.34 |
|-----------------------------|-------|

VERSION:

2.2

12/14/2009

Medium Burn Rate Segment Efficiency Results

Manufacturer: Thelin Hearth Products
Model: Echo Pellet II
Date: 02/10/20
Run: 1
Control #: 20-568
Test Duration: 120
Output Category: Medium

Test Results in Accordance with CSA B415.1-09

| | HHV Basis | LHV Basis |
|---------------------------------|-----------|-----------|
| Overall Efficiency | 75.3% | 80.6% |
| Combustion Efficiency | 99.5% | 99.5% |
| Heat Transfer Efficiency | 75.7% | 81.0% |

| | | | |
|---------------------------|--------|--------|----------------|
| Output Rate (kJ/h) | 24,083 | 22,845 | (Btu/h) |
| Burn Rate (kg/h) | 1.57 | 3.46 | (lb/h) |
| Input (kJ/h) | 31,977 | 30,334 | (Btu/h) |

| | | | |
|----------------------------------|------|------|---------------|
| Test Load Weight (dry kg) | 3.14 | 6.92 | dry lb |
| MC wet (%) | 2.48 | | |
| MC dry (%) | 2.54 | | |
| Particulate (g) | N/A | | |
| CO (g) | 16 | | |
| Test Duration (h) | 2.00 | | |

| Emissions | Particulate | CO |
|-------------------------|-------------|------|
| g/MJ Output | N/A | 0.32 |
| g/kg Dry Fuel | N/A | 4.98 |
| g/h | N/A | 7.82 |
| g/min | N/A | 0.13 |
| lb/MM Btu Output | N/A | 0.75 |

| | |
|-----------------------------|-------|
| Air/Fuel Ratio (A/F) | 19.74 |
|-----------------------------|-------|

VERSION:

2.2

12/14/2009

Minimum Burn Rate Segment Efficiency Results

Manufacturer: Thelin Hearth Products
Model: Echo Pellet II
Date: 02/10/20
Run: 1
Control #: 20-568
Test Duration: 180
Output Category: Minimum

Test Results in Accordance with CSA B415.1-09

| | HHV Basis | LHV Basis |
|---------------------------------|-----------|-----------|
| Overall Efficiency | 74.5% | 79.6% |
| Combustion Efficiency | 99.5% | 99.5% |
| Heat Transfer Efficiency | 74.8% | 80.0% |

| | | | |
|---------------------------|--------|--------|----------------|
| Output Rate (kJ/h) | 17,662 | 16,754 | (Btu/h) |
| Burn Rate (kg/h) | 1.17 | 2.57 | (lb/h) |
| Input (kJ/h) | 23,720 | 22,501 | (Btu/h) |

| | | | |
|----------------------------------|------|------|---------------|
| Test Load Weight (dry kg) | 3.50 | 7.70 | dry lb |
| MC wet (%) | 2.48 | | |
| MC dry (%) | 2.54 | | |
| Particulate (g) | N/A | | |
| CO (g) | 36 | | |
| Test Duration (h) | 3.00 | | |

| Emissions | Particulate | CO |
|-------------------------|-------------|-------|
| g/MJ Output | N/A | 0.68 |
| g/kg Dry Fuel | N/A | 10.27 |
| g/h | N/A | 11.96 |
| g/min | N/A | 0.20 |
| lb/MM Btu Output | N/A | 1.57 |

| | |
|-----------------------------|-------|
| Air/Fuel Ratio (A/F) | 25.09 |
|-----------------------------|-------|

VERSION:

2.2

12/14/2009

DILUTION TUNNEL & MISC. DATA - ASTM E2779 / E2515

Client: Thelin Hearth Products

Job #: 20-568

Model: Echo Pellet II

Tracking #: 0062

Run #: 1

Technician: SJB

Test Start Time: 8:47

Date: 2/10/2020

High Burn End Time (min): 60
 Medium Burn End Time (min): 180
 Total Sampling Time (min): 360
 Recording Interval (min): 1

Meter Box γ Factor: 1.012 (A)
 Meter Box γ Factor: 1.008 (B)
 Meter Box γ Factor: 1.000 (Ambient)

Induced Draft Check (in. H₂O): 0
 Smoke Capture Check (%): 100%
 Date Flue Pipe Last Cleaned: 2/10/2020

| | Pre-Test | Post Test | Avg. |
|------------------------------|----------|-----------|-----------------|
| Barometric Pressure (in. Hg) | 30.31 | 30.29 | 30.30 |
| Relative Humidity (%) | 39.7 | 32.2 | |
| Room Air Velocity (ft/min) | 0 | 0 | |
| Scale Audit (lbs) | 10.0 | 10.0 | |
| Ambient Sample Volume: | 0.000 | | ft ³ |

Sample Train Post-Test Leak Checks

| | | | |
|-----------|-------|-------|------------|
| (A) | 0.000 | cfm @ | -11 in. Hg |
| (B) | 0.000 | cfm @ | -10 in. Hg |
| (Ambient) | 0.000 | cfm @ | 0 in. Hg |

DILUTION TUNNEL FLOW

Traverse Data

| Point | dP (in H ₂ O) | Temp (°F) |
|--------|--------------------------|-----------|
| 1 | 0.044 | 94 |
| 2 | 0.056 | 94 |
| 3 | 0.056 | 94 |
| 4 | 0.048 | 94 |
| 5 | 0.048 | 94 |
| 6 | 0.058 | 94 |
| 7 | 0.054 | 94 |
| 8 | 0.046 | 94 |
| Center | 0.060 | 94 |

Dilution Tunnel H₂O: 2.00 percent
 Tunnel Diameter: 6 inches
 Pitot Tube Cp: 0.99 [unitless]
 Dilution Tunnel MW(dry): 29.00 lb/lb-mole
 Dilution Tunnel MW(wet): 28.78 lb/lb-mole
 Tunnel Area: 0.1963 ft²

V_{strav}: 15.39 ft/secV_{scent}: 16.52 ft/secF_p: 0.932 [ratio]

Initial Tunnel Flow: 169.9 scf/min

Static Pressure: -0.130 in. H₂O

TEST FUEL PROPERTIES

Default Fuel Values

| | | |
|-------------|--------|--------|
| Fuel Type: | D. Fir | Oak |
| HHV (kJ/kg) | 19,810 | 19,887 |
| %C | 48.73 | 50 |
| %H | 6.87 | 6.6 |
| %O | 43.9 | 42.9 |
| %Ash | 0.5 | 0.5 |

Actual Fuel Used Properties

| | |
|--------------------|---------------|
| Pellet Brand: | Bear Mountain |
| Pellet Fuel Grade: | PFI Premium |
| HHV (kJ/kg) | 20,357 |
| %C | 49.35 |
| %H | 6.14 |
| %O | 44.27 |
| %Ash | 0.24 |
| MC (%DB) | 2.54 |

PELLET STOVE PREBURN DATA - ASTM E2779

Client: Thelin Hearth Products

Job #: 20-568

Model: Echo Pellet II

Tracking #: 0062

Run #: 1

Technician: SJB

Date: 2/10/2020

 Recording Interval (min): 1
 Run Time (min): 60

| Elapsed Time (min) | Scale Reading (lbs) | Weight Change (lbs) | Average: | | |
|--------------------|---------------------|---------------------|----------------------------------|-----------|--------------|
| | | | -0.056 | 361 | 63 |
| | | | Flue Draft (in H ₂ O) | Flue (°F) | Ambient (°F) |
| 0 | 32.6 | - | -0.057 | 219 | 61 |
| 1 | 32.5 | -0.1 | -0.060 | 243 | 61 |
| 2 | 32.5 | 0 | -0.052 | 276 | 61 |
| 3 | 32.4 | -0.1 | -0.055 | 306 | 61 |
| 4 | 32.3 | -0.1 | -0.055 | 325 | 61 |
| 5 | 32.3 | 0 | -0.054 | 336 | 61 |
| 6 | 32.2 | -0.1 | -0.058 | 352 | 61 |
| 7 | 32.1 | -0.1 | -0.060 | 359 | 61 |
| 8 | 32.0 | -0.1 | -0.052 | 362 | 61 |
| 9 | 32.0 | 0 | -0.051 | 358 | 61 |
| 10 | 31.9 | -0.1 | -0.059 | 344 | 61 |
| 11 | 31.9 | 0 | -0.054 | 335 | 61 |
| 12 | 31.8 | -0.1 | -0.055 | 341 | 61 |
| 13 | 31.7 | -0.1 | -0.053 | 348 | 61 |
| 14 | 31.6 | -0.1 | -0.050 | 360 | 61 |
| 15 | 31.5 | -0.1 | -0.058 | 365 | 61 |
| 16 | 31.5 | 0 | -0.059 | 365 | 61 |
| 17 | 31.4 | -0.1 | -0.052 | 362 | 62 |
| 18 | 31.3 | -0.1 | -0.060 | 358 | 62 |
| 19 | 31.2 | -0.1 | -0.056 | 363 | 62 |
| 20 | 31.2 | 0 | -0.056 | 367 | 62 |
| 21 | 31.1 | -0.1 | -0.058 | 362 | 62 |
| 22 | 31.1 | 0 | -0.053 | 365 | 62 |
| 23 | 31.0 | -0.1 | -0.050 | 368 | 62 |
| 24 | 30.9 | -0.1 | -0.055 | 368 | 62 |
| 25 | 30.9 | 0 | -0.057 | 375 | 62 |
| 26 | 30.8 | -0.1 | -0.059 | 375 | 62 |
| 27 | 30.8 | 0 | -0.059 | 375 | 62 |
| 28 | 30.7 | -0.1 | -0.054 | 376 | 63 |
| 29 | 30.6 | -0.1 | -0.059 | 377 | 63 |
| 30 | 30.6 | 0 | -0.059 | 378 | 63 |
| 31 | 30.5 | -0.1 | -0.054 | 375 | 63 |
| 32 | 30.4 | -0.1 | -0.054 | 381 | 63 |
| 33 | 30.3 | -0.1 | -0.059 | 378 | 63 |
| 34 | 30.2 | -0.1 | -0.060 | 376 | 63 |
| 35 | 30.1 | -0.1 | -0.057 | 371 | 63 |
| 36 | 30.1 | 0 | -0.054 | 375 | 63 |
| 37 | 30.0 | -0.1 | -0.055 | 367 | 63 |
| 38 | 29.9 | -0.1 | -0.055 | 372 | 63 |
| 39 | 29.9 | 0 | -0.056 | 380 | 63 |
| 40 | 29.8 | -0.1 | -0.054 | 378 | 63 |
| 41 | 29.7 | -0.1 | -0.055 | 375 | 64 |
| 42 | 29.7 | 0 | -0.052 | 376 | 64 |
| 43 | 29.6 | -0.1 | -0.060 | 380 | 64 |
| 44 | 29.6 | 0 | -0.057 | 384 | 64 |
| 45 | 29.5 | -0.1 | -0.054 | 382 | 64 |
| 46 | 29.4 | -0.1 | -0.052 | 373 | 64 |

BOX A TEST DATA - ASTM E2779 / ASTM E2515

Client: Thelin Hearth ProductsJob #: 20-568Model: Echo Pellet IITracking #: 0062Run #: 1Technician: SJBDate: 2/10/2020

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 0 | 0.000 | | 0.069 | 0.00 | 67 | 0 | | 19.2 | | 98 | 382 | 65 | 64 |
| 1 | 0.145 | 0.145 | 0.067 | 2.25 | 67 | -2.92 | 103 | 19.2 | 0.0 | 98 | 386 | 65 | 64 |
| 2 | 0.290 | 0.145 | 0.068 | 2.26 | 67 | -0.36 | 102 | 19.1 | -0.1 | 98 | 387 | 65 | 64 |
| 3 | 0.435 | 0.145 | 0.068 | 2.25 | 67 | -1.63 | 102 | 19.0 | -0.1 | 98 | 386 | 66 | 64 |
| 4 | 0.580 | 0.145 | 0.069 | 2.25 | 68 | -0.49 | 101 | 19.0 | 0.0 | 98 | 384 | 66 | 64 |
| 5 | 0.725 | 0.145 | 0.070 | 2.26 | 68 | -1.8 | 101 | 18.8 | -0.2 | 98 | 380 | 66 | 64 |
| 6 | 0.870 | 0.145 | 0.069 | 2.26 | 68 | -1.41 | 101 | 18.8 | 0.0 | 98 | 378 | 66 | 64 |
| 7 | 1.015 | 0.145 | 0.068 | 2.25 | 68 | -1.37 | 102 | 18.8 | 0.0 | 98 | 383 | 66 | 64 |
| 8 | 1.160 | 0.145 | 0.068 | 2.24 | 68 | -1.79 | 102 | 18.7 | -0.1 | 98 | 390 | 66 | 64 |
| 9 | 1.305 | 0.145 | 0.068 | 2.25 | 68 | 0 | 102 | 18.5 | -0.2 | 98 | 385 | 67 | 64 |
| 10 | 1.450 | 0.145 | 0.065 | 2.27 | 69 | -2.18 | 104 | 18.6 | 0.1 | 98 | 383 | 67 | 64 |
| 11 | 1.595 | 0.145 | 0.068 | 2.24 | 69 | -2.66 | 102 | 18.5 | -0.1 | 98 | 384 | 67 | 64 |
| 12 | 1.740 | 0.145 | 0.066 | 2.27 | 69 | 0 | 103 | 18.4 | -0.1 | 98 | 381 | 67 | 64 |
| 13 | 1.885 | 0.145 | 0.068 | 2.24 | 70 | -1.82 | 102 | 18.4 | 0.0 | 98 | 384 | 67 | 64 |
| 14 | 2.030 | 0.145 | 0.067 | 2.25 | 70 | -2.75 | 103 | 18.3 | -0.1 | 98 | 385 | 67 | 64 |
| 15 | 2.175 | 0.145 | 0.067 | 2.24 | 70 | 0 | 103 | 18.1 | -0.2 | 98 | 391 | 67 | 64 |
| 16 | 2.320 | 0.145 | 0.066 | 2.23 | 71 | -0.19 | 103 | 18.1 | 0.0 | 98 | 389 | 67 | 64 |
| 17 | 2.465 | 0.145 | 0.069 | 2.24 | 71 | -2.84 | 101 | 18.1 | 0.0 | 98 | 391 | 67 | 64 |
| 18 | 2.610 | 0.145 | 0.070 | 2.25 | 71 | -2.16 | 100 | 18.0 | -0.1 | 98 | 393 | 68 | 64 |
| 19 | 2.755 | 0.145 | 0.067 | 2.24 | 72 | -0.96 | 102 | 17.9 | -0.1 | 98 | 389 | 68 | 64 |
| 20 | 2.900 | 0.145 | 0.064 | 2.26 | 72 | -2.57 | 104 | 17.8 | -0.1 | 98 | 393 | 68 | 64 |
| 21 | 3.045 | 0.145 | 0.066 | 2.27 | 72 | -1.41 | 103 | 17.8 | 0.0 | 98 | 383 | 68 | 64 |
| 22 | 3.190 | 0.145 | 0.068 | 2.27 | 73 | -1.04 | 101 | 17.7 | -0.1 | 99 | 393 | 68 | 64 |
| 23 | 3.335 | 0.145 | 0.068 | 2.24 | 73 | -1.89 | 101 | 17.7 | 0.0 | 99 | 393 | 68 | 64 |
| 24 | 3.480 | 0.145 | 0.069 | 2.26 | 73 | -1.18 | 101 | 17.6 | -0.1 | 99 | 388 | 68 | 64 |
| 25 | 3.625 | 0.145 | 0.069 | 2.28 | 74 | -2.84 | 100 | 17.5 | -0.1 | 99 | 389 | 69 | 64 |
| 26 | 3.770 | 0.145 | 0.070 | 2.26 | 74 | 0 | 100 | 17.4 | -0.1 | 99 | 384 | 69 | 64 |
| 27 | 3.915 | 0.145 | 0.067 | 2.27 | 74 | -2.48 | 102 | 17.4 | 0.0 | 99 | 385 | 69 | 64 |
| 28 | 4.060 | 0.145 | 0.067 | 2.26 | 75 | -1.09 | 102 | 17.3 | -0.1 | 99 | 392 | 69 | 64 |
| 29 | 4.205 | 0.145 | 0.068 | 2.24 | 75 | -0.96 | 101 | 17.2 | -0.1 | 99 | 393 | 70 | 64 |
| 30 | 4.348 | 0.143 | 0.068 | 2.25 | 76 | 0 | 99 | 17.1 | -0.1 | 99 | 395 | 70 | 64 |
| 31 | 4.493 | 0.145 | 0.068 | 2.23 | 76 | -2.78 | 101 | 17.1 | 0.0 | 99 | 388 | 70 | 64 |
| 32 | 4.638 | 0.145 | 0.066 | 2.24 | 76 | -0.53 | 102 | 17.0 | -0.1 | 99 | 393 | 70 | 64 |

BOX A TEST DATA - ASTM E2779 / ASTM E2515

Client: Thelin Hearth ProductsJob #: 20-568Model: Echo Pellet IITracking #: 0062Run #: 1Technician: SJBDate: 2/10/2020

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 33 | 4.783 | 0.145 | 0.066 | 2.23 | 77 | 0 | 102 | 16.9 | -0.1 | 99 | 394 | 70 | 65 |
| 34 | 4.928 | 0.145 | 0.066 | 2.23 | 77 | -0.18 | 102 | 16.8 | -0.1 | 99 | 395 | 70 | 65 |
| 35 | 5.073 | 0.145 | 0.067 | 2.23 | 77 | -2.83 | 101 | 16.7 | -0.1 | 99 | 392 | 70 | 65 |
| 36 | 5.218 | 0.145 | 0.064 | 2.21 | 78 | -0.26 | 103 | 16.7 | 0.0 | 99 | 393 | 70 | 65 |
| 37 | 5.363 | 0.145 | 0.068 | 2.23 | 78 | 0 | 100 | 16.7 | 0.0 | 99 | 393 | 70 | 65 |
| 38 | 5.508 | 0.145 | 0.066 | 2.21 | 78 | -2.4 | 102 | 16.6 | -0.1 | 99 | 387 | 70 | 65 |
| 39 | 5.653 | 0.145 | 0.067 | 2.23 | 79 | -0.67 | 101 | 16.5 | -0.1 | 99 | 387 | 70 | 65 |
| 40 | 5.798 | 0.145 | 0.067 | 2.21 | 79 | -2.14 | 101 | 16.4 | -0.1 | 99 | 385 | 70 | 65 |
| 41 | 5.943 | 0.145 | 0.064 | 2.24 | 79 | -2.54 | 103 | 16.4 | 0.0 | 99 | 382 | 70 | 65 |
| 42 | 6.088 | 0.145 | 0.068 | 2.22 | 80 | 0 | 100 | 16.3 | -0.1 | 99 | 387 | 70 | 65 |
| 43 | 6.233 | 0.145 | 0.068 | 2.22 | 80 | -1.76 | 100 | 16.3 | 0.0 | 99 | 385 | 70 | 65 |
| 44 | 6.378 | 0.145 | 0.066 | 2.22 | 80 | 0 | 102 | 16.2 | -0.1 | 100 | 380 | 70 | 65 |
| 45 | 6.523 | 0.145 | 0.066 | 2.24 | 80 | -0.19 | 102 | 16.1 | -0.1 | 100 | 386 | 70 | 65 |
| 46 | 6.668 | 0.145 | 0.065 | 2.24 | 81 | -1.62 | 102 | 16.0 | -0.1 | 100 | 387 | 70 | 65 |
| 47 | 6.813 | 0.145 | 0.068 | 2.24 | 81 | -1.76 | 100 | 16.0 | 0.0 | 100 | 384 | 70 | 65 |
| 48 | 6.958 | 0.145 | 0.068 | 2.20 | 81 | -2.56 | 100 | 15.9 | -0.1 | 100 | 375 | 71 | 65 |
| 49 | 7.103 | 0.145 | 0.066 | 2.27 | 82 | -0.49 | 101 | 15.8 | -0.1 | 100 | 383 | 71 | 65 |
| 50 | 7.248 | 0.145 | 0.065 | 2.23 | 82 | -2.19 | 102 | 15.7 | -0.1 | 100 | 385 | 71 | 65 |
| 51 | 7.393 | 0.145 | 0.068 | 2.24 | 82 | -2.57 | 100 | 15.7 | 0.0 | 100 | 387 | 71 | 65 |
| 52 | 7.538 | 0.145 | 0.066 | 2.23 | 82 | -0.13 | 101 | 15.6 | -0.1 | 100 | 390 | 71 | 65 |
| 53 | 7.683 | 0.145 | 0.067 | 2.23 | 83 | -1.41 | 100 | 15.5 | -0.1 | 100 | 394 | 71 | 65 |
| 54 | 7.828 | 0.145 | 0.065 | 2.22 | 83 | -0.06 | 102 | 15.5 | 0.0 | 100 | 395 | 71 | 65 |
| 55 | 7.973 | 0.145 | 0.066 | 2.22 | 83 | -2.38 | 101 | 15.4 | -0.1 | 100 | 393 | 71 | 65 |
| 56 | 8.118 | 0.145 | 0.063 | 2.23 | 83 | -2.83 | 103 | 15.3 | -0.1 | 101 | 393 | 72 | 65 |
| 57 | 8.263 | 0.145 | 0.066 | 2.22 | 84 | -0.26 | 101 | 15.3 | 0.0 | 101 | 392 | 72 | 65 |
| 58 | 8.408 | 0.145 | 0.069 | 2.21 | 84 | 0 | 99 | 15.2 | -0.1 | 101 | 387 | 72 | 65 |
| 59 | 8.553 | 0.145 | 0.067 | 2.21 | 84 | -2.4 | 100 | 15.1 | -0.1 | 101 | 385 | 72 | 65 |
| 60 | 8.718 | 0.165 | 0.068 | 2.25 | 84 | -0.71 | 113 | 15.0 | -0.1 | 101 | 384 | 72 | 65 |
| 61 | 8.873 | 0.155 | 0.066 | 2.31 | 85 | 0 | 107 | 15.0 | 0.0 | 99 | 375 | 72 | 65 |
| 62 | 9.018 | 0.145 | 0.063 | 2.27 | 85 | -2.52 | 103 | 14.9 | -0.1 | 98 | 360 | 72 | 65 |
| 63 | 9.166 | 0.148 | 0.068 | 2.26 | 85 | -1.65 | 101 | 14.9 | 0.0 | 97 | 356 | 72 | 65 |
| 64 | 9.311 | 0.145 | 0.066 | 2.27 | 86 | -2.78 | 100 | 14.8 | -0.1 | 97 | 355 | 72 | 65 |
| 65 | 9.460 | 0.149 | 0.067 | 2.27 | 86 | -2.85 | 102 | 14.7 | -0.1 | 97 | 361 | 72 | 65 |

BOX A TEST DATA - ASTM E2779 / ASTM E2515

Client: Thelin Hearth ProductsJob #: 20-568Model: Echo Pellet IITracking #: 0062Run #: 1Technician: SJBDate: 2/10/2020

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 66 | 9.604 | 0.144 | 0.066 | 2.27 | 86 | -2.62 | 99 | 14.6 | -0.1 | 97 | 364 | 72 | 65 |
| 67 | 9.753 | 0.149 | 0.070 | 2.27 | 86 | -0.97 | 100 | 14.6 | 0.0 | 97 | 369 | 72 | 65 |
| 68 | 9.898 | 0.145 | 0.069 | 2.26 | 86 | -2.41 | 98 | 14.5 | -0.1 | 96 | 368 | 72 | 65 |
| 69 | 10.047 | 0.149 | 0.065 | 2.26 | 87 | -2.68 | 103 | 14.4 | -0.1 | 96 | 364 | 72 | 65 |
| 70 | 10.192 | 0.145 | 0.065 | 2.27 | 87 | -0.39 | 101 | 14.4 | 0.0 | 96 | 361 | 72 | 65 |
| 71 | 10.340 | 0.148 | 0.063 | 2.25 | 87 | -1.99 | 104 | 14.3 | -0.1 | 96 | 359 | 72 | 65 |
| 72 | 10.485 | 0.145 | 0.066 | 2.27 | 87 | -2.77 | 100 | 14.3 | 0.0 | 96 | 359 | 72 | 65 |
| 73 | 10.634 | 0.149 | 0.064 | 2.26 | 87 | -1.93 | 104 | 14.2 | -0.1 | 96 | 357 | 72 | 65 |
| 74 | 10.779 | 0.145 | 0.065 | 2.28 | 88 | -2.9 | 100 | 14.1 | -0.1 | 96 | 355 | 72 | 65 |
| 75 | 10.928 | 0.149 | 0.065 | 2.27 | 88 | 0 | 103 | 14.1 | 0.0 | 96 | 357 | 72 | 65 |
| 76 | 11.073 | 0.145 | 0.068 | 2.29 | 88 | 0 | 98 | 14.0 | -0.1 | 95 | 357 | 72 | 65 |
| 77 | 11.221 | 0.148 | 0.067 | 2.26 | 88 | -2.91 | 101 | 14.0 | 0.0 | 95 | 352 | 72 | 65 |
| 78 | 11.367 | 0.146 | 0.068 | 2.24 | 88 | -1.48 | 99 | 13.9 | -0.1 | 95 | 351 | 72 | 65 |
| 79 | 11.516 | 0.149 | 0.062 | 2.26 | 89 | 0 | 105 | 13.9 | 0.0 | 95 | 346 | 72 | 65 |
| 80 | 11.662 | 0.146 | 0.066 | 2.26 | 89 | -2.71 | 100 | 13.8 | -0.1 | 95 | 351 | 72 | 65 |
| 81 | 11.811 | 0.149 | 0.063 | 2.27 | 89 | -2.49 | 105 | 13.7 | -0.1 | 95 | 350 | 72 | 65 |
| 82 | 11.957 | 0.146 | 0.065 | 2.27 | 89 | 0 | 101 | 13.7 | 0.0 | 95 | 353 | 72 | 65 |
| 83 | 12.105 | 0.148 | 0.063 | 2.27 | 89 | -2.82 | 104 | 13.6 | -0.1 | 94 | 351 | 72 | 65 |
| 84 | 12.251 | 0.146 | 0.064 | 2.25 | 89 | -0.76 | 102 | 13.6 | 0.0 | 95 | 349 | 72 | 65 |
| 85 | 12.399 | 0.148 | 0.067 | 2.26 | 89 | -2.57 | 101 | 13.5 | -0.1 | 95 | 350 | 72 | 65 |
| 86 | 12.546 | 0.147 | 0.066 | 2.27 | 90 | 0 | 101 | 13.4 | -0.1 | 96 | 352 | 72 | 65 |
| 87 | 12.694 | 0.148 | 0.067 | 2.27 | 90 | -1.25 | 101 | 13.4 | 0.0 | 95 | 350 | 72 | 65 |
| 88 | 12.841 | 0.147 | 0.067 | 2.25 | 90 | -2.84 | 100 | 13.3 | -0.1 | 95 | 350 | 72 | 66 |
| 89 | 12.989 | 0.148 | 0.066 | 2.26 | 90 | 0 | 101 | 13.3 | 0.0 | 95 | 352 | 72 | 65 |
| 90 | 13.137 | 0.148 | 0.066 | 2.27 | 90 | -0.03 | 101 | 13.2 | -0.1 | 95 | 347 | 72 | 65 |
| 91 | 13.284 | 0.147 | 0.064 | 2.29 | 90 | -0.32 | 102 | 13.2 | 0.0 | 95 | 351 | 72 | 65 |
| 92 | 13.432 | 0.148 | 0.067 | 2.28 | 90 | -2.44 | 101 | 13.1 | -0.1 | 95 | 342 | 71 | 65 |
| 93 | 13.579 | 0.147 | 0.066 | 2.25 | 91 | -1.42 | 100 | 13.0 | -0.1 | 95 | 348 | 72 | 65 |
| 94 | 13.728 | 0.149 | 0.065 | 2.27 | 91 | -3.04 | 103 | 13.0 | 0.0 | 96 | 357 | 72 | 65 |
| 95 | 13.875 | 0.147 | 0.067 | 2.30 | 91 | 0 | 100 | 12.9 | -0.1 | 95 | 352 | 72 | 65 |
| 96 | 14.024 | 0.149 | 0.065 | 2.28 | 91 | 0 | 103 | 12.9 | 0.0 | 96 | 360 | 72 | 65 |
| 97 | 14.170 | 0.146 | 0.067 | 2.27 | 91 | -2.85 | 99 | 12.8 | -0.1 | 96 | 356 | 72 | 65 |
| 98 | 14.319 | 0.149 | 0.068 | 2.23 | 91 | -2.9 | 100 | 12.7 | -0.1 | 96 | 357 | 72 | 65 |

BOX A TEST DATA - ASTM E2779 / ASTM E2515

Client: Thelin Hearth ProductsJob #: 20-568Model: Echo Pellet IITracking #: 0062Run #: 1Technician: SJBDate: 2/10/2020

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 99 | 14.465 | 0.146 | 0.069 | 2.26 | 91 | -0.16 | 98 | 12.7 | 0.0 | 95 | 361 | 72 | 65 |
| 100 | 14.615 | 0.150 | 0.068 | 2.26 | 91 | -0.38 | 101 | 12.6 | -0.1 | 95 | 358 | 72 | 65 |
| 101 | 14.760 | 0.145 | 0.069 | 2.26 | 91 | -1.33 | 97 | 12.5 | -0.1 | 96 | 357 | 72 | 65 |
| 102 | 14.909 | 0.149 | 0.068 | 2.28 | 92 | -2.48 | 100 | 12.5 | 0.0 | 95 | 352 | 72 | 65 |
| 103 | 15.054 | 0.145 | 0.068 | 2.28 | 92 | -1.32 | 97 | 12.4 | -0.1 | 95 | 347 | 71 | 65 |
| 104 | 15.204 | 0.150 | 0.069 | 2.26 | 92 | 0 | 100 | 12.4 | 0.0 | 95 | 349 | 71 | 65 |
| 105 | 15.350 | 0.146 | 0.066 | 2.26 | 92 | -1.83 | 100 | 12.3 | -0.1 | 96 | 353 | 72 | 65 |
| 106 | 15.501 | 0.151 | 0.069 | 2.27 | 92 | -1.66 | 101 | 12.2 | -0.1 | 96 | 358 | 72 | 65 |
| 107 | 15.645 | 0.144 | 0.064 | 2.27 | 92 | -2.66 | 100 | 12.2 | 0.0 | 96 | 360 | 72 | 65 |
| 108 | 15.796 | 0.151 | 0.070 | 2.27 | 92 | -2.43 | 100 | 12.1 | -0.1 | 96 | 362 | 72 | 65 |
| 109 | 15.941 | 0.145 | 0.066 | 2.28 | 92 | -2.92 | 99 | 12.0 | -0.1 | 95 | 362 | 72 | 65 |
| 110 | 16.092 | 0.151 | 0.066 | 2.26 | 92 | -0.36 | 103 | 12.0 | 0.0 | 96 | 361 | 72 | 65 |
| 111 | 16.237 | 0.145 | 0.069 | 2.28 | 92 | -1.63 | 97 | 11.9 | -0.1 | 96 | 356 | 72 | 65 |
| 112 | 16.389 | 0.152 | 0.067 | 2.26 | 92 | -0.49 | 103 | 11.9 | 0.0 | 96 | 357 | 72 | 66 |
| 113 | 16.533 | 0.144 | 0.068 | 2.25 | 93 | -1.8 | 97 | 11.8 | -0.1 | 96 | 355 | 72 | 65 |
| 114 | 16.685 | 0.152 | 0.067 | 2.26 | 93 | -1.41 | 103 | 11.8 | 0.0 | 96 | 357 | 72 | 65 |
| 115 | 16.829 | 0.144 | 0.070 | 2.27 | 93 | -1.37 | 95 | 11.7 | -0.1 | 96 | 358 | 71 | 66 |
| 116 | 16.980 | 0.151 | 0.066 | 2.27 | 93 | -1.79 | 103 | 11.6 | -0.1 | 96 | 360 | 72 | 65 |
| 117 | 17.126 | 0.146 | 0.064 | 2.24 | 93 | 0 | 101 | 11.6 | 0.0 | 95 | 357 | 72 | 65 |
| 118 | 17.277 | 0.151 | 0.069 | 2.26 | 93 | -2.18 | 101 | 11.5 | -0.1 | 95 | 354 | 72 | 65 |
| 119 | 17.422 | 0.145 | 0.067 | 2.28 | 93 | -2.66 | 98 | 11.5 | 0.0 | 95 | 353 | 72 | 65 |
| 120 | 17.572 | 0.150 | 0.067 | 2.26 | 93 | 0 | 101 | 11.4 | -0.1 | 96 | 351 | 72 | 66 |
| 121 | 17.717 | 0.145 | 0.063 | 2.27 | 93 | -1.82 | 101 | 11.3 | -0.1 | 96 | 358 | 72 | 65 |
| 122 | 17.866 | 0.149 | 0.064 | 2.26 | 93 | -2.75 | 103 | 11.3 | 0.0 | 96 | 357 | 72 | 65 |
| 123 | 18.012 | 0.146 | 0.070 | 2.24 | 93 | 0 | 97 | 11.2 | -0.1 | 96 | 352 | 72 | 65 |
| 124 | 18.161 | 0.149 | 0.065 | 2.24 | 93 | -2.74 | 102 | 11.2 | 0.0 | 96 | 350 | 72 | 65 |
| 125 | 18.308 | 0.147 | 0.066 | 2.27 | 93 | -0.36 | 100 | 11.1 | -0.1 | 96 | 356 | 72 | 66 |
| 126 | 18.457 | 0.149 | 0.066 | 2.26 | 93 | -2.44 | 102 | 11.0 | -0.1 | 96 | 356 | 72 | 65 |
| 127 | 18.603 | 0.146 | 0.064 | 2.26 | 93 | -2.26 | 101 | 11.0 | 0.0 | 96 | 356 | 72 | 66 |
| 128 | 18.752 | 0.149 | 0.064 | 2.26 | 94 | -0.43 | 103 | 10.9 | -0.1 | 96 | 354 | 72 | 66 |
| 129 | 18.899 | 0.147 | 0.066 | 2.27 | 94 | 0 | 100 | 10.9 | 0.0 | 96 | 358 | 72 | 66 |
| 130 | 19.047 | 0.148 | 0.066 | 2.26 | 94 | -0.89 | 101 | 10.8 | -0.1 | 96 | 353 | 72 | 66 |
| 131 | 19.195 | 0.148 | 0.064 | 2.26 | 94 | -0.55 | 102 | 10.8 | 0.0 | 96 | 352 | 72 | 66 |

BOX A TEST DATA - ASTM E2779 / ASTM E2515

Client: Thelin Hearth ProductsJob #: 20-568Model: Echo Pellet IITracking #: 0062Run #: 1Technician: SJBDate: 2/10/2020

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 132 | 19.343 | 0.148 | 0.066 | 2.25 | 94 | -0.77 | 101 | 10.7 | -0.1 | 96 | 353 | 72 | 66 |
| 133 | 19.492 | 0.149 | 0.065 | 2.25 | 94 | -0.41 | 102 | 10.6 | -0.1 | 97 | 358 | 72 | 66 |
| 134 | 19.639 | 0.147 | 0.067 | 2.25 | 94 | -1.5 | 99 | 10.5 | -0.1 | 97 | 362 | 72 | 66 |
| 135 | 19.788 | 0.149 | 0.066 | 2.25 | 94 | -2.78 | 101 | 10.5 | 0.0 | 97 | 361 | 72 | 66 |
| 136 | 19.934 | 0.146 | 0.064 | 2.26 | 94 | -0.53 | 101 | 10.4 | -0.1 | 97 | 362 | 72 | 66 |
| 137 | 20.084 | 0.150 | 0.069 | 2.25 | 94 | 0 | 100 | 10.4 | 0.0 | 97 | 359 | 72 | 66 |
| 138 | 20.230 | 0.146 | 0.066 | 2.25 | 94 | -0.18 | 99 | 10.3 | -0.1 | 96 | 356 | 72 | 66 |
| 139 | 20.379 | 0.149 | 0.069 | 2.26 | 94 | -2.83 | 99 | 10.1 | -0.2 | 97 | 357 | 72 | 66 |
| 140 | 20.525 | 0.146 | 0.062 | 2.26 | 94 | -0.26 | 103 | 10.1 | 0.0 | 97 | 354 | 72 | 66 |
| 141 | 20.675 | 0.150 | 0.068 | 2.25 | 94 | 0 | 101 | 10.1 | 0.0 | 97 | 357 | 72 | 66 |
| 142 | 20.820 | 0.145 | 0.066 | 2.24 | 94 | -2.4 | 99 | 10.1 | 0.0 | 97 | 352 | 72 | 66 |
| 143 | 20.970 | 0.150 | 0.068 | 2.25 | 95 | -0.67 | 100 | 10.1 | 0.0 | 96 | 352 | 72 | 66 |
| 144 | 21.115 | 0.145 | 0.065 | 2.27 | 95 | -2.14 | 99 | 10.0 | -0.1 | 96 | 354 | 72 | 65 |
| 145 | 21.265 | 0.150 | 0.063 | 2.24 | 95 | -2.54 | 104 | 9.9 | -0.1 | 97 | 356 | 72 | 66 |
| 146 | 21.411 | 0.146 | 0.068 | 2.27 | 95 | 0 | 98 | 9.9 | 0.0 | 97 | 355 | 72 | 66 |
| 147 | 21.561 | 0.150 | 0.069 | 2.24 | 95 | -1.76 | 100 | 9.8 | -0.1 | 97 | 346 | 72 | 66 |
| 148 | 21.706 | 0.145 | 0.064 | 2.25 | 95 | 0 | 100 | 9.7 | -0.1 | 97 | 346 | 72 | 66 |
| 149 | 21.856 | 0.150 | 0.061 | 2.24 | 95 | -0.19 | 106 | 9.7 | 0.0 | 96 | 346 | 72 | 66 |
| 150 | 22.001 | 0.145 | 0.066 | 2.23 | 95 | -2.84 | 98 | 9.7 | 0.0 | 96 | 344 | 72 | 66 |
| 151 | 22.152 | 0.151 | 0.064 | 2.24 | 95 | -2.16 | 104 | 9.6 | -0.1 | 96 | 342 | 72 | 66 |
| 152 | 22.296 | 0.144 | 0.065 | 2.25 | 95 | -0.96 | 99 | 9.5 | -0.1 | 96 | 341 | 72 | 66 |
| 153 | 22.448 | 0.152 | 0.067 | 2.24 | 95 | -2.57 | 102 | 9.5 | 0.0 | 96 | 347 | 72 | 65 |
| 154 | 22.593 | 0.145 | 0.066 | 2.24 | 95 | -1.41 | 98 | 9.4 | -0.1 | 96 | 346 | 72 | 66 |
| 155 | 22.744 | 0.151 | 0.063 | 2.23 | 95 | -1.04 | 105 | 9.4 | 0.0 | 96 | 347 | 72 | 66 |
| 156 | 22.889 | 0.145 | 0.068 | 2.25 | 95 | -1.89 | 97 | 9.3 | -0.1 | 97 | 350 | 72 | 65 |
| 157 | 23.039 | 0.150 | 0.070 | 2.25 | 95 | -1.18 | 99 | 9.2 | -0.1 | 97 | 348 | 72 | 66 |
| 158 | 23.184 | 0.145 | 0.062 | 2.23 | 95 | -2.84 | 102 | 9.2 | 0.0 | 97 | 356 | 72 | 66 |
| 159 | 23.334 | 0.150 | 0.069 | 2.24 | 95 | 0 | 100 | 9.1 | -0.1 | 97 | 353 | 72 | 66 |
| 160 | 23.480 | 0.146 | 0.064 | 2.23 | 95 | -2.48 | 101 | 9.1 | 0.0 | 97 | 354 | 72 | 66 |
| 161 | 23.630 | 0.150 | 0.068 | 2.21 | 95 | -1.09 | 100 | 9.0 | -0.1 | 97 | 358 | 72 | 66 |
| 162 | 23.775 | 0.145 | 0.066 | 2.27 | 95 | 0 | 99 | 8.9 | -0.1 | 97 | 359 | 72 | 66 |
| 163 | 23.924 | 0.149 | 0.068 | 2.24 | 96 | -0.04 | 100 | 8.9 | 0.0 | 97 | 361 | 72 | 66 |
| 164 | 24.070 | 0.146 | 0.068 | 2.23 | 96 | -0.85 | 98 | 8.8 | -0.1 | 98 | 356 | 72 | 66 |

BOX A TEST DATA - ASTM E2779 / ASTM E2515

Client: Thelin Hearth ProductsJob #: 20-568Model: Echo Pellet IITracking #: 0062Run #: 1Technician: SJBDate: 2/10/2020

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 165 | 24.219 | 0.149 | 0.066 | 2.25 | 96 | -2.13 | 101 | 8.8 | 0.0 | 97 | 355 | 72 | 66 |
| 166 | 24.365 | 0.146 | 0.068 | 2.25 | 96 | -2.77 | 98 | 8.7 | -0.1 | 97 | 356 | 72 | 66 |
| 167 | 24.514 | 0.149 | 0.067 | 2.24 | 96 | -0.3 | 100 | 8.7 | 0.0 | 97 | 350 | 72 | 66 |
| 168 | 24.660 | 0.146 | 0.066 | 2.24 | 96 | 0 | 99 | 8.5 | -0.2 | 97 | 349 | 72 | 66 |
| 169 | 24.810 | 0.150 | 0.066 | 2.26 | 96 | -2.83 | 102 | 8.5 | 0.0 | 97 | 351 | 72 | 66 |
| 170 | 24.956 | 0.146 | 0.064 | 2.26 | 96 | -0.28 | 101 | 8.5 | 0.0 | 97 | 355 | 72 | 66 |
| 171 | 25.105 | 0.149 | 0.070 | 2.27 | 96 | -1.52 | 98 | 8.4 | -0.1 | 97 | 355 | 72 | 66 |
| 172 | 25.252 | 0.147 | 0.070 | 2.26 | 96 | 0 | 97 | 8.4 | 0.0 | 97 | 358 | 72 | 66 |
| 173 | 25.401 | 0.149 | 0.065 | 2.24 | 96 | -2.7 | 102 | 8.3 | -0.1 | 97 | 360 | 72 | 66 |
| 174 | 25.549 | 0.148 | 0.070 | 2.26 | 96 | -2.51 | 97 | 8.2 | -0.1 | 97 | 355 | 72 | 66 |
| 175 | 25.697 | 0.148 | 0.066 | 2.24 | 96 | -1.61 | 100 | 8.2 | 0.0 | 97 | 357 | 72 | 66 |
| 176 | 25.846 | 0.149 | 0.068 | 2.24 | 96 | 0 | 100 | 8.1 | -0.1 | 97 | 359 | 72 | 66 |
| 177 | 25.993 | 0.147 | 0.068 | 2.26 | 96 | -0.1 | 98 | 8.1 | 0.0 | 98 | 357 | 72 | 66 |
| 178 | 26.142 | 0.149 | 0.067 | 2.25 | 96 | -0.27 | 100 | 7.9 | -0.2 | 98 | 353 | 72 | 66 |
| 179 | 26.288 | 0.146 | 0.067 | 2.25 | 96 | -0.07 | 98 | 7.9 | 0.0 | 97 | 353 | 72 | 66 |
| 180 | 26.438 | 0.150 | 0.068 | 2.24 | 96 | -0.35 | 100 | 7.9 | 0.0 | 97 | 354 | 72 | 66 |
| 181 | 26.584 | 0.146 | 0.068 | 2.22 | 96 | -2.35 | 97 | 7.8 | -0.1 | 96 | 341 | 72 | 66 |
| 182 | 26.734 | 0.150 | 0.064 | 2.24 | 96 | -0.19 | 103 | 7.8 | 0.0 | 95 | 332 | 72 | 66 |
| 183 | 26.879 | 0.145 | 0.066 | 2.23 | 96 | -0.21 | 98 | 7.8 | 0.0 | 94 | 324 | 72 | 66 |
| 184 | 27.029 | 0.150 | 0.067 | 2.23 | 96 | -2.7 | 101 | 7.7 | -0.1 | 94 | 318 | 72 | 66 |
| 185 | 27.174 | 0.145 | 0.068 | 2.24 | 96 | 0 | 97 | 7.7 | 0.0 | 93 | 311 | 72 | 66 |
| 186 | 27.323 | 0.149 | 0.068 | 2.25 | 96 | 0 | 99 | 7.7 | 0.0 | 93 | 306 | 72 | 66 |
| 187 | 27.468 | 0.145 | 0.063 | 2.23 | 97 | -2.29 | 100 | 7.7 | 0.0 | 92 | 305 | 72 | 66 |
| 188 | 27.619 | 0.151 | 0.064 | 2.25 | 97 | -2.9 | 103 | 7.6 | -0.1 | 92 | 303 | 72 | 66 |
| 189 | 27.764 | 0.145 | 0.067 | 2.23 | 97 | -1.05 | 97 | 7.4 | -0.2 | 92 | 298 | 72 | 66 |
| 190 | 27.914 | 0.150 | 0.063 | 2.23 | 97 | -2.59 | 103 | 7.5 | 0.1 | 91 | 301 | 72 | 66 |
| 191 | 28.059 | 0.145 | 0.068 | 2.24 | 97 | 0 | 96 | 7.4 | -0.1 | 92 | 307 | 72 | 66 |
| 192 | 28.209 | 0.150 | 0.064 | 2.27 | 97 | -0.05 | 103 | 7.4 | 0.0 | 92 | 302 | 72 | 66 |
| 193 | 28.354 | 0.145 | 0.064 | 2.22 | 97 | -0.84 | 99 | 7.4 | 0.0 | 92 | 304 | 72 | 66 |
| 194 | 28.505 | 0.151 | 0.069 | 2.21 | 97 | -2.37 | 99 | 7.3 | -0.1 | 91 | 307 | 72 | 66 |
| 195 | 28.649 | 0.144 | 0.065 | 2.22 | 97 | 0 | 98 | 7.3 | 0.0 | 92 | 307 | 72 | 66 |
| 196 | 28.801 | 0.152 | 0.065 | 2.25 | 97 | -0.89 | 103 | 7.1 | -0.2 | 91 | 311 | 72 | 66 |
| 197 | 28.945 | 0.144 | 0.068 | 2.23 | 97 | -0.35 | 96 | 7.2 | 0.1 | 92 | 311 | 72 | 66 |

BOX A TEST DATA - ASTM E2779 / ASTM E2515

Client: Thelin Hearth ProductsJob #: 20-568Model: Echo Pellet IITracking #: 0062Run #: 1Technician: SJBDate: 2/10/2020

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 198 | 29.096 | 0.151 | 0.065 | 2.24 | 97 | 0 | 103 | 7.1 | -0.1 | 92 | 311 | 72 | 66 |
| 199 | 29.241 | 0.145 | 0.068 | 2.23 | 97 | 0 | 96 | 7.1 | 0.0 | 92 | 308 | 72 | 66 |
| 200 | 29.391 | 0.150 | 0.064 | 2.25 | 97 | -0.49 | 103 | 7.1 | 0.0 | 91 | 306 | 72 | 66 |
| 201 | 29.536 | 0.145 | 0.068 | 2.26 | 97 | 0 | 96 | 7.0 | -0.1 | 92 | 303 | 72 | 66 |
| 202 | 29.686 | 0.150 | 0.068 | 2.26 | 97 | 0 | 100 | 7.0 | 0.0 | 92 | 301 | 72 | 66 |
| 203 | 29.832 | 0.146 | 0.064 | 2.24 | 97 | -2.66 | 100 | 6.9 | -0.1 | 91 | 305 | 72 | 66 |
| 204 | 29.982 | 0.150 | 0.067 | 2.22 | 97 | 0 | 100 | 6.9 | 0.0 | 91 | 309 | 72 | 65 |
| 205 | 30.127 | 0.145 | 0.068 | 2.23 | 97 | -2.75 | 96 | 6.7 | -0.2 | 92 | 311 | 72 | 66 |
| 206 | 30.277 | 0.150 | 0.067 | 2.22 | 97 | -0.36 | 100 | 6.8 | 0.1 | 92 | 310 | 72 | 66 |
| 207 | 30.422 | 0.145 | 0.068 | 2.22 | 97 | 0 | 96 | 6.8 | 0.0 | 92 | 306 | 72 | 66 |
| 208 | 30.572 | 0.150 | 0.066 | 2.24 | 97 | -0.02 | 101 | 6.7 | -0.1 | 91 | 310 | 72 | 66 |
| 209 | 30.717 | 0.145 | 0.068 | 2.23 | 97 | -0.37 | 96 | 6.6 | -0.1 | 92 | 312 | 72 | 66 |
| 210 | 30.866 | 0.149 | 0.066 | 2.23 | 97 | -1.4 | 100 | 6.6 | 0.0 | 92 | 310 | 72 | 66 |
| 211 | 31.012 | 0.146 | 0.067 | 2.21 | 97 | 0 | 98 | 6.5 | -0.1 | 92 | 313 | 72 | 66 |
| 212 | 31.161 | 0.149 | 0.066 | 2.24 | 97 | -2.79 | 100 | 6.5 | 0.0 | 92 | 311 | 72 | 66 |
| 213 | 31.308 | 0.147 | 0.064 | 2.23 | 97 | -2.86 | 101 | 6.5 | 0.0 | 91 | 309 | 72 | 66 |
| 214 | 31.456 | 0.148 | 0.067 | 2.27 | 97 | 0 | 99 | 6.4 | -0.1 | 91 | 308 | 72 | 66 |
| 215 | 31.603 | 0.147 | 0.067 | 2.22 | 97 | 0 | 98 | 6.4 | 0.0 | 91 | 307 | 72 | 66 |
| 216 | 31.751 | 0.148 | 0.067 | 2.23 | 97 | -0.23 | 99 | 6.3 | -0.1 | 91 | 307 | 72 | 66 |
| 217 | 31.898 | 0.147 | 0.066 | 2.23 | 97 | 0 | 99 | 6.2 | -0.1 | 91 | 299 | 72 | 66 |
| 218 | 32.046 | 0.148 | 0.068 | 2.22 | 97 | -1.84 | 98 | 6.2 | 0.0 | 91 | 297 | 72 | 66 |
| 219 | 32.195 | 0.149 | 0.068 | 2.23 | 97 | -0.94 | 99 | 6.2 | 0.0 | 91 | 296 | 72 | 66 |
| 220 | 32.342 | 0.147 | 0.066 | 2.24 | 97 | -0.96 | 99 | 6.2 | 0.0 | 91 | 298 | 72 | 66 |
| 221 | 32.490 | 0.148 | 0.063 | 2.23 | 97 | -0.68 | 102 | 6.1 | -0.1 | 91 | 304 | 72 | 66 |
| 222 | 32.637 | 0.147 | 0.065 | 2.23 | 97 | 0 | 100 | 6.1 | 0.0 | 91 | 307 | 72 | 66 |
| 223 | 32.786 | 0.149 | 0.066 | 2.23 | 98 | -2.83 | 100 | 6.0 | -0.1 | 91 | 305 | 72 | 66 |
| 224 | 32.932 | 0.146 | 0.069 | 2.21 | 97 | -0.06 | 96 | 6.0 | 0.0 | 91 | 307 | 72 | 66 |
| 225 | 33.081 | 0.149 | 0.067 | 2.23 | 98 | -2.18 | 99 | 6.0 | 0.0 | 91 | 298 | 72 | 66 |
| 226 | 33.227 | 0.146 | 0.067 | 2.21 | 98 | -2.18 | 97 | 5.8 | -0.2 | 91 | 301 | 72 | 66 |
| 227 | 33.376 | 0.149 | 0.068 | 2.23 | 98 | -1.19 | 99 | 5.9 | 0.1 | 91 | 300 | 72 | 66 |
| 228 | 33.522 | 0.146 | 0.065 | 2.21 | 98 | 0 | 99 | 5.8 | -0.1 | 91 | 295 | 72 | 66 |
| 229 | 33.672 | 0.150 | 0.065 | 2.24 | 98 | -0.45 | 102 | 5.8 | 0.0 | 91 | 293 | 72 | 66 |
| 230 | 33.817 | 0.145 | 0.066 | 2.22 | 98 | 0 | 97 | 5.6 | -0.2 | 91 | 300 | 72 | 66 |

BOX A TEST DATA - ASTM E2779 / ASTM E2515

Client: Thelin Hearth ProductsJob #: 20-568Model: Echo Pellet IITracking #: 0062Run #: 1Technician: SJBDate: 2/10/2020

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 231 | 33.967 | 0.150 | 0.062 | 2.22 | 98 | -0.1 | 104 | 5.7 | 0.1 | 91 | 308 | 72 | 66 |
| 232 | 34.112 | 0.145 | 0.068 | 2.22 | 98 | -2.76 | 96 | 5.7 | 0.0 | 91 | 303 | 72 | 66 |
| 233 | 34.261 | 0.149 | 0.064 | 2.24 | 98 | 0 | 102 | 5.6 | -0.1 | 91 | 306 | 72 | 66 |
| 234 | 34.406 | 0.145 | 0.068 | 2.24 | 98 | -0.01 | 96 | 5.5 | -0.1 | 91 | 307 | 72 | 66 |
| 235 | 34.556 | 0.150 | 0.066 | 2.24 | 98 | -0.09 | 101 | 5.5 | 0.0 | 92 | 311 | 72 | 66 |
| 236 | 34.701 | 0.145 | 0.066 | 2.20 | 98 | -2.52 | 98 | 5.4 | -0.1 | 92 | 316 | 72 | 66 |
| 237 | 34.851 | 0.150 | 0.068 | 2.27 | 98 | -2.79 | 99 | 5.4 | 0.0 | 92 | 314 | 72 | 66 |
| 238 | 34.996 | 0.145 | 0.062 | 2.23 | 98 | -0.01 | 101 | 5.4 | 0.0 | 92 | 317 | 72 | 66 |
| 239 | 35.146 | 0.150 | 0.068 | 2.24 | 98 | -0.12 | 99 | 5.3 | -0.1 | 92 | 313 | 72 | 66 |
| 240 | 35.291 | 0.145 | 0.070 | 2.23 | 98 | -0.26 | 95 | 5.3 | 0.0 | 92 | 312 | 72 | 66 |
| 241 | 35.441 | 0.150 | 0.066 | 2.23 | 98 | 0 | 101 | 5.2 | -0.1 | 92 | 315 | 72 | 66 |
| 242 | 35.586 | 0.145 | 0.066 | 2.22 | 98 | -2.4 | 98 | 5.2 | 0.0 | 92 | 311 | 72 | 66 |
| 243 | 35.737 | 0.151 | 0.068 | 2.22 | 98 | -2.57 | 100 | 5.1 | -0.1 | 92 | 313 | 72 | 66 |
| 244 | 35.882 | 0.145 | 0.063 | 2.23 | 98 | -0.77 | 100 | 5.1 | 0.0 | 92 | 312 | 72 | 66 |
| 245 | 36.033 | 0.151 | 0.066 | 2.22 | 98 | -2.7 | 102 | 5.0 | -0.1 | 92 | 308 | 72 | 66 |
| 246 | 36.177 | 0.144 | 0.064 | 2.21 | 98 | -2.49 | 98 | 4.9 | -0.1 | 92 | 307 | 72 | 66 |
| 247 | 36.328 | 0.151 | 0.067 | 2.21 | 98 | -2.79 | 101 | 5.0 | 0.1 | 92 | 306 | 72 | 66 |
| 248 | 36.473 | 0.145 | 0.069 | 2.20 | 98 | 0 | 95 | 4.9 | -0.1 | 91 | 295 | 72 | 66 |
| 249 | 36.623 | 0.150 | 0.066 | 2.22 | 98 | -0.34 | 101 | 4.9 | 0.0 | 91 | 290 | 72 | 66 |
| 250 | 36.768 | 0.145 | 0.064 | 2.20 | 98 | 0 | 99 | 4.8 | -0.1 | 91 | 298 | 72 | 66 |
| 251 | 36.919 | 0.151 | 0.068 | 2.24 | 98 | 0 | 100 | 4.8 | 0.0 | 91 | 300 | 72 | 66 |
| 252 | 37.064 | 0.145 | 0.067 | 2.22 | 98 | -0.21 | 97 | 4.8 | 0.0 | 91 | 297 | 72 | 66 |
| 253 | 37.214 | 0.150 | 0.067 | 2.22 | 98 | -0.91 | 100 | 4.7 | -0.1 | 91 | 302 | 72 | 66 |
| 254 | 37.360 | 0.146 | 0.064 | 2.21 | 98 | -2.46 | 100 | 4.7 | 0.0 | 92 | 308 | 72 | 66 |
| 255 | 37.509 | 0.149 | 0.065 | 2.23 | 98 | -2.6 | 101 | 4.6 | -0.1 | 91 | 302 | 72 | 66 |
| 256 | 37.654 | 0.145 | 0.064 | 2.23 | 98 | 0 | 99 | 4.5 | -0.1 | 91 | 297 | 72 | 66 |
| 257 | 37.803 | 0.149 | 0.068 | 2.25 | 98 | 0 | 99 | 4.5 | 0.0 | 92 | 305 | 72 | 66 |
| 258 | 37.949 | 0.146 | 0.066 | 2.23 | 98 | -1.35 | 98 | 4.5 | 0.0 | 91 | 299 | 72 | 66 |
| 259 | 38.098 | 0.149 | 0.067 | 2.22 | 98 | 0 | 99 | 4.5 | 0.0 | 91 | 297 | 72 | 66 |
| 260 | 38.244 | 0.146 | 0.068 | 2.18 | 98 | -2.13 | 97 | 4.4 | -0.1 | 91 | 302 | 72 | 66 |
| 261 | 38.393 | 0.149 | 0.066 | 2.22 | 98 | -1.25 | 100 | 4.4 | 0.0 | 92 | 305 | 72 | 66 |
| 262 | 38.539 | 0.146 | 0.069 | 2.24 | 98 | 0 | 96 | 4.3 | -0.1 | 91 | 301 | 72 | 66 |
| 263 | 38.688 | 0.149 | 0.068 | 2.21 | 98 | -1.7 | 99 | 4.3 | 0.0 | 91 | 302 | 72 | 66 |

BOX A TEST DATA - ASTM E2779 / ASTM E2515

Client: Thelin Hearth ProductsJob #: 20-568Model: Echo Pellet IITracking #: 0062Run #: 1Technician: SJBDate: 2/10/2020

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 264 | 38.834 | 0.146 | 0.064 | 2.23 | 98 | -2.14 | 100 | 4.2 | -0.1 | 92 | 306 | 72 | 66 |
| 265 | 38.982 | 0.148 | 0.067 | 2.21 | 98 | -0.22 | 99 | 4.2 | 0.0 | 92 | 305 | 72 | 66 |
| 266 | 39.129 | 0.147 | 0.068 | 2.23 | 98 | -2.45 | 97 | 4.2 | 0.0 | 92 | 307 | 72 | 66 |
| 267 | 39.277 | 0.148 | 0.062 | 2.23 | 98 | -2.96 | 103 | 4.1 | -0.1 | 92 | 305 | 72 | 66 |
| 268 | 39.425 | 0.148 | 0.065 | 2.21 | 98 | 0 | 100 | 4.1 | 0.0 | 92 | 307 | 72 | 66 |
| 269 | 39.572 | 0.147 | 0.064 | 2.20 | 98 | -0.25 | 100 | 3.9 | -0.2 | 92 | 308 | 72 | 66 |
| 270 | 39.720 | 0.148 | 0.067 | 2.21 | 98 | -0.13 | 99 | 4.0 | 0.1 | 92 | 307 | 72 | 66 |
| 271 | 39.867 | 0.147 | 0.069 | 2.19 | 98 | -2.68 | 97 | 3.9 | -0.1 | 92 | 308 | 72 | 66 |
| 272 | 40.015 | 0.148 | 0.069 | 2.20 | 98 | -0.1 | 97 | 3.9 | 0.0 | 92 | 309 | 72 | 66 |
| 273 | 40.162 | 0.147 | 0.068 | 2.20 | 98 | 0 | 97 | 3.8 | -0.1 | 92 | 308 | 72 | 67 |
| 274 | 40.311 | 0.149 | 0.065 | 2.20 | 98 | -2.85 | 101 | 3.8 | 0.0 | 92 | 310 | 72 | 67 |
| 275 | 40.457 | 0.146 | 0.063 | 2.21 | 98 | -0.58 | 101 | 3.7 | -0.1 | 92 | 309 | 72 | 66 |
| 276 | 40.606 | 0.149 | 0.065 | 2.20 | 98 | -0.05 | 101 | 3.7 | 0.0 | 92 | 313 | 72 | 67 |
| 277 | 40.752 | 0.146 | 0.065 | 2.19 | 98 | -1.33 | 99 | 3.7 | 0.0 | 92 | 303 | 72 | 67 |
| 278 | 40.901 | 0.149 | 0.064 | 2.22 | 98 | -2.37 | 102 | 3.6 | -0.1 | 92 | 308 | 72 | 67 |
| 279 | 41.047 | 0.146 | 0.065 | 2.20 | 98 | 0 | 99 | 3.5 | -0.1 | 92 | 308 | 72 | 66 |
| 280 | 41.196 | 0.149 | 0.063 | 2.21 | 98 | -0.41 | 103 | 3.4 | -0.1 | 92 | 306 | 72 | 66 |
| 281 | 41.341 | 0.145 | 0.067 | 2.23 | 98 | 0 | 97 | 3.5 | 0.1 | 92 | 306 | 72 | 66 |
| 282 | 41.491 | 0.150 | 0.067 | 2.22 | 98 | 0 | 100 | 3.5 | 0.0 | 92 | 302 | 72 | 66 |
| 283 | 41.636 | 0.145 | 0.064 | 2.24 | 98 | -0.17 | 99 | 3.4 | -0.1 | 92 | 306 | 72 | 66 |
| 284 | 41.785 | 0.149 | 0.062 | 2.22 | 99 | 0 | 103 | 3.5 | 0.1 | 92 | 310 | 72 | 67 |
| 285 | 41.930 | 0.145 | 0.067 | 2.20 | 99 | 0 | 97 | 3.3 | -0.2 | 92 | 306 | 72 | 67 |
| 286 | 42.080 | 0.150 | 0.066 | 2.22 | 99 | -1.17 | 101 | 3.2 | -0.1 | 92 | 307 | 72 | 66 |
| 287 | 42.224 | 0.144 | 0.066 | 2.22 | 99 | -2.64 | 97 | 3.2 | 0.0 | 92 | 308 | 72 | 66 |
| 288 | 42.374 | 0.150 | 0.071 | 2.21 | 99 | 0 | 97 | 3.2 | 0.0 | 92 | 308 | 72 | 67 |
| 289 | 42.519 | 0.145 | 0.066 | 2.19 | 99 | -0.82 | 97 | 3.1 | -0.1 | 92 | 311 | 72 | 67 |
| 290 | 42.669 | 0.150 | 0.065 | 2.22 | 99 | -2.2 | 102 | 3.1 | 0.0 | 92 | 317 | 73 | 66 |
| 291 | 42.814 | 0.145 | 0.065 | 2.25 | 99 | -0.8 | 98 | 3.1 | 0.0 | 93 | 316 | 73 | 67 |
| 292 | 42.964 | 0.150 | 0.069 | 2.20 | 99 | -2.53 | 99 | 3.0 | -0.1 | 93 | 308 | 73 | 67 |
| 293 | 43.108 | 0.144 | 0.067 | 2.23 | 99 | -2.94 | 96 | 3.0 | 0.0 | 92 | 301 | 73 | 66 |
| 294 | 43.258 | 0.150 | 0.068 | 2.20 | 99 | 0 | 99 | 2.9 | -0.1 | 92 | 299 | 73 | 66 |
| 295 | 43.402 | 0.144 | 0.064 | 2.21 | 99 | -1.18 | 98 | 2.9 | 0.0 | 92 | 295 | 73 | 67 |
| 296 | 43.553 | 0.151 | 0.065 | 2.20 | 99 | -1.99 | 102 | 2.9 | 0.0 | 92 | 296 | 73 | 67 |

BOX A TEST DATA - ASTM E2779 / ASTM E2515

Client: Thelin Hearth ProductsJob #: 20-568Model: Echo Pellet IITracking #: 0062Run #: 1Technician: SJBDate: 2/10/2020

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 297 | 43.697 | 0.144 | 0.068 | 2.20 | 99 | -2.78 | 95 | 2.7 | -0.2 | 92 | 299 | 73 | 67 |
| 298 | 43.848 | 0.151 | 0.066 | 2.22 | 99 | 0 | 101 | 2.8 | 0.1 | 92 | 300 | 73 | 67 |
| 299 | 43.992 | 0.144 | 0.064 | 2.19 | 99 | -1.52 | 98 | 2.7 | -0.1 | 92 | 307 | 73 | 67 |
| 300 | 44.142 | 0.150 | 0.069 | 2.19 | 99 | -2.29 | 99 | 2.7 | 0.0 | 92 | 305 | 73 | 67 |
| 301 | 44.287 | 0.145 | 0.063 | 2.21 | 99 | -0.98 | 100 | 2.6 | -0.1 | 92 | 306 | 73 | 67 |
| 302 | 44.437 | 0.150 | 0.067 | 2.20 | 99 | -1.58 | 100 | 2.6 | 0.0 | 92 | 303 | 73 | 67 |
| 303 | 44.582 | 0.145 | 0.064 | 2.20 | 99 | -2.27 | 99 | 2.5 | -0.1 | 92 | 308 | 73 | 67 |
| 304 | 44.732 | 0.150 | 0.065 | 2.20 | 99 | 0 | 102 | 2.5 | 0.0 | 92 | 307 | 73 | 67 |
| 305 | 44.876 | 0.144 | 0.067 | 2.21 | 99 | -0.13 | 96 | 2.4 | -0.1 | 93 | 313 | 73 | 67 |
| 306 | 45.026 | 0.150 | 0.067 | 2.19 | 99 | -3.02 | 100 | 2.3 | -0.1 | 93 | 314 | 73 | 67 |
| 307 | 45.171 | 0.145 | 0.064 | 2.22 | 99 | -0.17 | 99 | 2.4 | 0.1 | 93 | 312 | 73 | 67 |
| 308 | 45.321 | 0.150 | 0.065 | 2.21 | 99 | 0 | 102 | 2.2 | -0.2 | 93 | 313 | 73 | 67 |
| 309 | 45.465 | 0.144 | 0.065 | 2.22 | 99 | -1.05 | 98 | 2.3 | 0.1 | 93 | 312 | 73 | 67 |
| 310 | 45.616 | 0.151 | 0.069 | 2.21 | 99 | -2.17 | 99 | 2.2 | -0.1 | 93 | 312 | 73 | 67 |
| 311 | 45.760 | 0.144 | 0.067 | 2.22 | 99 | -1.87 | 96 | 2.2 | 0.0 | 93 | 311 | 73 | 67 |
| 312 | 45.910 | 0.150 | 0.070 | 2.21 | 99 | -2.66 | 98 | 2.1 | -0.1 | 93 | 311 | 73 | 67 |
| 313 | 46.055 | 0.145 | 0.065 | 2.20 | 99 | -0.37 | 98 | 2.1 | 0.0 | 93 | 312 | 73 | 67 |
| 314 | 46.205 | 0.150 | 0.068 | 2.20 | 99 | -1.34 | 99 | 2.0 | -0.1 | 93 | 308 | 73 | 67 |
| 315 | 46.350 | 0.145 | 0.065 | 2.21 | 99 | -1.27 | 98 | 2.0 | 0.0 | 93 | 307 | 73 | 67 |
| 316 | 46.499 | 0.149 | 0.065 | 2.19 | 99 | 0 | 101 | 2.0 | 0.0 | 93 | 311 | 73 | 67 |
| 317 | 46.644 | 0.145 | 0.065 | 2.20 | 99 | -2.19 | 98 | 1.8 | -0.2 | 93 | 312 | 73 | 67 |
| 318 | 46.793 | 0.149 | 0.069 | 2.21 | 99 | -1.44 | 98 | 1.8 | 0.0 | 93 | 313 | 73 | 67 |
| 319 | 46.938 | 0.145 | 0.064 | 2.21 | 99 | -2.65 | 99 | 1.8 | 0.0 | 93 | 316 | 73 | 67 |
| 320 | 47.087 | 0.149 | 0.066 | 2.20 | 99 | 0 | 100 | 1.8 | 0.0 | 93 | 313 | 73 | 67 |
| 321 | 47.232 | 0.145 | 0.067 | 2.22 | 99 | -2.68 | 97 | 1.6 | -0.2 | 93 | 313 | 73 | 67 |
| 322 | 47.381 | 0.149 | 0.065 | 2.20 | 99 | 0 | 101 | 1.7 | 0.1 | 93 | 314 | 73 | 67 |
| 323 | 47.526 | 0.145 | 0.064 | 2.21 | 99 | 0 | 99 | 1.6 | -0.1 | 93 | 317 | 73 | 67 |
| 324 | 47.675 | 0.149 | 0.068 | 2.25 | 99 | 0 | 99 | 1.6 | 0.0 | 93 | 316 | 73 | 67 |
| 325 | 47.821 | 0.146 | 0.067 | 2.19 | 99 | -1.89 | 97 | 1.4 | -0.2 | 93 | 320 | 73 | 67 |
| 326 | 47.970 | 0.149 | 0.069 | 2.20 | 99 | -2.94 | 98 | 1.5 | 0.1 | 94 | 316 | 73 | 67 |
| 327 | 48.116 | 0.146 | 0.065 | 2.22 | 99 | -2.86 | 99 | 1.4 | -0.1 | 93 | 314 | 73 | 67 |
| 328 | 48.264 | 0.148 | 0.064 | 2.20 | 99 | -0.19 | 101 | 1.4 | 0.0 | 93 | 317 | 73 | 67 |
| 329 | 48.410 | 0.146 | 0.065 | 2.21 | 99 | -1.33 | 99 | 1.3 | -0.1 | 93 | 316 | 73 | 67 |

BOX A TEST DATA - ASTM E2779 / ASTM E2515

Client: Thelin Hearth ProductsJob #: 20-568Model: Echo Pellet IITracking #: 0062Run #: 1Technician: SJBDate: 2/10/2020

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Fuel Weight (lb) | | Temperature Data (°F) | | | |
|--------------------|------------------------------|-------------------|--|----------------------------------|-----------------|----------------------|---------------|------------------|---------------|-----------------------|------|--------|---------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Dilution Tunnel dP (in H ₂ O) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Scale Reading | Weight Change | Dilution Tunnel | Flue | Filter | Ambient |
| 330 | 48.558 | 0.148 | 0.065 | 2.21 | 99 | -2.74 | 100 | 1.3 | 0.0 | 93 | 310 | 73 | 67 |
| 331 | 48.704 | 0.146 | 0.064 | 2.19 | 99 | -2.55 | 100 | 1.2 | -0.1 | 93 | 313 | 73 | 67 |
| 332 | 48.852 | 0.148 | 0.063 | 2.20 | 99 | -0.23 | 102 | 1.1 | -0.1 | 94 | 318 | 73 | 67 |
| 333 | 48.998 | 0.146 | 0.069 | 2.20 | 99 | -1.39 | 96 | 1.2 | 0.1 | 93 | 313 | 73 | 67 |
| 334 | 49.146 | 0.148 | 0.060 | 2.20 | 99 | -1.35 | 104 | 1.1 | -0.1 | 93 | 311 | 73 | 67 |
| 335 | 49.293 | 0.147 | 0.066 | 2.21 | 99 | -1.88 | 99 | 1.1 | 0.0 | 93 | 306 | 73 | 67 |
| 336 | 49.441 | 0.148 | 0.060 | 2.20 | 99 | -1.62 | 104 | 1.0 | -0.1 | 93 | 306 | 73 | 67 |
| 337 | 49.587 | 0.146 | 0.068 | 2.18 | 99 | -1.76 | 97 | 1.0 | 0.0 | 93 | 307 | 73 | 67 |
| 338 | 49.735 | 0.148 | 0.069 | 2.21 | 99 | -2.56 | 97 | 1.0 | 0.0 | 93 | 307 | 73 | 67 |
| 339 | 49.882 | 0.147 | 0.063 | 2.20 | 99 | -0.49 | 101 | 0.9 | -0.1 | 93 | 311 | 73 | 67 |
| 340 | 50.030 | 0.148 | 0.070 | 2.19 | 99 | -2.19 | 97 | 0.9 | 0.0 | 93 | 309 | 73 | 67 |
| 341 | 50.177 | 0.147 | 0.067 | 2.22 | 99 | -2.57 | 98 | 0.8 | -0.1 | 93 | 310 | 73 | 67 |
| 342 | 50.324 | 0.147 | 0.065 | 2.20 | 99 | -0.13 | 100 | 0.8 | 0.0 | 93 | 306 | 73 | 67 |
| 343 | 50.472 | 0.148 | 0.064 | 2.22 | 99 | -1.41 | 101 | 0.8 | 0.0 | 93 | 305 | 73 | 67 |
| 344 | 50.618 | 0.146 | 0.066 | 2.20 | 99 | -0.06 | 98 | 0.7 | -0.1 | 93 | 303 | 73 | 67 |
| 345 | 50.766 | 0.148 | 0.066 | 2.20 | 99 | -2.38 | 99 | 0.6 | -0.1 | 93 | 303 | 73 | 67 |
| 346 | 50.912 | 0.146 | 0.068 | 2.21 | 99 | -0.32 | 97 | 0.6 | 0.0 | 93 | 311 | 73 | 67 |
| 347 | 51.061 | 0.149 | 0.068 | 2.19 | 99 | 0 | 99 | 0.6 | 0.0 | 93 | 314 | 73 | 68 |
| 348 | 51.206 | 0.145 | 0.067 | 2.20 | 99 | 0 | 97 | 0.5 | -0.1 | 93 | 310 | 73 | 67 |
| 349 | 51.355 | 0.149 | 0.065 | 2.20 | 99 | 0 | 101 | 0.5 | 0.0 | 93 | 309 | 73 | 67 |
| 350 | 51.501 | 0.146 | 0.066 | 2.20 | 99 | 0 | 98 | 0.5 | 0.0 | 93 | 305 | 73 | 67 |
| 351 | 51.649 | 0.148 | 0.066 | 2.20 | 99 | -2.87 | 99 | 0.4 | -0.1 | 93 | 302 | 73 | 68 |
| 352 | 51.795 | 0.146 | 0.064 | 2.19 | 99 | -2.62 | 100 | 0.4 | 0.0 | 93 | 299 | 73 | 67 |
| 353 | 51.943 | 0.148 | 0.068 | 2.21 | 99 | -2.35 | 98 | 0.2 | -0.2 | 93 | 298 | 73 | 67 |
| 354 | 52.089 | 0.146 | 0.071 | 2.19 | 99 | -1.27 | 95 | 0.3 | 0.1 | 93 | 297 | 73 | 67 |
| 355 | 52.238 | 0.149 | 0.064 | 2.21 | 99 | -1.61 | 102 | 0.2 | -0.1 | 93 | 304 | 73 | 67 |
| 356 | 52.383 | 0.145 | 0.065 | 2.19 | 99 | -2.44 | 98 | 0.1 | -0.1 | 93 | 307 | 73 | 67 |
| 357 | 52.532 | 0.149 | 0.066 | 2.18 | 99 | -2.19 | 100 | 0.2 | 0.1 | 93 | 306 | 73 | 67 |
| 358 | 52.677 | 0.145 | 0.065 | 2.19 | 99 | -1.99 | 98 | 0.1 | -0.1 | 93 | 303 | 73 | 67 |
| 359 | 52.826 | 0.149 | 0.069 | 2.20 | 99 | 0 | 98 | 0.0 | -0.1 | 93 | 305 | 73 | 67 |
| 360 | 52.971 | 0.145 | 0.063 | 2.20 | 99 | -0.29 | 100 | 0.0 | 0.0 | 93 | 303 | 73 | 67 |
| Avg/Tot | 52.971 | 0.147 | 0.066 | 2.23 | 92 | -1.24 | 100 | | | 95 | 337 | 72 | 66 |

BOX B TEST DATA - ASTM E2779 / ASTM E2515

Client: Thelin Hearth Products
 Model: Echo Pellet II
 Run #: 1

Job #: 20-568
 Tracking #: 0062
 Technician: SJB
 Date: 2/10/2020

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 0 | 0.000 | | 0.00 | 65 | 0 | | 66 | 0.000 | 6.21 | 0.00 |
| 1 | 0.140 | 0.140 | 2.11 | 67 | -3.14 | 103 | 66 | -0.060 | 7.11 | 0.00 |
| 2 | 0.280 | 0.140 | 2.12 | 67 | -0.35 | 102 | 66 | -0.050 | 7.05 | 0.02 |
| 3 | 0.420 | 0.140 | 2.12 | 68 | -0.63 | 102 | 67 | -0.070 | 6.72 | 0.00 |
| 4 | 0.560 | 0.140 | 2.13 | 68 | -0.45 | 101 | 67 | -0.030 | 6.38 | 0.00 |
| 5 | 0.700 | 0.140 | 2.13 | 68 | -1.1 | 100 | 67 | -0.040 | 6.07 | 0.00 |
| 6 | 0.840 | 0.140 | 2.11 | 68 | -1.27 | 101 | 67 | -0.050 | 5.43 | 0.00 |
| 7 | 0.980 | 0.140 | 2.13 | 68 | -0.32 | 102 | 67 | -0.050 | 6.21 | 0.00 |
| 8 | 1.120 | 0.140 | 2.12 | 68 | -1.03 | 102 | 67 | -0.060 | 7.57 | 0.00 |
| 9 | 1.260 | 0.140 | 2.11 | 69 | -3.15 | 102 | 67 | -0.070 | 6.87 | 0.00 |
| 10 | 1.400 | 0.140 | 2.11 | 69 | -0.41 | 104 | 67 | -0.040 | 5.74 | 0.04 |
| 11 | 1.540 | 0.140 | 2.12 | 69 | -0.89 | 102 | 67 | -0.050 | 5.94 | 0.00 |
| 12 | 1.680 | 0.140 | 2.10 | 70 | -0.24 | 103 | 67 | -0.050 | 5.75 | 0.04 |
| 13 | 1.820 | 0.140 | 2.11 | 70 | -0.22 | 101 | 67 | -0.050 | 6.67 | 0.00 |
| 14 | 1.960 | 0.140 | 2.12 | 70 | -0.6 | 102 | 68 | -0.060 | 6.12 | 0.00 |
| 15 | 2.100 | 0.140 | 2.11 | 71 | -3 | 102 | 68 | -0.050 | 7.56 | 0.00 |
| 16 | 2.240 | 0.140 | 2.11 | 71 | -0.26 | 103 | 68 | -0.050 | 6.49 | 0.00 |
| 17 | 2.380 | 0.140 | 2.11 | 71 | -2.16 | 101 | 68 | -0.060 | 7.24 | 0.00 |
| 18 | 2.520 | 0.140 | 2.09 | 72 | -0.98 | 100 | 68 | -0.070 | 7.00 | 0.00 |
| 19 | 2.660 | 0.140 | 2.11 | 72 | -0.28 | 102 | 68 | -0.060 | 7.07 | 0.02 |
| 20 | 2.800 | 0.140 | 2.11 | 72 | -0.43 | 104 | 68 | -0.060 | 6.77 | 0.00 |
| 21 | 2.940 | 0.140 | 2.11 | 73 | -0.73 | 102 | 68 | -0.050 | 6.02 | 0.01 |
| 22 | 3.080 | 0.140 | 2.10 | 73 | -0.83 | 101 | 69 | -0.050 | 7.07 | 0.00 |
| 23 | 3.220 | 0.140 | 2.12 | 73 | -3.2 | 101 | 69 | -0.060 | 7.23 | 0.00 |
| 24 | 3.360 | 0.140 | 2.11 | 74 | -2.15 | 100 | 69 | -0.030 | 7.39 | 0.00 |
| 25 | 3.500 | 0.140 | 2.11 | 74 | -0.32 | 100 | 69 | -0.060 | 5.39 | 0.01 |
| 26 | 3.640 | 0.140 | 2.11 | 74 | -3.2 | 99 | 69 | -0.060 | 7.55 | 0.00 |
| 27 | 3.780 | 0.140 | 2.10 | 75 | -2.71 | 101 | 69 | -0.060 | 5.39 | 0.00 |
| 28 | 3.920 | 0.140 | 2.12 | 75 | -2.81 | 101 | 70 | -0.040 | 6.81 | 0.00 |
| 29 | 4.060 | 0.140 | 2.10 | 76 | -2.98 | 100 | 70 | -0.070 | 8.90 | 0.00 |
| 30 | 4.177 | 0.117 | 2.12 | 76 | -3.19 | 84 | 70 | -0.050 | 6.59 | 0.00 |
| 31 | 4.317 | 0.140 | 2.11 | 76 | -2.75 | 100 | 70 | -0.070 | 6.76 | 0.00 |

BOX B TEST DATA - ASTM E2779 / ASTM E2515

Client: Thelin Hearth Products
 Model: Echo Pellet II
 Run #: 1

Job #: 20-568
 Tracking #: 0062
 Technician: SJB
 Date: 2/10/2020

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 32 | 4.457 | 0.140 | 2.10 | 77 | -0.61 | 102 | 70 | -0.050 | 6.79 | 0.00 |
| 33 | 4.597 | 0.140 | 2.10 | 77 | -3.15 | 102 | 70 | -0.050 | 6.25 | 0.00 |
| 34 | 4.737 | 0.140 | 2.11 | 77 | -0.33 | 102 | 70 | -0.060 | 6.98 | 0.00 |
| 35 | 4.877 | 0.140 | 2.11 | 78 | -0.34 | 101 | 70 | -0.060 | 8.04 | 0.00 |
| 36 | 5.017 | 0.140 | 2.11 | 78 | -1.1 | 103 | 70 | -0.050 | 6.63 | 0.00 |
| 37 | 5.157 | 0.140 | 2.12 | 78 | -3.29 | 100 | 70 | -0.050 | 8.40 | 0.00 |
| 38 | 5.297 | 0.140 | 2.11 | 79 | -2.29 | 101 | 70 | -0.060 | 6.17 | 0.03 |
| 39 | 5.437 | 0.140 | 2.10 | 79 | -3.17 | 101 | 70 | -0.040 | 6.07 | 0.00 |
| 40 | 5.577 | 0.140 | 2.10 | 79 | -2.89 | 101 | 70 | -0.050 | 5.30 | 0.03 |
| 41 | 5.717 | 0.140 | 2.13 | 79 | -1.3 | 103 | 70 | -0.050 | 6.45 | 0.00 |
| 42 | 5.857 | 0.140 | 2.10 | 79 | -2.21 | 100 | 70 | -0.060 | 7.38 | 0.01 |
| 43 | 5.997 | 0.140 | 2.11 | 79 | -0.64 | 100 | 71 | -0.050 | 7.81 | 0.00 |
| 44 | 6.137 | 0.140 | 2.12 | 79 | -0.44 | 101 | 71 | -0.050 | 5.17 | 0.02 |
| 45 | 6.277 | 0.140 | 2.11 | 79 | -2.07 | 101 | 71 | -0.050 | 6.48 | 0.00 |
| 46 | 6.417 | 0.140 | 2.10 | 80 | -3.17 | 102 | 71 | -0.050 | 6.81 | 0.00 |
| 47 | 6.557 | 0.140 | 2.10 | 80 | -2.7 | 100 | 71 | -0.050 | 7.24 | 0.02 |
| 48 | 6.697 | 0.140 | 2.13 | 80 | -0.42 | 100 | 71 | -0.060 | 4.77 | 0.05 |
| 49 | 6.837 | 0.140 | 2.10 | 80 | -3.25 | 101 | 71 | -0.060 | 6.52 | 0.00 |
| 50 | 6.977 | 0.140 | 2.11 | 80 | -0.49 | 102 | 72 | -0.050 | 7.02 | 0.00 |
| 51 | 7.117 | 0.140 | 2.11 | 80 | -0.58 | 100 | 72 | -0.070 | 7.60 | 0.00 |
| 52 | 7.257 | 0.140 | 2.12 | 80 | -0.32 | 101 | 72 | -0.050 | 7.39 | 0.00 |
| 53 | 7.397 | 0.140 | 2.11 | 80 | -3.14 | 100 | 72 | -0.060 | 8.16 | 0.00 |
| 54 | 7.537 | 0.140 | 2.10 | 81 | -3.18 | 102 | 72 | -0.060 | 7.40 | 0.00 |
| 55 | 7.677 | 0.140 | 2.10 | 81 | -0.62 | 101 | 72 | -0.050 | 6.93 | 0.00 |
| 56 | 7.817 | 0.140 | 2.13 | 81 | -0.45 | 104 | 72 | -0.050 | 6.28 | 0.00 |
| 57 | 7.957 | 0.140 | 2.10 | 81 | -1.1 | 101 | 72 | -0.070 | 6.00 | 0.03 |
| 58 | 8.097 | 0.140 | 2.11 | 81 | -1.27 | 99 | 72 | -0.050 | 5.76 | 0.00 |
| 59 | 8.237 | 0.140 | 2.12 | 82 | -0.32 | 100 | 72 | -0.060 | 6.44 | 0.01 |
| 60 | 8.390 | 0.153 | 2.12 | 82 | -1.03 | 109 | 72 | -0.060 | 5.80 | 0.00 |
| 61 | 8.538 | 0.148 | 2.11 | 82 | -1.13 | 107 | 72 | -0.050 | 7.27 | 0.00 |
| 62 | 8.677 | 0.139 | 2.10 | 83 | -3.14 | 102 | 72 | -0.060 | 5.81 | 0.01 |
| 63 | 8.821 | 0.144 | 2.12 | 83 | -2.52 | 102 | 72 | -0.050 | 5.10 | 0.08 |

BOX B TEST DATA - ASTM E2779 / ASTM E2515

Client: Thelin Hearth Products
 Model: Echo Pellet II
 Run #: 1

Job #: 20-568
 Tracking #: 0062
 Technician: SJB
 Date: 2/10/2020

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 64 | 8.961 | 0.140 | 2.12 | 83 | -1.94 | 100 | 72 | -0.050 | 6.72 | 0.07 |
| 65 | 9.102 | 0.141 | 2.10 | 83 | -3.2 | 100 | 72 | -0.050 | 5.90 | 0.02 |
| 66 | 9.243 | 0.141 | 2.11 | 83 | -0.52 | 101 | 72 | -0.060 | 8.92 | 0.00 |
| 67 | 9.383 | 0.140 | 2.11 | 84 | -1.54 | 97 | 72 | -0.040 | 8.95 | 0.00 |
| 68 | 9.528 | 0.145 | 2.13 | 84 | -0.2 | 101 | 72 | -0.050 | 6.28 | 0.01 |
| 69 | 9.666 | 0.138 | 2.11 | 84 | -0.26 | 99 | 72 | -0.050 | 6.46 | 0.01 |
| 70 | 9.809 | 0.143 | 2.11 | 84 | -3.18 | 103 | 72 | -0.050 | 4.57 | 0.13 |
| 71 | 9.949 | 0.140 | 2.11 | 84 | -2.31 | 102 | 72 | -0.050 | 7.01 | 0.00 |
| 72 | 10.092 | 0.143 | 2.12 | 85 | -0.22 | 102 | 72 | -0.050 | 5.19 | 0.02 |
| 73 | 10.233 | 0.141 | 2.11 | 85 | -0.39 | 102 | 72 | -0.050 | 6.11 | 0.04 |
| 74 | 10.374 | 0.141 | 2.10 | 85 | -1.69 | 101 | 72 | -0.060 | 5.99 | 0.03 |
| 75 | 10.515 | 0.141 | 2.10 | 85 | -0.99 | 101 | 72 | -0.060 | 7.01 | 0.06 |
| 76 | 10.656 | 0.141 | 2.13 | 85 | -0.27 | 99 | 72 | -0.040 | 5.63 | 0.03 |
| 77 | 10.800 | 0.144 | 2.11 | 85 | -2.33 | 102 | 72 | -0.050 | 5.91 | 0.04 |
| 78 | 10.939 | 0.139 | 2.12 | 86 | -0.24 | 98 | 72 | -0.060 | 5.46 | 0.04 |
| 79 | 11.083 | 0.144 | 2.11 | 86 | -3.22 | 106 | 72 | -0.050 | 5.11 | 0.00 |
| 80 | 11.221 | 0.138 | 2.10 | 86 | -3.03 | 98 | 72 | -0.060 | 7.19 | 0.00 |
| 81 | 11.365 | 0.144 | 2.11 | 86 | -0.43 | 105 | 72 | -0.050 | 6.42 | 0.00 |
| 82 | 11.506 | 0.141 | 2.12 | 86 | -3.14 | 101 | 72 | -0.050 | 6.09 | 0.00 |
| 83 | 11.648 | 0.142 | 2.11 | 86 | -1.94 | 103 | 72 | -0.040 | 6.53 | 0.01 |
| 84 | 11.790 | 0.142 | 2.11 | 86 | -0.6 | 103 | 72 | -0.070 | 5.87 | 0.00 |
| 85 | 11.930 | 0.140 | 2.12 | 86 | -0.29 | 99 | 72 | -0.050 | 5.55 | 0.05 |
| 86 | 12.073 | 0.143 | 2.12 | 87 | -0.83 | 102 | 72 | -0.050 | 6.13 | 0.04 |
| 87 | 12.214 | 0.141 | 2.13 | 87 | -3.2 | 99 | 72 | -0.050 | 6.21 | 0.06 |
| 88 | 12.358 | 0.144 | 2.13 | 87 | -2.15 | 102 | 72 | -0.050 | 5.18 | 0.08 |
| 89 | 12.497 | 0.139 | 2.11 | 87 | -0.32 | 99 | 72 | -0.050 | 5.63 | 0.00 |
| 90 | 12.640 | 0.143 | 2.13 | 87 | -3.2 | 102 | 72 | -0.050 | 6.46 | 0.02 |
| 91 | 12.780 | 0.140 | 2.12 | 87 | -2.71 | 101 | 72 | -0.050 | 5.83 | 0.00 |
| 92 | 12.925 | 0.145 | 2.11 | 87 | -2.81 | 102 | 72 | -0.050 | 4.62 | 0.06 |
| 93 | 13.065 | 0.140 | 2.11 | 88 | -2.98 | 99 | 72 | -0.050 | 5.97 | 0.00 |
| 94 | 13.206 | 0.141 | 2.12 | 88 | -3.19 | 101 | 72 | -0.050 | 8.22 | 0.04 |
| 95 | 13.348 | 0.142 | 2.10 | 88 | -0.51 | 100 | 72 | -0.050 | 5.19 | 0.07 |

BOX B TEST DATA - ASTM E2779 / ASTM E2515

Client: Thelin Hearth Products
 Model: Echo Pellet II
 Run #: 1

Job #: 20-568
 Tracking #: 0062
 Technician: SJB
 Date: 2/10/2020

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 96 | 13.488 | 0.140 | 2.11 | 88 | -3 | 100 | 72 | -0.050 | 7.08 | 0.00 |
| 97 | 13.634 | 0.146 | 2.12 | 88 | -0.22 | 103 | 72 | -0.050 | 6.47 | 0.00 |
| 98 | 13.773 | 0.139 | 2.11 | 88 | -3.29 | 97 | 72 | -0.060 | 5.80 | 0.02 |
| 99 | 13.917 | 0.144 | 2.11 | 88 | -0.78 | 100 | 72 | -0.050 | 6.72 | 0.00 |
| 100 | 14.056 | 0.139 | 2.11 | 88 | -0.65 | 97 | 72 | -0.070 | 6.60 | 0.00 |
| 101 | 14.200 | 0.144 | 2.09 | 88 | -1.44 | 100 | 72 | -0.060 | 6.30 | 0.02 |
| 102 | 14.341 | 0.141 | 2.11 | 88 | -0.07 | 99 | 72 | -0.040 | 6.08 | 0.00 |
| 103 | 14.484 | 0.143 | 2.11 | 88 | -3.17 | 100 | 72 | -0.050 | 4.98 | 0.04 |
| 104 | 14.625 | 0.141 | 2.11 | 89 | -0.23 | 98 | 72 | -0.040 | 5.38 | 0.03 |
| 105 | 14.765 | 0.140 | 2.10 | 89 | -3.08 | 99 | 72 | -0.040 | 6.64 | 0.02 |
| 106 | 14.909 | 0.144 | 2.12 | 89 | -3 | 100 | 72 | -0.060 | 7.68 | 0.00 |
| 107 | 15.050 | 0.141 | 2.11 | 89 | -3.14 | 101 | 72 | -0.070 | 6.50 | 0.05 |
| 108 | 15.194 | 0.144 | 2.11 | 89 | -2.95 | 99 | 72 | -0.040 | 7.19 | 0.03 |
| 109 | 15.333 | 0.139 | 2.11 | 89 | -3 | 98 | 72 | -0.050 | 8.03 | 0.00 |
| 110 | 15.477 | 0.144 | 2.10 | 89 | -1.33 | 102 | 72 | -0.050 | 6.25 | 0.02 |
| 111 | 15.618 | 0.141 | 2.12 | 89 | -1.84 | 98 | 72 | -0.040 | 5.98 | 0.01 |
| 112 | 15.761 | 0.143 | 2.10 | 89 | -2.79 | 101 | 72 | -0.060 | 5.60 | 0.08 |
| 113 | 15.903 | 0.142 | 2.09 | 89 | -0.57 | 99 | 72 | -0.050 | 6.15 | 0.00 |
| 114 | 16.045 | 0.142 | 2.13 | 89 | -3.19 | 100 | 72 | -0.060 | 6.30 | 0.00 |
| 115 | 16.187 | 0.142 | 2.11 | 89 | -3.14 | 98 | 72 | -0.070 | 7.22 | 0.00 |
| 116 | 16.327 | 0.140 | 2.11 | 89 | -0.35 | 99 | 72 | -0.050 | 6.72 | 0.04 |
| 117 | 16.471 | 0.144 | 2.11 | 90 | -0.63 | 103 | 72 | -0.060 | 5.83 | 0.04 |
| 118 | 16.612 | 0.141 | 2.11 | 90 | -0.45 | 97 | 72 | -0.050 | 7.12 | 0.04 |
| 119 | 16.756 | 0.144 | 2.11 | 90 | -1.1 | 101 | 72 | -0.050 | 5.93 | 0.03 |
| 120 | 16.896 | 0.140 | 2.11 | 90 | -1.27 | 98 | 72 | -0.050 | 5.48 | 0.02 |
| 121 | 17.039 | 0.143 | 2.11 | 90 | -0.32 | 104 | 72 | -0.060 | 7.06 | 0.04 |
| 122 | 17.180 | 0.141 | 2.11 | 90 | -1.03 | 101 | 72 | -0.050 | 6.57 | 0.04 |
| 123 | 17.324 | 0.144 | 2.11 | 90 | -3.15 | 99 | 72 | -0.050 | 5.47 | 0.09 |
| 124 | 17.465 | 0.141 | 2.12 | 90 | -0.41 | 101 | 72 | -0.040 | 5.45 | 0.05 |
| 125 | 17.607 | 0.142 | 2.09 | 90 | -0.89 | 100 | 72 | -0.060 | 7.05 | 0.01 |
| 126 | 17.749 | 0.142 | 2.09 | 90 | -0.24 | 100 | 72 | -0.050 | 6.34 | 0.05 |
| 127 | 17.890 | 0.141 | 2.12 | 90 | -0.22 | 101 | 72 | -0.060 | 6.68 | 0.02 |

BOX B TEST DATA - ASTM E2779 / ASTM E2515

Client: Thelin Hearth Products
 Model: Echo Pellet II
 Run #: 1

Job #: 20-568
 Tracking #: 0062
 Technician: SJB
 Date: 2/10/2020

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 128 | 18.034 | 0.144 | 2.11 | 90 | -0.6 | 103 | 72 | -0.040 | 6.26 | 0.03 |
| 129 | 18.175 | 0.141 | 2.08 | 90 | -3 | 100 | 72 | -0.060 | 5.68 | 0.03 |
| 130 | 18.319 | 0.144 | 2.10 | 90 | -0.26 | 102 | 72 | -0.050 | 5.75 | 0.02 |
| 131 | 18.458 | 0.139 | 2.10 | 90 | -2.16 | 100 | 72 | -0.040 | 5.37 | 0.05 |
| 132 | 18.602 | 0.144 | 2.11 | 90 | -0.98 | 102 | 72 | -0.030 | 5.74 | 0.00 |
| 133 | 18.743 | 0.141 | 2.12 | 90 | -0.28 | 101 | 72 | -0.070 | 8.55 | 0.00 |
| 134 | 18.887 | 0.144 | 2.12 | 90 | -0.43 | 101 | 72 | -0.060 | 7.49 | 0.04 |
| 135 | 19.028 | 0.141 | 2.09 | 91 | -0.73 | 100 | 72 | -0.060 | 6.59 | 0.00 |
| 136 | 19.170 | 0.142 | 2.10 | 91 | -0.83 | 102 | 72 | -0.040 | 6.76 | 0.01 |
| 137 | 19.312 | 0.142 | 2.10 | 91 | -3.23 | 98 | 72 | -0.060 | 6.36 | 0.02 |
| 138 | 19.453 | 0.141 | 2.11 | 91 | -3.24 | 100 | 72 | -0.040 | 5.39 | 0.00 |
| 139 | 19.598 | 0.145 | 2.10 | 91 | -2.31 | 100 | 72 | -0.060 | 5.91 | 0.00 |
| 140 | 19.737 | 0.139 | 2.10 | 91 | -3.11 | 101 | 72 | -0.060 | 6.23 | 0.06 |
| 141 | 19.882 | 0.145 | 2.09 | 91 | -0.85 | 101 | 72 | -0.050 | 5.88 | 0.02 |
| 142 | 20.021 | 0.139 | 2.10 | 91 | -2.64 | 98 | 72 | -0.060 | 5.50 | 0.00 |
| 143 | 20.165 | 0.144 | 2.11 | 91 | -1.64 | 100 | 72 | -0.050 | 6.14 | 0.05 |
| 144 | 20.306 | 0.141 | 2.11 | 91 | -2.77 | 100 | 72 | -0.060 | 6.16 | 0.00 |
| 145 | 20.450 | 0.144 | 2.10 | 91 | -0.42 | 104 | 72 | -0.050 | 6.48 | 0.00 |
| 146 | 20.591 | 0.141 | 2.10 | 91 | -3.08 | 98 | 72 | -0.040 | 5.92 | 0.05 |
| 147 | 20.733 | 0.142 | 2.11 | 91 | -3.19 | 98 | 72 | -0.050 | 4.77 | 0.06 |
| 148 | 20.875 | 0.142 | 2.10 | 91 | -0.21 | 102 | 72 | -0.050 | 4.92 | 0.03 |
| 149 | 21.016 | 0.141 | 2.10 | 91 | -0.23 | 104 | 72 | -0.050 | 6.63 | 0.00 |
| 150 | 21.161 | 0.145 | 2.11 | 91 | -1.04 | 102 | 72 | -0.060 | 5.15 | 0.03 |
| 151 | 21.301 | 0.140 | 2.09 | 91 | -0.34 | 100 | 72 | -0.050 | 5.27 | 0.01 |
| 152 | 21.446 | 0.145 | 2.09 | 91 | -0.28 | 103 | 72 | -0.050 | 4.20 | 0.08 |
| 153 | 21.585 | 0.139 | 2.10 | 91 | -1.75 | 97 | 72 | -0.040 | 6.01 | 0.03 |
| 154 | 21.729 | 0.144 | 2.11 | 92 | -0.27 | 102 | 72 | -0.040 | 7.39 | 0.00 |
| 155 | 21.870 | 0.141 | 2.11 | 92 | -1.24 | 102 | 72 | -0.040 | 4.86 | 0.03 |
| 156 | 22.014 | 0.144 | 2.11 | 92 | -3.14 | 100 | 72 | -0.060 | 6.31 | 0.03 |
| 157 | 22.155 | 0.141 | 2.10 | 92 | -0.88 | 97 | 72 | -0.040 | 5.79 | 0.01 |
| 158 | 22.297 | 0.142 | 2.11 | 92 | -0.7 | 103 | 72 | -0.060 | 7.44 | 0.00 |
| 159 | 22.439 | 0.142 | 2.10 | 92 | -0.79 | 98 | 72 | -0.050 | 6.12 | 0.03 |

BOX B TEST DATA - ASTM E2779 / ASTM E2515

Client: Thelin Hearth Products
 Model: Echo Pellet II
 Run #: 1

Job #: 20-568
 Tracking #: 0062
 Technician: SJB
 Date: 2/10/2020

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 160 | 22.580 | 0.141 | 2.10 | 92 | -1.51 | 101 | 72 | -0.060 | 5.24 | 0.04 |
| 161 | 22.725 | 0.145 | 2.12 | 92 | -0.57 | 101 | 72 | -0.060 | 6.63 | 0.00 |
| 162 | 22.865 | 0.140 | 2.10 | 92 | -0.32 | 99 | 72 | -0.070 | 6.97 | 0.05 |
| 163 | 23.009 | 0.144 | 2.10 | 92 | -1.81 | 100 | 72 | -0.050 | 6.15 | 0.00 |
| 164 | 23.148 | 0.139 | 2.10 | 92 | -3.03 | 97 | 72 | -0.050 | 5.46 | 0.04 |
| 165 | 23.293 | 0.145 | 2.11 | 92 | -3.07 | 102 | 72 | -0.050 | 5.72 | 0.05 |
| 166 | 23.434 | 0.141 | 2.11 | 92 | -0.73 | 98 | 72 | -0.040 | 5.90 | 0.00 |
| 167 | 23.578 | 0.144 | 2.10 | 92 | -2.91 | 101 | 72 | -0.040 | 5.98 | 0.00 |
| 168 | 23.719 | 0.141 | 2.10 | 92 | -1.01 | 99 | 72 | -0.050 | 4.47 | 0.08 |
| 169 | 23.861 | 0.142 | 2.10 | 92 | -0.45 | 100 | 72 | -0.050 | 6.63 | 0.00 |
| 170 | 24.003 | 0.142 | 2.10 | 92 | -0.56 | 102 | 72 | -0.050 | 7.02 | 0.01 |
| 171 | 24.144 | 0.141 | 2.08 | 92 | -0.35 | 97 | 72 | -0.060 | 6.13 | 0.05 |
| 172 | 24.289 | 0.145 | 2.08 | 92 | -1.08 | 99 | 72 | -0.060 | 6.30 | 0.00 |
| 173 | 24.429 | 0.140 | 2.11 | 92 | -0.56 | 100 | 72 | -0.050 | 7.68 | 0.00 |
| 174 | 24.574 | 0.145 | 2.09 | 92 | -3.21 | 99 | 72 | -0.050 | 5.47 | 0.01 |
| 175 | 24.713 | 0.139 | 2.07 | 92 | -0.53 | 98 | 72 | -0.060 | 5.14 | 0.04 |
| 176 | 24.857 | 0.144 | 2.11 | 92 | -0.19 | 100 | 72 | -0.040 | 7.26 | 0.02 |
| 177 | 24.998 | 0.141 | 2.10 | 93 | -3.2 | 98 | 72 | -0.050 | 6.39 | 0.00 |
| 178 | 25.142 | 0.144 | 2.11 | 93 | -1.38 | 101 | 72 | -0.050 | 5.13 | 0.06 |
| 179 | 25.283 | 0.141 | 2.09 | 93 | -2.5 | 99 | 72 | -0.050 | 6.91 | 0.00 |
| 180 | 25.425 | 0.142 | 2.09 | 93 | -0.43 | 99 | 72 | -0.070 | 5.40 | 0.00 |
| 181 | 25.567 | 0.142 | 2.09 | 93 | -0.32 | 98 | 72 | -0.040 | 6.22 | 0.00 |
| 182 | 25.709 | 0.142 | 2.11 | 93 | -3.02 | 101 | 72 | -0.070 | 4.45 | 0.02 |
| 183 | 25.853 | 0.144 | 2.10 | 93 | -1.52 | 101 | 72 | -0.050 | 3.97 | 0.10 |
| 184 | 25.993 | 0.140 | 2.10 | 93 | -0.67 | 98 | 72 | -0.050 | 4.39 | 0.02 |
| 185 | 26.138 | 0.145 | 2.09 | 93 | -1.15 | 100 | 72 | -0.060 | 3.40 | 0.11 |
| 186 | 26.277 | 0.139 | 2.09 | 93 | -0.24 | 96 | 72 | -0.050 | 3.71 | 0.03 |
| 187 | 26.422 | 0.145 | 2.09 | 93 | -0.69 | 104 | 72 | -0.050 | 5.12 | 0.00 |
| 188 | 26.562 | 0.140 | 2.10 | 93 | -2.75 | 100 | 72 | -0.040 | 4.13 | 0.02 |
| 189 | 26.707 | 0.145 | 2.10 | 93 | -0.61 | 101 | 72 | -0.050 | 3.34 | 0.15 |
| 190 | 26.848 | 0.141 | 2.10 | 93 | -3.15 | 101 | 72 | -0.060 | 4.27 | 0.03 |
| 191 | 26.990 | 0.142 | 2.08 | 93 | -0.33 | 98 | 72 | -0.050 | 5.71 | 0.06 |

BOX B TEST DATA - ASTM E2779 / ASTM E2515

Client: Thelin Hearth Products
 Model: Echo Pellet II
 Run #: 1

Job #: 20-568
 Tracking #: 0062
 Technician: SJB
 Date: 2/10/2020

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 192 | 27.132 | 0.142 | 2.09 | 93 | -0.34 | 101 | 72 | -0.060 | 4.51 | 0.07 |
| 193 | 27.274 | 0.142 | 2.10 | 93 | -1.1 | 101 | 72 | -0.030 | 4.68 | 0.07 |
| 194 | 27.418 | 0.144 | 2.11 | 93 | -3.29 | 99 | 72 | -0.040 | 4.92 | 0.04 |
| 195 | 27.559 | 0.141 | 2.09 | 93 | -2.29 | 100 | 72 | -0.060 | 5.62 | 0.01 |
| 196 | 27.703 | 0.144 | 2.10 | 93 | -3.17 | 102 | 72 | -0.050 | 5.21 | 0.03 |
| 197 | 27.843 | 0.140 | 2.09 | 93 | -2.89 | 97 | 72 | -0.050 | 5.54 | 0.07 |
| 198 | 27.986 | 0.143 | 2.11 | 93 | -1.3 | 101 | 72 | -0.050 | 4.47 | 0.01 |
| 199 | 28.127 | 0.141 | 2.09 | 93 | -2.21 | 97 | 72 | -0.040 | 4.57 | 0.06 |
| 200 | 28.272 | 0.145 | 2.09 | 93 | -0.64 | 103 | 72 | -0.040 | 4.41 | 0.09 |
| 201 | 28.413 | 0.141 | 2.09 | 93 | -0.44 | 97 | 72 | -0.050 | 5.22 | 0.01 |
| 202 | 28.556 | 0.143 | 2.09 | 93 | -2.07 | 99 | 72 | -0.040 | 3.34 | 0.10 |
| 203 | 28.697 | 0.141 | 2.10 | 93 | -3.17 | 100 | 72 | -0.040 | 5.24 | 0.03 |
| 204 | 28.838 | 0.141 | 2.09 | 93 | -2.7 | 98 | 72 | -0.040 | 5.68 | 0.03 |
| 205 | 28.983 | 0.145 | 2.09 | 93 | -0.42 | 100 | 72 | -0.050 | 6.64 | 0.00 |
| 206 | 29.124 | 0.141 | 2.11 | 93 | -3.25 | 98 | 72 | -0.040 | 5.26 | 0.02 |
| 207 | 29.268 | 0.144 | 2.08 | 93 | -0.49 | 99 | 72 | -0.050 | 3.55 | 0.05 |
| 208 | 29.408 | 0.140 | 2.10 | 94 | -0.58 | 98 | 72 | -0.070 | 5.67 | 0.02 |
| 209 | 29.552 | 0.144 | 2.09 | 94 | -0.32 | 99 | 72 | -0.050 | 5.91 | 0.00 |
| 210 | 29.693 | 0.141 | 2.09 | 94 | -3.14 | 99 | 72 | -0.050 | 4.29 | 0.07 |
| 211 | 29.837 | 0.144 | 2.10 | 94 | -3.18 | 100 | 72 | -0.060 | 5.87 | 0.02 |
| 212 | 29.979 | 0.142 | 2.09 | 94 | -0.62 | 99 | 72 | -0.050 | 4.90 | 0.03 |
| 213 | 30.121 | 0.142 | 2.09 | 94 | -2.6 | 101 | 72 | -0.050 | 4.74 | 0.04 |
| 214 | 30.263 | 0.142 | 2.11 | 94 | -0.06 | 99 | 72 | -0.050 | 4.52 | 0.06 |
| 215 | 30.404 | 0.141 | 2.09 | 94 | -2 | 98 | 72 | -0.060 | 4.27 | 0.08 |
| 216 | 30.548 | 0.144 | 2.08 | 94 | -2.74 | 100 | 72 | -0.040 | 4.91 | 0.01 |
| 217 | 30.689 | 0.141 | 2.09 | 94 | -2.4 | 99 | 72 | -0.030 | 3.94 | 0.04 |
| 218 | 30.834 | 0.145 | 2.10 | 94 | -3.24 | 100 | 72 | -0.050 | 3.24 | 0.10 |
| 219 | 30.973 | 0.139 | 2.07 | 94 | -2.59 | 96 | 72 | -0.050 | 4.40 | 0.06 |
| 220 | 31.117 | 0.144 | 2.08 | 94 | -3.16 | 101 | 72 | -0.050 | 4.56 | 0.03 |
| 221 | 31.258 | 0.141 | 2.09 | 94 | -0.26 | 101 | 72 | -0.070 | 5.37 | 0.06 |
| 222 | 31.402 | 0.144 | 2.09 | 94 | -3.22 | 101 | 72 | -0.050 | 6.20 | 0.01 |
| 223 | 31.544 | 0.142 | 2.10 | 94 | -0.28 | 99 | 72 | -0.050 | 4.96 | 0.01 |

BOX B TEST DATA - ASTM E2779 / ASTM E2515

Client: Thelin Hearth Products
 Model: Echo Pellet II
 Run #: 1

Job #: 20-568
 Tracking #: 0062
 Technician: SJB
 Date: 2/10/2020

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 224 | 31.686 | 0.142 | 2.09 | 94 | -3.11 | 97 | 72 | -0.030 | 5.21 | 0.00 |
| 225 | 31.828 | 0.142 | 2.10 | 94 | -3.05 | 99 | 72 | -0.060 | 4.10 | 0.04 |
| 226 | 31.969 | 0.141 | 2.09 | 94 | -1.91 | 98 | 72 | -0.040 | 4.28 | 0.03 |
| 227 | 32.113 | 0.144 | 2.10 | 94 | -2.91 | 99 | 72 | -0.040 | 4.87 | 0.00 |
| 228 | 32.254 | 0.141 | 2.09 | 94 | -2.96 | 99 | 72 | -0.030 | 3.77 | 0.04 |
| 229 | 32.399 | 0.145 | 2.07 | 94 | -0.94 | 102 | 72 | -0.050 | 3.31 | 0.13 |
| 230 | 32.539 | 0.140 | 2.09 | 94 | -2.97 | 98 | 72 | -0.050 | 4.57 | 0.04 |
| 231 | 32.683 | 0.144 | 2.10 | 94 | -3.09 | 104 | 72 | -0.060 | 6.63 | 0.03 |
| 232 | 32.823 | 0.140 | 2.08 | 94 | -0.99 | 96 | 72 | -0.050 | 5.02 | 0.04 |
| 233 | 32.967 | 0.144 | 2.08 | 94 | -0.52 | 102 | 72 | -0.050 | 4.49 | 0.05 |
| 234 | 33.109 | 0.142 | 2.06 | 94 | -1.22 | 98 | 72 | -0.060 | 4.59 | 0.07 |
| 235 | 33.252 | 0.143 | 2.10 | 94 | -2.76 | 100 | 72 | -0.040 | 5.85 | 0.01 |
| 236 | 33.394 | 0.142 | 2.09 | 94 | -0.35 | 99 | 72 | -0.050 | 5.96 | 0.01 |
| 237 | 33.535 | 0.141 | 2.08 | 94 | -0.54 | 97 | 72 | -0.050 | 5.47 | 0.00 |
| 238 | 33.679 | 0.144 | 2.09 | 94 | -0.44 | 104 | 72 | -0.040 | 5.22 | 0.03 |
| 239 | 33.819 | 0.140 | 2.09 | 94 | -2.57 | 97 | 72 | -0.040 | 4.70 | 0.08 |
| 240 | 33.964 | 0.145 | 2.10 | 94 | -1.65 | 99 | 72 | -0.040 | 4.25 | 0.07 |
| 241 | 34.104 | 0.140 | 2.09 | 94 | -3.16 | 98 | 72 | -0.050 | 6.44 | 0.00 |
| 242 | 34.249 | 0.145 | 2.09 | 94 | -3.21 | 101 | 72 | -0.040 | 4.71 | 0.05 |
| 243 | 34.388 | 0.139 | 2.08 | 94 | -0.97 | 96 | 72 | -0.040 | 5.14 | 0.03 |
| 244 | 34.533 | 0.145 | 2.08 | 94 | -1.47 | 104 | 72 | -0.060 | 5.98 | 0.00 |
| 245 | 34.674 | 0.141 | 2.10 | 94 | -0.22 | 99 | 72 | -0.050 | 4.28 | 0.05 |
| 246 | 34.818 | 0.144 | 2.08 | 94 | -3.32 | 102 | 72 | -0.040 | 3.79 | 0.05 |
| 247 | 34.959 | 0.141 | 2.08 | 94 | -0.23 | 98 | 72 | -0.060 | 5.66 | 0.04 |
| 248 | 35.101 | 0.142 | 2.07 | 94 | -0.72 | 97 | 72 | -0.050 | 2.89 | 0.08 |
| 249 | 35.244 | 0.143 | 2.08 | 94 | -0.27 | 100 | 72 | -0.050 | 2.79 | 0.07 |
| 250 | 35.384 | 0.140 | 2.07 | 94 | -1.5 | 99 | 72 | -0.050 | 4.27 | 0.05 |
| 251 | 35.530 | 0.146 | 2.11 | 94 | -2.76 | 101 | 72 | -0.040 | 6.34 | 0.00 |
| 252 | 35.670 | 0.140 | 2.09 | 94 | -1.06 | 97 | 72 | -0.050 | 4.02 | 0.07 |
| 253 | 35.814 | 0.144 | 2.08 | 94 | -1.63 | 100 | 72 | -0.060 | 5.69 | 0.02 |
| 254 | 35.954 | 0.140 | 2.07 | 94 | -2.25 | 99 | 72 | -0.050 | 5.50 | 0.05 |
| 255 | 36.098 | 0.144 | 2.08 | 94 | -1.35 | 101 | 72 | -0.060 | 5.66 | 0.00 |

BOX B TEST DATA - ASTM E2779 / ASTM E2515

Client: Thelin Hearth Products
 Model: Echo Pellet II
 Run #: 1

Job #: 20-568
 Tracking #: 0062
 Technician: SJB
 Date: 2/10/2020

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 256 | 36.239 | 0.141 | 2.10 | 94 | -2.23 | 100 | 72 | -0.040 | 3.14 | 0.08 |
| 257 | 36.383 | 0.144 | 2.10 | 94 | -1.47 | 99 | 72 | -0.060 | 5.66 | 0.00 |
| 258 | 36.525 | 0.142 | 2.08 | 94 | -3.26 | 99 | 72 | -0.050 | 4.66 | 0.01 |
| 259 | 36.666 | 0.141 | 2.09 | 94 | -0.22 | 98 | 72 | -0.050 | 3.54 | 0.07 |
| 260 | 36.809 | 0.143 | 2.07 | 95 | -1.5 | 98 | 72 | -0.050 | 4.89 | 0.01 |
| 261 | 36.950 | 0.141 | 2.09 | 95 | -0.24 | 99 | 72 | -0.040 | 5.44 | 0.00 |
| 262 | 37.094 | 0.144 | 2.08 | 95 | -1.19 | 98 | 72 | -0.050 | 4.49 | 0.03 |
| 263 | 37.235 | 0.141 | 2.08 | 95 | -3.01 | 97 | 72 | -0.070 | 4.84 | 0.05 |
| 264 | 37.380 | 0.145 | 2.09 | 95 | -0.59 | 103 | 72 | -0.030 | 5.27 | 0.00 |
| 265 | 37.519 | 0.139 | 2.08 | 95 | -3.15 | 96 | 72 | -0.050 | 5.07 | 0.02 |
| 266 | 37.663 | 0.144 | 2.08 | 95 | -3.17 | 99 | 72 | -0.050 | 4.31 | 0.08 |
| 267 | 37.803 | 0.140 | 2.07 | 95 | -3.06 | 101 | 72 | -0.050 | 5.39 | 0.00 |
| 268 | 37.948 | 0.145 | 2.09 | 95 | -3.14 | 102 | 72 | -0.050 | 4.55 | 0.06 |
| 269 | 38.089 | 0.141 | 2.09 | 95 | -2.94 | 100 | 72 | -0.050 | 5.32 | 0.00 |
| 270 | 38.231 | 0.142 | 2.08 | 95 | -3.09 | 98 | 72 | -0.040 | 5.13 | 0.02 |
| 271 | 38.374 | 0.143 | 2.07 | 95 | -2.32 | 98 | 72 | -0.040 | 4.16 | 0.06 |
| 272 | 38.515 | 0.141 | 2.08 | 95 | -0.82 | 96 | 72 | -0.060 | 5.98 | 0.00 |
| 273 | 38.659 | 0.144 | 2.10 | 95 | -3.25 | 99 | 72 | -0.060 | 4.64 | 0.01 |
| 274 | 38.800 | 0.141 | 2.10 | 95 | -1.24 | 99 | 72 | -0.050 | 4.44 | 0.03 |
| 275 | 38.944 | 0.144 | 2.10 | 95 | -2.97 | 103 | 72 | -0.050 | 5.19 | 0.03 |
| 276 | 39.084 | 0.140 | 2.08 | 95 | -0.31 | 99 | 72 | -0.040 | 5.10 | 0.02 |
| 277 | 39.228 | 0.144 | 2.09 | 95 | -0.43 | 101 | 72 | -0.070 | 3.77 | 0.09 |
| 278 | 39.369 | 0.141 | 2.08 | 95 | -2.03 | 100 | 72 | -0.040 | 4.52 | 0.02 |
| 279 | 39.513 | 0.144 | 2.10 | 95 | -0.43 | 101 | 72 | -0.050 | 5.46 | 0.03 |
| 280 | 39.654 | 0.141 | 2.09 | 95 | -2.85 | 101 | 72 | -0.050 | 4.22 | 0.08 |
| 281 | 39.797 | 0.143 | 2.09 | 95 | -3.13 | 99 | 72 | -0.060 | 5.45 | 0.00 |
| 282 | 39.939 | 0.142 | 2.06 | 95 | -1.33 | 98 | 72 | -0.060 | 3.74 | 0.09 |
| 283 | 40.080 | 0.141 | 2.10 | 95 | -0.12 | 100 | 72 | -0.040 | 4.66 | 0.03 |
| 284 | 40.224 | 0.144 | 2.10 | 95 | -1.58 | 104 | 73 | -0.060 | 6.79 | 0.00 |
| 285 | 40.365 | 0.141 | 2.09 | 95 | -2.98 | 98 | 72 | -0.040 | 4.76 | 0.06 |
| 286 | 40.509 | 0.144 | 2.08 | 95 | -2.4 | 101 | 73 | -0.040 | 5.07 | 0.00 |
| 287 | 40.649 | 0.140 | 2.08 | 95 | -0.94 | 98 | 73 | -0.040 | 4.75 | 0.05 |

BOX B TEST DATA - ASTM E2779 / ASTM E2515

Client: Thelin Hearth Products
 Model: Echo Pellet II
 Run #: 1

Job #: 20-568
 Tracking #: 0062
 Technician: SJB
 Date: 2/10/2020

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 288 | 40.793 | 0.144 | 2.09 | 95 | -0.66 | 97 | 73 | -0.070 | 4.84 | 0.02 |
| 289 | 40.933 | 0.140 | 2.09 | 95 | -1.83 | 98 | 73 | -0.040 | 5.56 | 0.02 |
| 290 | 41.077 | 0.144 | 2.08 | 95 | -3.18 | 101 | 73 | -0.050 | 6.22 | 0.00 |
| 291 | 41.219 | 0.142 | 2.08 | 95 | -0.28 | 100 | 73 | -0.050 | 6.29 | 0.00 |
| 292 | 41.361 | 0.142 | 2.08 | 95 | -0.28 | 97 | 73 | -0.070 | 3.78 | 0.06 |
| 293 | 41.503 | 0.142 | 2.07 | 95 | -1.68 | 98 | 73 | -0.040 | 3.35 | 0.10 |
| 294 | 41.644 | 0.141 | 2.09 | 95 | -0.78 | 97 | 73 | -0.070 | 3.55 | 0.07 |
| 295 | 41.788 | 0.144 | 2.09 | 95 | -2 | 102 | 73 | -0.040 | 4.06 | 0.02 |
| 296 | 41.929 | 0.141 | 2.08 | 95 | -0.95 | 99 | 73 | -0.050 | 3.81 | 0.06 |
| 297 | 42.073 | 0.144 | 2.08 | 95 | -1.14 | 99 | 73 | -0.050 | 4.84 | 0.01 |
| 298 | 42.213 | 0.140 | 2.08 | 95 | -3.17 | 98 | 73 | -0.040 | 4.80 | 0.01 |
| 299 | 42.357 | 0.144 | 2.07 | 95 | -0.47 | 102 | 73 | -0.040 | 5.14 | 0.00 |
| 300 | 42.497 | 0.140 | 2.10 | 95 | -0.56 | 96 | 73 | -0.050 | 5.38 | 0.00 |
| 301 | 42.641 | 0.144 | 2.10 | 95 | -0.49 | 103 | 73 | -0.050 | 5.00 | 0.00 |
| 302 | 42.783 | 0.142 | 2.06 | 95 | -2.6 | 98 | 73 | -0.050 | 3.96 | 0.08 |
| 303 | 42.925 | 0.142 | 2.08 | 95 | -3.11 | 101 | 73 | -0.050 | 5.03 | 0.00 |
| 304 | 43.067 | 0.142 | 2.08 | 95 | -1.86 | 100 | 73 | -0.040 | 5.28 | 0.04 |
| 305 | 43.208 | 0.141 | 2.08 | 95 | -3.09 | 98 | 73 | -0.040 | 4.88 | 0.04 |
| 306 | 43.352 | 0.144 | 2.09 | 95 | -0.31 | 100 | 73 | -0.060 | 6.62 | 0.00 |
| 307 | 43.493 | 0.141 | 2.09 | 95 | -2.9 | 100 | 73 | -0.050 | 4.44 | 0.06 |
| 308 | 43.637 | 0.144 | 2.08 | 95 | -0.71 | 101 | 73 | -0.050 | 5.41 | 0.02 |
| 309 | 43.776 | 0.139 | 2.06 | 95 | -2.19 | 98 | 73 | -0.050 | 5.20 | 0.01 |
| 310 | 43.920 | 0.144 | 2.07 | 95 | -3.24 | 98 | 73 | -0.050 | 5.54 | 0.00 |
| 311 | 44.061 | 0.141 | 2.09 | 95 | -3.02 | 98 | 73 | -0.040 | 4.40 | 0.05 |
| 312 | 44.205 | 0.144 | 2.08 | 95 | -0.22 | 98 | 73 | -0.050 | 4.61 | 0.06 |
| 313 | 44.346 | 0.141 | 2.08 | 95 | -2.79 | 99 | 73 | -0.060 | 5.48 | 0.00 |
| 314 | 44.489 | 0.143 | 2.08 | 95 | -3.2 | 99 | 73 | -0.060 | 4.81 | 0.00 |
| 315 | 44.630 | 0.141 | 2.09 | 95 | -2.95 | 99 | 73 | -0.060 | 3.80 | 0.07 |
| 316 | 44.771 | 0.141 | 2.07 | 95 | -0.67 | 99 | 73 | -0.050 | 5.11 | 0.04 |
| 317 | 44.915 | 0.144 | 2.08 | 95 | -3.23 | 101 | 73 | -0.050 | 5.02 | 0.00 |
| 318 | 45.056 | 0.141 | 2.09 | 95 | -0.27 | 96 | 73 | -0.050 | 4.98 | 0.00 |
| 319 | 45.200 | 0.144 | 2.07 | 95 | -2.26 | 102 | 73 | -0.070 | 5.37 | 0.00 |

BOX B TEST DATA - ASTM E2779 / ASTM E2515

Client: Thelin Hearth Products
 Model: Echo Pellet II
 Run #: 1

Job #: 20-568
 Tracking #: 0062
 Technician: SJB
 Date: 2/10/2020

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 320 | 45.340 | 0.140 | 2.08 | 95 | -2.07 | 98 | 73 | -0.070 | 5.20 | 0.03 |
| 321 | 45.484 | 0.144 | 2.07 | 95 | -0.76 | 100 | 73 | -0.050 | 4.73 | 0.06 |
| 322 | 45.624 | 0.140 | 2.06 | 95 | -3.23 | 99 | 73 | -0.060 | 5.17 | 0.03 |
| 323 | 45.768 | 0.144 | 2.08 | 95 | -2.72 | 102 | 73 | -0.050 | 5.60 | 0.03 |
| 324 | 45.910 | 0.142 | 2.08 | 95 | -3.21 | 98 | 73 | -0.060 | 4.78 | 0.07 |
| 325 | 46.052 | 0.142 | 2.07 | 95 | -0.98 | 99 | 73 | -0.050 | 6.45 | 0.00 |
| 326 | 46.193 | 0.141 | 2.08 | 95 | -0.29 | 97 | 73 | -0.060 | 5.22 | 0.02 |
| 327 | 46.335 | 0.142 | 2.08 | 95 | -0.26 | 100 | 73 | -0.050 | 4.45 | 0.09 |
| 328 | 46.479 | 0.144 | 2.08 | 95 | -3.24 | 102 | 73 | -0.050 | 5.24 | 0.00 |
| 329 | 46.619 | 0.140 | 2.06 | 95 | -0.18 | 99 | 73 | -0.050 | 6.09 | 0.00 |
| 330 | 46.764 | 0.145 | 2.07 | 95 | -1.59 | 102 | 73 | -0.040 | 4.30 | 0.05 |
| 331 | 46.903 | 0.139 | 2.08 | 95 | -1.62 | 99 | 73 | -0.050 | 4.83 | 0.01 |
| 332 | 47.047 | 0.144 | 2.08 | 95 | -0.26 | 103 | 73 | -0.040 | 5.95 | 0.00 |
| 333 | 47.187 | 0.140 | 2.07 | 95 | -2.51 | 96 | 73 | -0.030 | 5.45 | 0.00 |
| 334 | 47.332 | 0.145 | 2.08 | 95 | -2.84 | 106 | 73 | -0.030 | 4.37 | 0.04 |
| 335 | 47.472 | 0.140 | 2.07 | 96 | -0.88 | 98 | 73 | -0.050 | 4.24 | 0.04 |
| 336 | 47.614 | 0.142 | 2.06 | 96 | -3.07 | 104 | 73 | -0.050 | 3.63 | 0.07 |
| 337 | 47.756 | 0.142 | 2.09 | 96 | -2.82 | 98 | 73 | -0.040 | 5.21 | 0.02 |
| 338 | 47.897 | 0.141 | 2.08 | 96 | -0.3 | 96 | 73 | -0.050 | 4.91 | 0.03 |
| 339 | 48.042 | 0.145 | 2.07 | 96 | -1.34 | 104 | 73 | -0.060 | 4.85 | 0.03 |
| 340 | 48.182 | 0.140 | 2.08 | 96 | -0.28 | 95 | 73 | -0.050 | 6.26 | 0.04 |
| 341 | 48.326 | 0.144 | 2.07 | 96 | -0.48 | 100 | 73 | -0.050 | 4.13 | 0.07 |
| 342 | 48.465 | 0.139 | 2.07 | 96 | -3.09 | 98 | 73 | -0.060 | 5.10 | 0.00 |
| 343 | 48.610 | 0.145 | 2.07 | 96 | -0.33 | 103 | 73 | -0.050 | 3.34 | 0.07 |
| 344 | 48.750 | 0.140 | 2.07 | 96 | -0.42 | 98 | 73 | -0.040 | 4.87 | 0.00 |
| 345 | 48.894 | 0.144 | 2.07 | 96 | -3.13 | 101 | 73 | -0.050 | 3.78 | 0.03 |
| 346 | 49.035 | 0.141 | 2.07 | 96 | -0.23 | 97 | 73 | -0.040 | 5.31 | 0.00 |
| 347 | 49.177 | 0.142 | 2.08 | 96 | -2.73 | 98 | 73 | -0.050 | 6.65 | 0.00 |
| 348 | 49.319 | 0.142 | 2.08 | 96 | -2.73 | 98 | 73 | -0.050 | 4.43 | 0.07 |
| 349 | 49.460 | 0.141 | 2.07 | 96 | -3.17 | 99 | 73 | -0.040 | 4.12 | 0.09 |
| 350 | 49.605 | 0.145 | 2.08 | 96 | -3.2 | 101 | 73 | -0.060 | 4.27 | 0.02 |
| 351 | 49.744 | 0.139 | 2.07 | 96 | -0.36 | 97 | 73 | -0.030 | 4.97 | 0.00 |

BOX B TEST DATA - ASTM E2779 / ASTM E2515

Client: Thelin Hearth Products
 Model: Echo Pellet II
 Run #: 1

Job #: 20-568
 Tracking #: 0062
 Technician: SJB
 Date: 2/10/2020

| Elapsed Time (min) | Particulate Sampling Data | | | | | | | Flue Gas Data | | |
|--------------------|------------------------------|-------------------|----------------------------------|-----------------|----------------------|---------------|-------------|----------------------------------|---------------------|--------|
| | Gas Meter (ft ³) | Sample Rate (cfm) | Orifice dH (in H ₂ O) | Meter Temp (°F) | Meter Vacuum (in Hg) | Pro. Rate (%) | Filter (°F) | Flue Draft (in H ₂ O) | CO ₂ (%) | CO (%) |
| 352 | 49.889 | 0.145 | 2.07 | 96 | -0.2 | 103 | 73 | -0.050 | 3.48 | 0.09 |
| 353 | 50.028 | 0.139 | 2.07 | 96 | -1.14 | 96 | 73 | -0.050 | 3.87 | 0.00 |
| 354 | 50.172 | 0.144 | 2.07 | 96 | -0.29 | 97 | 73 | -0.040 | 4.04 | 0.01 |
| 355 | 50.313 | 0.141 | 2.08 | 96 | -2.57 | 100 | 73 | -0.060 | 5.51 | 0.03 |
| 356 | 50.456 | 0.143 | 2.06 | 96 | -0.3 | 101 | 73 | -0.050 | 5.57 | 0.00 |
| 357 | 50.598 | 0.142 | 2.07 | 96 | -0.34 | 99 | 73 | -0.030 | 6.11 | 0.00 |
| 358 | 50.738 | 0.140 | 2.07 | 96 | -0.22 | 98 | 73 | -0.050 | 4.54 | 0.03 |
| 359 | 50.882 | 0.144 | 2.07 | 96 | -2.77 | 98 | 73 | -0.050 | 4.73 | 0.04 |
| 360 | 51.022 | 0.140 | 2.07 | 96 | -3.18 | 100 | 73 | -0.040 | 4.82 | 0.00 |
| Avg/Tot | 51.022 | 0.142 | 2.09 | 89 | -1.64 | 100 | | | 5.60 | 0.03 |

LAB SAMPLE DATA - ASTM E2515

Client: Thelin Hearth Products
 Model: Echo Pellet II
 Run #: 1

Job #: 20-568
 Tracking #: 0062
 Technician: SJB
 Date: 2/10/2020

| | Sample ID | Tare, mg | Total, mg | Final, mg | Catch, mg |
|-------------------------------------|-----------|----------|-----------|-----------|-----------|
| Train A Filters - First Hour | 3725 | 120.6 | 120.6 | 121.1 | 0.5 |
| | | | | | |
| Train A Filters - Remainder | 3726 | 120.6 | 240.1 | 243.4 | 3.3 |
| | 3727 | 119.5 | | | |
| Train A Probe | 8A | 116824.1 | 116824.1 | 116824.3 | 0.2 |
| Train A O-Rings | 8A | 3552.1 | 3552.1 | 3552.5 | 0.4 |
| Train B Filters | 3728 | 118.6 | 241.4 | 244.1 | 2.7 |
| | 3729 | 122.8 | | | |
| | | | | | |
| Train B Probe | 8B | 116826.5 | 116826.5 | 116826.5 | 0.0 |
| Train B O-Rings | 8B | 3585.8 | 3585.8 | 3587.0 | 1.2 |
| Background Filter | | | 0.0 | 0.0 | |

| | |
|---------------------------------|-------------------|
| Placed in Dessicator on: | 2-10-2020 - 15:00 |
|---------------------------------|-------------------|

| | | | | | | |
|-------------------------------------|----------|-----------|----------|-----------|--|--|
| Train A Filters - First Hour | 121.2 | 2/12 9:08 | 121.1 | 2/13 7:59 | | |
| Train A Filters - Remainder | 243.4 | 2/12 9:08 | 243.4 | 2/13 7:59 | | |
| Train A Probe | 116824.1 | 2/12 9:08 | 116824.3 | 2/13 7:59 | | |
| Train A O-Rings | 3552.5 | 2/12 9:08 | 3552.5 | 2/13 7:59 | | |
| Train B Filters | 244.2 | 2/12 9:08 | 244.1 | 2/13 7:59 | | |
| Train B Probe | 116826.3 | 2/12 9:08 | 116826.5 | 2/13 8:00 | | |
| Train B O-Rings | 3586.8 | 2/12 9:08 | 3587.0 | 2/13 8:00 | | |
| Background Filter | | | | | | |

| | |
|-------------------------------|------------|
| 1st hour Sub-Total, mg: | 0.5 |
| Remainder Sub-Total, mg: | 3.9 |
| Train 1 Aggregate, mg: | 4.4 |
| Train 2 Aggregate, mg: | 3.9 |
| Ambient Aggregate, mg: | 0.0 |

ASTM E2779 Pellet Heater Run Sheets

Client: Thelin Hearth Products Job Number: 20-568 Tracking #: 0062
 Model: Echo II Run Number: 1 Test Date: 2/10/2020

Pellet Heater Control Settings

High Burn Rate Settings: "Hi" – Trim set to Max

Medium Burn Rate Settings: "Med" – Trim set to Max

Low Burn Rate Settings: "Lo" – Trim set to Max

Preburn Notes

Preburn Start Time: 7:46

| Time | Notes |
|------|-------|
| N/A | N/A |

Test Notes

Test Burn Start Time: 8:47

| Time | Notes |
|---------|---|
| 0 min | Test start |
| 60 min | Changed 1 st hr filter, changed stove to Medium Test Setting |
| 180 min | Changed stove to Low Test Setting |
| 360 min | End of Test |

Test Burn End Time: 14:47

Flue Gas Concentration Measurement

Calibration Gas Values: Span Gas CO₂ (%): 16.99 CO (%): 4.31
 Mid Gas CO₂ (%): 10.00 CO (%): 2.51

Calibration Results:

| | Pre Test | | | Post Test | | |
|-----------------|----------|-------|-------|-----------|-------|-------|
| | Zero | Mid | Span | Zero | Mid | Span |
| Time | 8:09 | 8:13 | 8:11 | 13:11 | 13:12 | 13:15 |
| CO ₂ | 0.00 | 10.14 | 16.99 | 0.00 | 10.03 | 16.95 |
| CO | 0.00 | 2.516 | 4.311 | -0.054 | 2.419 | 4.206 |

Flue Gas Probe Leak Check: Initial: No Leakage Final: No Leakage

Technician Signature: 

Date: 2/10/2020



Twin Ports Testing, Inc.
 1301 North 3rd Street
 Superior, WI 54880
 p: 715-392-7114
 p: 800-373-2562
 f: 715-392-7163
 www.twinportstesting.com

Report No: USR:W219-0755-01
Issue No: 1

Analytical Test Report

Client: PFS-TECO
Attention: Sebastian Button
PO No: A-Kravitz

Signed:
 Stephen Sundeen
 Chemistry Laboratory Manager
Date of Issue: 9/20/2019
THIS DOCUMENT SHALL NOT BE REPRODUCED EXCEPT IN FULL

| Sample Details | | | |
|------------------------------|---------------|----------------------|-----------|
| Sample Log No: | W219-0755-01 | Sample Date: | 8/30/2019 |
| Sample Designation: | Bear Mountain | Sample Time: | 10:30 AM |
| Sample Recognized As: | Wood Pellets | Arrival Date: | 9/12/2019 |

| Test Results | | | | |
|---|--------------|---------------------|---------------|-------------|
| | METHOD | UNITS | MOISTURE FREE | AS RECEIVED |
| Moisture Total | ASTM E871 | wt. % | | 2.48 |
| Ash | ASTM D1102 | wt. % | 0.24 | 0.24 |
| Volatile Matter | ASTM D3175 | wt. % | 80.80 | 78.79 |
| Fixed Carbon by Difference | ASTM D3172 | wt. % | 18.96 | 18.49 |
| Sulfur | ASTM D4239 | wt. % | 0.034 | 0.034 |
| SO ₂ | Calculated | lb/mmbtu | | 0.079 |
| Net Cal. Value at Const. Pressure | ISO 1928 | GJ/tonne | 19.02 | 18.49 |
| Gross Cal. Value at Const. Vol. | ASTM E711 | Btu/lb | 8752 | 8535 |
| Carbon | ASTM D5373 | wt. % | 49.35 | 48.12 |
| Hydrogen* | ASTM D5373 | wt. % | 6.14 | 5.99 |
| Nitrogen | ASTM D5373 | wt. % | < 0.20 | < 0.20 |
| Oxygen* | ASTM D3176 | wt. % | > 44.03 | > 42.94 |
| *Note: As received values do not include hydrogen and oxygen in the total moisture. | | | | |
| Chlorine | ASTM D6721 | mg/kg | | |
| Fluorine | ASTM D3761 | mg/kg | | |
| Mercury | ASTM D6722 | mg/kg | | |
| Bulk Density | ASTM E873 | lbs/ft ³ | | |
| Fines (Less than 1/8") | TPT CH-P-06 | wt. % | | |
| Durability Index | Kansas State | PDI | | |
| Sample Above 1.50" | TPT CH-P-06 | wt. % | | |
| Maximum Length (Single Pellet) | TPT CH-P-06 | inch | | |
| Diameter, Range | TPT CH-P-05 | inch | | to |
| Diameter, Average | TPT CH-P-05 | inch | | |
| Stated Bag Weight | TPT CH-P-01 | lbs | | |
| Actual Bag Weight | TPT CH-P-01 | lbs | | |

Comments:



Accreditation #60243

Results issued on this report only reflect the analysis of the sample submitted. Our reports and letters are for the exclusive and confidential use of our clients and may not be reproduced, except in their entirety, without the written approval of Twin Ports Testing. Twin Ports Testing Laboratory is accredited to the ISO/IEC 17025:2017 standard by PJLA.

ASTM E2515 - Glass Filters

| Sample | Weight 1 | Weight 2 | Weight 3 | Weight 4 | Initial | Project | Run |
|--------|----------|----------|----------|----------|---------|---------|-----|
| 3721 | 120.9 | 120.7 | - | - | SB | 19-551 | #4 |
| 3722 | 120.8 | 120.7 | - | - | SB | ↓ | ↓ |
| 3723 | 119.9 | 119.9 | - | - | SB | ↓ | ↓ |
| 3724 | 118.7 | 118.8 | - | - | SB | ————— | |
| 3725 | 120.7 | 120.6 | - | - | SB | 20-568 | #1 |
| 3726 | 120.5 | 120.6 | - | - | SB | ↓ | ↓ |
| 3727 | 119.4 | 119.5 | - | - | SB | ↓ | ↓ |
| 3728 | 118.4 | 118.6 | - | - | SB | ↓ | ↓ |
| 3729 | 123.0 | 122.8 | - | - | SB | ↓ | ↓ |
| 3730 | 121.7 | 121.5 | - | - | SB | ————— | |
| 3731 | 119.8 | 119.8 | - | - | SB | | |
| 3732 | 119.5 | 119.5 | - | - | SB | | |
| 3733 | 119.0 | 118.9 | - | - | SB | | |
| 3734 | 118.3 | 118.3 | - | - | SB | | |
| 3735 | 119.4 | 119.2 | - | - | SB | | |
| 3736 | 119.2 | 119.2 | - | - | SB | | |
| 3737 | 117.7 | 117.5 | - | - | SB | | |
| 3738 | 119.8 | 119.6 | - | - | SB | | |

| | |
|---------------------|-------------|
| Weight 1 Date/Time: | 12/5- 9:00 |
| Weight 2 Date/Time: | 12/6- 10:30 |
| Weight 3 Date/Time: | |
| Weight 4 Date/Time: | |

| Sample | Weight 1 | Weight 2 | Weight 3 | Weight 4 | Initial | Project | Run |
|--------|----------|----------|----------|----------|---------|---------|-----|
| 3739 | 119.1 | 119.1 | - | - | A | | |
| 3740 | 119.2 | 119.1 | - | - | A | | |
| 3741 | 118.8 | 118.9 | - | - | A | | |
| 3742 | 118.7 | 118.7 | - | - | A | | |
| 3743 | 118.4 | 118.6 | - | - | A | | |
| 3744 | 119.3 | 119.4 | - | - | A | | |
| 3745 | 119.4 | 119.5 | - | - | A | | |
| 3746 | 119.6 | 119.8 | - | - | A | | |
| 3747 | 119.2 | 119.2 | - | - | A | | |
| 3748 | 118.5 | 118.7 | - | - | A | | |
| 3749 | 119.2 | 119.4 | - | - | A | | |
| 3750 | 119.0 | 119.0 | - | - | A | | |
| 3751 | 118.7 | 118.7 | - | - | A | | |
| 3752 | 119.2 | 119.1 | - | - | A | | |
| 3753 | 118.3 | 118.2 | - | - | A | | |
| 3754 | 118.4 | 118.3 | - | - | A | | |
| 3755 | 119.0 | 119.0 | - | - | A | | |
| 3756 | 119.5 | 119.5 | - | - | A | | |

| | |
|---------------------|-------------|
| Weight 1 Date/Time: | 1/8/19 0845 |
| Weight 2 Date/Time: | |
| Weight 3 Date/Time: | |
| Weight 4 Date/Time: | |

ASTM E2515 - Probes

| Sample | Weight 1 | Weight 2 | Weight 3 | Weight 4 | Initial | Project | Run |
|--------|----------|----------|----------|----------|---------|---------|-----|
| 1A | 115627.8 | 115627.6 | - | - | A | 19-551 | 1 |
| 1B | 115900.9 | 115900.7 | - | - | L | | |
| 2A | 116239.9 | 116239.7 | 116239.8 | - | A | 19-551 | 2 |
| 2B | 116328.6 | 2328.4 | 116328.2 | 116328.3 | L | | |
| 3A | 116074.6 | 116074.2 | 116074.3 | - | A | 19-551 | 3 |
| 3B | 116339.7 | 116338.9 | 116339.0 | - | L | | |
| 4A | 116183.7 | 116182.5 | 116182.7 | - | L | 19-551 | 4 |
| 4B | 116367.0 | 116366.1 | 116366.3 | - | L | | |
| 5A | 116766.9 | 116766.0 | 116766.2 | - | A | 19-529 | #1 |
| 5B | 116874.7 | 116874.0 | 116874.2 | - | L | | |

Weight 1 Date/Time:
1/8/19 0830

Weight 2 Date/Time:
1/9/19 1400

Weight 3 Date/Time:
1/10/19 0900

Weight 4 Date/Time:

| Sample | Weight 1 | Weight 2 | Weight 3 | Weight 4 | Initial | Project | Run |
|--------|----------|----------|----------|----------|---------|---------|-----|
| 6A | 116543.8 | 116543.7 | - | - | SB | 19-529 | #2 |
| 6B | 116118.0 | 116118.1 | - | - | SB | | |
| 7A | 116739.4 | 116739.4 | - | - | SB | 19-529 | #3 |
| 7B | 117286.8 | 117286.7 | - | - | SB | | |
| 8A | 116824.0 | 116824.1 | - | - | SB | 20-588 | #1 |
| 8B | 116826.6 | 116826.5 | - | - | SB | | |
| 9A | - | 116713.7 | | | | | |
| 9B | - | 117919.3 | | | | | |
| 10A | - | 116819.7 | | | | | |
| 10B | - | 117903.4 | | | | | |

Weight 1 Date/Time:
2/3-10:00

Weight 2 Date/Time:
2/4-8:00

Weight 3 Date/Time:

Weight 4 Date/Time:

| Sample | Weight 1 | Weight 2 | Weight 3 | Weight 4 | Initial | Project | Run |
|--------|----------|----------|----------|----------|---------|---------|-----|
| 11A | | | | | | | |
| 11B | | | | | | | |
| 12A | | | | | | | |
| 12B | | | | | | | |
| 13A | | | | | | | |
| 13B | | | | | | | |
| 14A | | | | | | | |
| 14B | | | | | | | |
| 15A | | | | | | | |
| 15B | | | | | | | |

Weight 1 Date/Time:

Weight 2 Date/Time:

Weight 3 Date/Time:

Weight 4 Date/Time:

ASTM E2515 - O-Rings

| Sample | Weight 1 | Weight 2 | Weight 3 | Weight 4 | Initial | Project | Run |
|--------|----------|----------|----------|----------|---------|---------|-----|
| 1A | 3567.1 | 3567.1 | - | - | A | 19-551 | 1 |
| 1B | 3555.5 | 3555.4 | - | - | A | | |
| 2A | 3580.7 | 3553.1 | 3553.0 | - | B | 19-551 | 2 |
| 2B | 3571.8 | 3571.8 | - | - | A | | |
| 3A | 3580.2 | 3580.2 | - | - | A | 19-551 | 3 |
| 3B | 3568.5 | 3568.5 | - | - | A | | |
| 4A | 3623.7 | 3623.8 | - | - | A | 19-551 | 4 |
| 4B | 3580.5 | 3580.7 | - | - | A | | |
| 5A | 3535.4 | 3535.5 | - | - | A | 19-529 | #1 |
| 5B | 3531.4 | 3531.5 | - | - | A | | |

Weight 1 Date/Time:
1/8/20 0830

Weight 2 Date/Time:
1/11/20 1400

Weight 3 Date/Time:

Weight 4 Date/Time:

| Sample | Weight 1 | Weight 2 | Weight 3 | Weight 4 | Initial | Project | Run |
|--------|----------|----------|----------|----------|---------|---------|-----|
| 6A | 3615.9 | 3616.0 | - | - | SB | 19-529 | #2 |
| 6B | 3397.2 | 3397.3 | - | - | SB | | |
| 7A | 3573.2 | 3573.3 | - | - | SB | 19-529 | #3 |
| 7B | 3522.9 | 3522.8 | - | - | SB | | |
| 8A | 3552.1 | 3552.1 | - | - | SB | 20-568 | #1 |
| 8B | 3585.7 | 3585.8 | - | - | SB | | |
| 9A | 3581.7 | 3581.7 | - | - | SB | | |
| 9B | 3524.7 | 3524.6 | - | - | SB | | |
| 10A | 3431.9 | 3431.9 | - | - | SB | | |
| 10B | 3571.1 | 3571.2 | - | - | SB | | |

Weight 1 Date/Time:
2/3-10:00

Weight 2 Date/Time:
2/4-8:00

Weight 3 Date/Time:

Weight 4 Date/Time:

| Sample | Weight 1 | Weight 2 | Weight 3 | Weight 4 | Initial | Project | Run |
|--------|----------|----------|----------|----------|---------|---------|-----|
| 11A | | | | | | | |
| 11B | | | | | | | |
| 12A | | | | | | | |
| 12B | | | | | | | |
| 13A | | | | | | | |
| 13B | | | | | | | |
| 14A | | | | | | | |
| 14B | | | | | | | |
| 15A | | | | | | | |
| 15B | | | | | | | |

Weight 1 Date/Time:

Weight 2 Date/Time:

Weight 3 Date/Time:

Weight 4 Date/Time:

| |
|---|
| Equations and Sample Calculations – ASTM E2779 & E2515 |
|---|

Client Thelin Hearth Products
 Model: Echo Pellet II
 Tracking #: 0062
 Run: 1

Equations used to calculate the parameters listed below are described in this appendix. Sample calculations are provided for each equation. The raw data and printout results from a sample run are also provided for comparison to the sample calculations.

M_{Bdb} – Weight of test fuel burned during test run, dry basis, kg

M_{BSidb} – Weight of test fuel burned during test run segment i , dry basis, kg

BR – Average dry burn rate over full integrated test run, kg/hr

BR_{Si} – Average dry burn rate over test run segment i , kg/hr

V_s – Average gas velocity in the dilution tunnel, ft/sec

Q_{sd} – Average gas flow rate in dilution tunnel, dscf/hr

$V_{m(std)}$ – Volume of Gas Sampled Corrected to Dry Standard Conditions, dscf

m_n – Total Particulate Matter Collected, mg

C_s - Concentration of particulate matter in tunnel gas, dry basis, corrected to STP, g/dscf

E_T – Total Particulate Emissions, g

PR - Proportional Rate Variation

PM_R – Average particulate emissions for full integrated test run, g/hr

PM_F – Average particulate emission factor for full integrated test run, g/dry kg of fuel burned

M_{Bdb} – Weight of test fuel burned during test run, dry basis, kg
ASTM E2779 equation (1)

$$M_{Bdb} = (M_{Swb} - M_{Ewb})(100/(100 + FM))$$

Where,

- FM = average fuel moisture of test fuel, % dry basis
- M_{Swb} = weight of test fuel in hopper at start of test run, wet basis, kg
- M_{Ewb} = weight of test fuel in hopper at end of test run, wet basis, kg

Sample Calculation:

- FM = 2.54 %
- M_{Swb} = 19.2 lbs
- M_{Ewb} = 0.0 lbs
- 0.4536 = Conversion factor from lbs to kg

$$M_{Bdb} = [(19.2 \times 0.4536) - (0.0 \times 0.4536)] (100/(100 + 2.54))$$

$$M_{Bdb} = \mathbf{8.49 \text{ kg}}$$

M_{BSidb} – Weight of test fuel burned during test run segment i , dry basis, kg
ASTM E2779 equation (2)

$$M_{BSidb} = (M_{SSiwb} - M_{ESiwb})(100/(100 + FM))$$

Where,

M_{SSiwb} = weight of test fuel in hopper at start of test run segment i , wet basis, kg

M_{ESiwb} = weight of test fuel in hopper at end of test run segment i , wet basis, kg

Sample Calculation (from medium burn rate segment):

$$FM = 2.54 \%$$

$$M_{SSiwb} = 15.0 \text{ lbs}$$

$$M_{ESiwb} = 7.9 \text{ lbs}$$

0.4536 = Conversion factor from lbs to kg

$$M_{BSidb} = [(15.0 \times 0.4536) - (7.9 \times 0.4536)] (100/(100 + 2.54))$$

$$M_{BSidb} = \mathbf{3.14 \text{ kg}}$$

BR – Average dry burn rate over full integrated test run, kg/hr
ASTM E2779 equation (3)

$$BR = \frac{60 M_{Bdb}}{\theta}$$

Where,

θ = Total length of full integrated test run, min

Sample Calculation:

$$M_{Bdb} = 8.49 \quad \text{kg}$$

$$\theta = 360 \quad \text{min}$$

$$BR = \frac{60 \times 8.49}{360}$$

$$BR = 1.42 \quad \text{kg/hr}$$

BR_{Si} – Average dry burn rate over test run segment *i*, kg/hr
ASTM E2779 equation (4)

$$BR_{Si} = \frac{60 M_{BSidb}}{\theta_{Si}}$$

Where,

$$\theta_{Si} = \text{Total length of test run segment } i, \text{ min}$$

Sample Calculation (from medium burn rate segment):

$$M_{BSidb} = 3.14 \text{ kg}$$

$$\theta = 120 \text{ min}$$

$$BR = \frac{60 \times 3.14}{120}$$

$$BR = 1.57 \text{ kg/hr}$$

V_s – Average gas velocity in the dilution tunnel, ft/sec

ASTM E2515 equations (9)

$$V_s = F_p \times K_p \times C_p \times (\sqrt{\Delta P})_{avg} \times \sqrt{\frac{T_s}{P_s \times M_s}}$$

Where:

- F_p = Adjustment factor for center of tunnel pitot tube placement, $F_p = \frac{V_{strav}}{V_{scent}}$, ASTM E2515 Equation (1)
- V_{scent} = Dilution tunnel velocity calculated after the multi-point pitot traverse at the center, ft/sec
- V_{strav} = Dilution tunnel velocity calculated after the multi-point pitot traverse, ft/sec
- k_p = Pitot tube constant, 85.49
- C_p = Pitot tube coefficient: 0.99, unitless
- ΔP^* = Velocity pressure in the dilution tunnel, in H₂O
- T_s = Absolute average gas temperature in the dilution tunnel, °R; (°R = °F + 460)
- P_s = Absolute average gas static pressure in dilution tunnel, = $P_{bar} + P_g$, in Hg
- P_{bar} = Barometric pressure at test site, in. Hg
- P_g = Static pressure of tunnel, in. H₂O; (in Hg = in H₂O/13.6)
- M_s = **The dilution tunnel wet molecular weight; $M_s = 28.78$ assuming a dry weight of 29 lb/lb-mole

Sample calculation:

$$F_p = \frac{15.39}{16.52} = 0.932$$

$$V_s = 0.932 \times 85.49 \times 0.99 \times 0.258 \times \left(\frac{94.7 + 460}{30.30 + \frac{-0.13}{13.6}} \right)^{1/2} \times 28.78$$

$$V_s = \mathbf{16.20} \text{ ft/s}$$

*The ASTM test standard mistakenly has the square root of the average delta p instead of the average of the square root of delta p. The current EPA Method 2 is also incorrect. This was verified by Mike Toney at EPA.

**The ASTM test standard mistakenly identifies M_s as the dry molecular weight. It should be the wet molecular weight as indicated in EPA Method 2.

Q_{sd} – Average gas flow rate in dilution tunnel, dscf/hr

ASTM E2515 equation (3)

$$Q_{sd} = 3600 \times (1 - B_{ws}) \times v_s \times A \times \frac{T_{std}}{T_s} \times \frac{P_s}{P_{std}}$$

Where:

| | | |
|------------------|---|--|
| 3600 | = | Conversion from seconds to hours (ASTM method uses 60 to convert in minutes) |
| B _{ws} | = | Water vapor in gas stream, proportion by volume; assume 2% |
| A | = | Cross sectional area of dilution tunnel, ft ² |
| T _{std} | = | Standard absolute temperature, 528 °R |
| P _s | = | Absolute average gas static pressure in dilution tunnel, = P _{bar} + P _g , in Hg |
| T _s | = | Absolute average gas temperature in the dilution tunnel, °R; (°R = °F + 460) |
| P _{std} | = | Standard absolute pressure, 29.92 in Hg |

Sample calculation:

$$Q_{sd} = 3600 \times (1 - 0.02) \times 16.20 \times 0.1963 \times \frac{528}{94.7 + 460} \times \frac{30.3 + \frac{-0.13}{13.6}}{29.92}$$

$$Q_{sd} = \mathbf{10814.4} \text{ dscf/hr}$$

$V_{m(std)}$ – Volume of Gas Sampled Corrected to Dry Standard Conditions, dscf
 ASTM E2515 equation (6)

$$V_{m(std)} = K_1 \times V_m \times Y \times \frac{P_{bar} + \left(\frac{\Delta H}{13.6} \right)}{T_m}$$

Where:

| | | |
|------------|---|--|
| K_1 | = | 17.64 °R/in. Hg |
| V_m | = | Volume of gas sample measured at the dry gas meter, dcf |
| Y | = | Dry gas meter calibration factor, dimensionless |
| P_{bar} | = | Barometric pressure at the testing site, in. Hg |
| ΔH | = | Average pressure differential across the orifice meter, in. H ₂ O |
| T_m | = | Absolute average dry gas meter temperature, °R |

Sample Calculation:

Using equation for Train A:

$$V_{m(std)} = 17.64 \times 52.971 \times 1.012 \times \frac{\left(30.3 + \frac{2.23}{13.6} \right)}{\left(92.4 + 460 \right)}$$

$$V_{m(std)} = \mathbf{52.152} \text{ dscf}$$

Using equation for Train B:

$$V_{m(std)} = 17.64 \times 51.022 \times 1.008 \times \frac{\left(30.30 + \frac{2.09}{13.6} \right)}{\left(89.4 + 460 \right)}$$

$$V_{m(std)} = \mathbf{50.286} \text{ dscf}$$

Using equation for ambient train:

$$V_{m(std)} = 17.64 \times 0.00 \times 1 \times \frac{\left(30.3 + \frac{0.00}{13.6} \right)}{\left(65.8 + 460 \right)}$$

$$V_{m(std)} = \mathbf{0.000} \text{ dscf}$$

m_n – Total Particulate Matter Collected, mg
ASTM E2515 Equation (12)

$$m_n = m_p + m_f + m_g$$

Where:

m_p = mass of particulate matter from probe, mg

m_f = mass of particulate matter from filters, mg

m_g = mass of particulate matter from filter seals, mg

Sample Calculation:

Using equation for Train A (first hour):

$$m_n = 0.0 + 0.5 + 0.0$$

$$m_n = 0.5 \text{ mg}$$

Using equation for Train A (remainder):

$$m_n = 0.2 + 3.3 + 0.4$$

$$m_n = 3.9 \text{ mg}$$

Train A Aggregate = **4.4 mg**

Using equation for Train B:

$$m_n = 0.0 + 2.7 + 1.2$$

$$m_n = \mathbf{3.9 \text{ mg}}$$

C_s - Concentration of particulate matter in tunnel gas, dry basis, corrected to standard conditions, g/dscf
 ASTM E2515 equation (13)

$$C_s = K_2 \times \frac{m_n}{V_{m(std)}}$$

Where:

- K_2 = Constant, 0.001 g/mg
 m_n = Total mass of particulate matter collected in the sampling train, mg
 $V_{m(std)}$ = Volume of gas sampled corrected to dry standard conditions, dscf

Sample calculation:

For Train A:

$$C_s = 0.001 \times \frac{4.4}{52.15}$$

$$C_s = \mathbf{0.00008} \text{ g/dscf}$$

For Train B:

$$C_s = 0.001 \times \frac{3.9}{50.29}$$

$$C_s = \mathbf{0.00008} \text{ g/dscf}$$

For Ambient Train

$$C_r = 0.001 \times \frac{0.0}{0.00}$$

$$C_r = \mathbf{0.000000} \text{ g/dscf}$$

E_T – Total Particulate Emissions, g

ASTM E2515 equation (15)

$$E_T = (c_s - c_r) \times Q_{std} \times \theta$$

Where:

| | | |
|-----------|---|---|
| C_s | = | Concentration of particulate matter in tunnel gas, g/dscf |
| C_r | = | Concentration particulate matter room air, g/dscf |
| Q_{std} | = | Average dilution tunnel gas flow rate, dscf/hr |
| θ | = | Total time of test run, minutes |

Sample calculation:

For Train A

$$E_T = (\underline{0.000084} - 0.000000) \times \underline{10814.4} \times \underline{360} / 60$$

$$E_T = \underline{5.47} \text{ g}$$

For Train B

$$E_T = (\underline{0.000078} - 0.000000) \times \underline{10814.4} \times \underline{360} / 60$$

$$E_T = \underline{5.03} \text{ g}$$

Average

$$E = \underline{5.25} \text{ g}$$

Total emission values shall not differ by more than 7.5% from the total average emissions

$$7.5\% \text{ of the average} = \underline{0.39}$$

$$\text{Train A difference} = \underline{0.22}$$

$$\text{Train B difference} = \underline{0.22}$$

PR - Proportional Rate Variation

ASTM E2515 equation (16)

$$PR = \left[\frac{\theta \times V_{mi} \times V_s \times T_m \times T_{si}}{\theta_i \times V_m \times V_{si} \times T_{mi} \times T_s} \right] \times 100$$

Where:

- θ = Total sampling time, min
- θ_i = Length of recording interval, min
- V_{mi} = Volume of gas sample measured by the dry gas meter during the "ith" time interval, dcf
- V_m = Volume of gas sample as measured by dry gas meter, dcf
- V_{si} = Average gas velocity in the dilution tunnel during the "ith" time interval, ft/sec
- V_s = Average gas velocity in the dilution tunnel, ft/sec
- T_{mi} = Absolute average dry gas meter temperature during the "ith" time interval, °R
- T_m = Absolute average dry gas meter temperature, °R
- T_{si} = Absolute average gas temperature in the dilution tunnel during the "ith" time interval, °R
- T_s = Absolute average gas temperature in the dilution tunnel, °R

Sample calculation (for the first 1 minute interval of Train A):

$$PR = \left(\frac{360 \times 0.145 \times 16.20 \times (92.4 + 460) \times (98.0 + 460)}{1 \times 52.971 \times 16.33 \times (94.7 + 460) \times (67.0 + 460)} \right) \times 100$$

$$PR = \underline{103} \%$$

PM_R – Average particulate emissions for full integrated test run, g/hr
ASTM E2779 equation (5)

$$PM_R = 60 (E_T/\theta)$$

Where,

E_T = Total particulate emissions, grams

θ = Total length of full integrated test run, min

Sample Calculation:

$$E_T (\text{Dual train average}) = 5.25 \text{ g}$$

$$\theta = 360 \text{ min}$$

$$PM_R = 60 \times (5.25 / 360)$$

$$PM_R = \mathbf{0.88} \text{ g/hr}$$

PM_F – Average particulate emission factor for full integrated test run, g/dry kg of fuel burned
ASTM E2779 equation (6)

$$PM_F = E_T / M_{Bdb}$$

Where,

E_T = Total particulate emissions, grams

M_{Bdb} = Weight of test fuel burned during test run, dry basis, kg

Sample Calculation:

$$E_T \text{ (Dual train average)} = 5.25 \text{ g}$$

$$M_{Bdb} = 8.49 \text{ kg}$$

$$PM_F = 5.25 / 8.49)$$

$$PM_F = \mathbf{0.62} \text{ g/kg}$$

Thelin Hearth Products - Echo-Comstock EPA 2020 Label
 Label Size - Height - 1.12, Width - 9.50
 P/N: 00.0075.0209 (Location lower right)
 Material: ANSI Class IIIA - .002 Thick Alum. Foil Rated at 150C, w/adhesive backing
 Background - Silver, Foreground Black (Reversed lettering)



W/N 14139

Model/Modèle: Echo

DATE OF MFG. SERIAL NO.

16010

**NE PAS ENLEVER
CETTE ÉTIQUETTE**



Carson City, NV 89706

Pellet Fuel Room Heater. Also For Use in Mobile Homes/Appareil de chauffage à granulés de bois - Peut également s'utiliser dans les maisons mobiles

Install and use only in accordance with manufacturer's installation and operating instructions. Contact local building officials about restrictions and installation inspection in your area. À installer et utiliser uniquement conformément à la notice d'installation et d'utilisation. Contacter les autorités responsables de la construction sur les restrictions et l'inspection de montage dans votre région.

This pellet fired appliance has been tested and listed for use in manufactured homes in accordance with Oregon Administrative Rules 814-23-900 through 814-23-909, ASTM E1509-04, ULC S627-03 and UL 1492-00. Install per H.U.D. 24CFR Sec. 3290.

Cet appareil à granulés de bois a été testé et certifié pour être utilisé dans des maisons préfabriquées conformément aux règlements - Oregon Administrative Rules - 814-23-900 à 814-23-909, ASTM E1509-04, ULC S627-03 et UL 1492-00.

PREVENT HOUSE FIRES

- Install and use only in accordance with the owner's manual provided with this appliance.
- Contact local building or fire officials about restrictions and installation inspections in your area.
- For use with pelletized wood fuel only. Use of other fuels will cause a hazardous condition.
- Do not connect this unit to a chimney flue serving another appliance.
- Keep viewing and ash removal doors tightly closed during operation.
- Input Rating - 3.1 lbs/hr

CAUTION: Special methods are required when passing chimney through a wall or ceiling. Refer to local building codes. Replace glass only with 5mm ceramic. Operate this unit only with the fuel hopper lid closed. Failure to do so may result in emission of products of combustion from the hopper under certain conditions. Maintain hopper seal in good condition. Do not overfill the hopper.

WARNING: (Mobile Home) An outside air inlet must be provided for combustion and be unrestricted while unit is in use. The structural integrity of the mobile home floor, walls, ceiling, and roof must be maintained.

DANGER: Risk of electrical shock. Disconnect power before servicing unit. Do not run power cord under appliance.

INSTALLATION REQUIREMENTS

Refer to local codes and the chimney manufacturer's instructions for precautions required for passing a chimney through a combustible wall or ceiling. Place a non-combustible floor protection which extends 6-inches to the front, and 6-inches to each side, of the fuel opening. See burner's manual for additional clearance information.

VERT TYPE: Use only type "PL" pellet vent and connectors (Size 3" / 75mm or 4" / 100mm).

ELECTRICAL RATING: 120 Volts/2.0 Amps/60Hz/1 Phase - U.K. 240V

ÉVITEZ LES INCENDIES

- À installer et utiliser uniquement conformément au manuel d'utilisation fourni avec cet appareil.
- Contacter les autorités locales en matière de feu ou de construction afin de connaître les restrictions et les inspections de montage propres à votre région.
- À utiliser uniquement avec des bois de chauffage en granulés. Tout autre combustible causera un danger.
- Ne pas relier cet appareil à un conduit de cheminée servant un autre appareil.
- S'assurer que la vitre et la porte de retrait des cendres sont bien fermées lorsque l'appareil est en marche.
- Consommation Thermique - 3.1 lbs/hr

ATTENTION: Des techniques spéciales sont nécessaires en cas de passage de la cheminée à travers un mur ou un plafond. Consulter les codes locaux du bâtiment. Remplacer la vitre avec un verre en céramique de 5mm uniquement. S'assurer que le couvercle de la trémie est bien fermé lorsque l'appareil est en marche. Il y a un risque d'émissions de produits de combustion de la trémie sous certaines conditions. S'assurer que le joint de la trémie est en bon état. Ne pas trop remplir la trémie.

AVERTISSEMENT: (Maison Mobile) Une arrivée d'air extérieur pour la combustion doit être installée et dégagée lorsque l'appareil est en marche. L'intégrité structurelle du plancher, des murs, du plafond et du toit de la maison mobile doit être maintenue.

DANGER: Risque de choc électrique. Débrancher l'appareil avant tout entretien ou réparation. Ne pas acheminer le cordon d'alimentation sous l'appareil.







CONDITIONS D'INSTALLATION:

Consulter les codes locaux et les consignes du fabricant de la cheminée pour les précautions nécessaires en cas de passage d'une cheminée par un mur ou un plafond combustibles. Placer sur un protecteur de plancher qui dépasse de 6 po vers l'avant et de 6 po de chaque côté de l'ouverture du combustible. Consulter le manuel d'utilisation pour d'autres informations concernant les dégagements.

TYPE D'ÉVENT: Utiliser seulement un conduit d'évacuation et des raccords de type -PL- (Taille 3" / 75mm or 4" / 100mm).

CARACTÉRISTIQUES ÉLECTRIQUES: 120 Volts/2.0 Amps/60Hz/1 Phase - G.B. 240V

| | | |
|--|---|---|
| <p>Emission of CO in combustion products: nominal heat output <0.04% Reduced heat output <0.05%</p> <p>Flue Gas Temperature: 169 Deg. C</p> <p>Thermal Output: 6.9 kW</p> <p>Energy Efficiency: nominal heat output 6.9kW 85% Reduced heat output 3.7kW 80%</p> <p>Fuel Types: Wood Pellets, 8mm diameter, 12mm to 25mm long</p> |  <p>06</p> <p>EN 14785:2007</p> <p>Residential Space Heating appliance fired by wood pellets</p> | <p>Émission de CO dans les produits de combustion: Puissance calorifique nominale <0.04% Puissance calorifique réduite <0.05%</p> <p>Température du gaz de cheminée: 169 Deg. C</p> <p>Puissance thermique: 6.9 kW</p> <p>Rendement énergétique: Puissance calorifique nominale 6.9kW 85% Puissance calorifique réduite 3.7kW 80%</p> <p>Types de combustible: Granulés de bois, 8mm de diamètre, 12mm à 25mm de long</p> |
|--|---|---|

| CLEARANCES TO COMBUSTIBLES - FREESTANDING HEATER / DÉGAGEMENT AUX COMBUSTIBLES - APPAREIL DE CHAUFFAGE AUTONOME | | | | | |
|---|--|---|---|---|--|
| <table border="0"> <tr> <td style="width: 50%;"> <p>A. UNIT TO BACKWALL 3" / 75mm</p> <p>B. UNIT TO SIDEWALLS 5" / 125mm</p> <p>C. UNIT TO DIAGONAL WALL 3.5" / 89mm</p> <p>D. FLOOR PROTECTOR 6" / 150mm</p> <p>MINIMUM ALCOVE WIDTH 38" / 965mm</p> <p>MINIMUM ALCOVE HEIGHT 48" / 1220mm</p> </td> <td style="width: 50%; text-align: center;">  </td> </tr> </table> | <p>A. UNIT TO BACKWALL 3" / 75mm</p> <p>B. UNIT TO SIDEWALLS 5" / 125mm</p> <p>C. UNIT TO DIAGONAL WALL 3.5" / 89mm</p> <p>D. FLOOR PROTECTOR 6" / 150mm</p> <p>MINIMUM ALCOVE WIDTH 38" / 965mm</p> <p>MINIMUM ALCOVE HEIGHT 48" / 1220mm</p> |  | <table border="0"> <tr> <td style="width: 50%;"> <p>A. APPAREIL AU MUR ARRIÈRE 3" / 75mm</p> <p>B. APPAREIL AUX MURS LATÉRAUX 5" / 125mm</p> <p>C. APPAREIL AU MUR EN DIAGONALE 3.5" / 89mm</p> <p>D. PROTECTEUR DE PLANCHER 6" / 150mm</p> <p>LARGEUR MINIMUM DE L'ALCÔVE 38" / 965mm</p> <p>HAUTEUR MINIMUM DE L'ALCÔVE 48" / 1220mm</p> </td> <td style="width: 50%; text-align: center;">  </td> </tr> </table> | <p>A. APPAREIL AU MUR ARRIÈRE 3" / 75mm</p> <p>B. APPAREIL AUX MURS LATÉRAUX 5" / 125mm</p> <p>C. APPAREIL AU MUR EN DIAGONALE 3.5" / 89mm</p> <p>D. PROTECTEUR DE PLANCHER 6" / 150mm</p> <p>LARGEUR MINIMUM DE L'ALCÔVE 38" / 965mm</p> <p>HAUTEUR MINIMUM DE L'ALCÔVE 48" / 1220mm</p> |  |
| <p>A. UNIT TO BACKWALL 3" / 75mm</p> <p>B. UNIT TO SIDEWALLS 5" / 125mm</p> <p>C. UNIT TO DIAGONAL WALL 3.5" / 89mm</p> <p>D. FLOOR PROTECTOR 6" / 150mm</p> <p>MINIMUM ALCOVE WIDTH 38" / 965mm</p> <p>MINIMUM ALCOVE HEIGHT 48" / 1220mm</p> |  | | | | |
| <p>A. APPAREIL AU MUR ARRIÈRE 3" / 75mm</p> <p>B. APPAREIL AUX MURS LATÉRAUX 5" / 125mm</p> <p>C. APPAREIL AU MUR EN DIAGONALE 3.5" / 89mm</p> <p>D. PROTECTEUR DE PLANCHER 6" / 150mm</p> <p>LARGEUR MINIMUM DE L'ALCÔVE 38" / 965mm</p> <p>HAUTEUR MINIMUM DE L'ALCÔVE 48" / 1220mm</p> |  | | | | |

CAUTION: HOT WHILE IN OPERATION. DO NOT TOUCH. KEEP CHILDREN, CLOTHING, AND FURNITURE AWAY. CONTACT MAY CAUSE SKIN BURNS. SEE NAMEPLATE AND INSTRUCTIONS.



ATTENTION: L'APPAREIL EST CHAUD LORSQU'IL EST EN MARCHÉ. NE PAS TOUCHER. GARDER LES ENFANTS, LES VÊTEMENTS ET LES MEUBLES LOIN DE L'APPAREIL. TOUT CONTACT PEUT CAUSER DES BRÛLURES. VOIR PLAQUE SIGNALÉTIQUE ET CONSIGNES.


| | | |
|--|---|---|
| <p>U.S. ENVIRONMENTAL PROTECTION AGENCY Certified to comply with EPA NSPS 2020 emission standards.</p> <p>FOR USE WITH PELLETTIZED WOOD FUEL ONLY</p> | <p>DATE OF MANUFACTURE _____ SERIAL NO. _____</p> <p>MODEL: PROVIDENCE INSERT/REPLACE EMISSION RATE (G/hr) 0.88 EFFICIENCY (CSA B415.1) 75%</p> | <p>This appliance needs periodic inspection and repair for proper operation. Consult owner's manual for further information. It is against federal regulations to operate this appliance in a manner inconsistent with operating instructions in the owner's manual.</p> <p style="text-align: right; font-size: xx-small;">P/N: 00.0075.0209</p> |
|--|---|---|

SAMPLE FOR REFERENCE ONLY

ECHO-COMSTOCK PELLETT E.I. II

Pellet Heater Owner's Manual Installation and Operating Instructions

Made in the USA by:



Please read this entire manual before installation and use of the pellet fuel-burning room heater. Failure to follow these instructions could result in property damage, bodily injury or even death.

SAFETY NOTICE

- HEATER MUST BE PROPERLY INSTALLED AND MAINTAINED OR A HOUSE FIRE MAY RESULT.
- FOR YOUR SAFETY, FOLLOW THE INSTALLATION INSTRUCTIONS.
- CONTACT LOCAL BUILDING OFFICIALS ABOUT RESTRICTIONS AND INSTALLATION INSPECTION AND PERMIT REQUIREMENTS.
- FAILURE TO COMPLY WITH OWNER'S MANUAL INSTRUCTIONS WILL VOID WARRANTY AND COULD RESULT IN PROPERTY DAMAGE, BODILY INJURY OR EVEN DEATH.

PLEASE LEAVE THIS MANUAL WITH THE OWNER!!

INDEX OF CONTENTS

- Appendix A, 25
- Appendix B, 26
- Appendix C, 27
- Appendix D, 28
- Battery
 - installation, 16
 - operation, 16
- Battery Light, 16
- Circuit Board Diagram, 22
- Clean Out Tee, 7, 11
- Cleaning
 - exhaust fan blade, 18
 - fan guard, 18
 - fly ash removal, 17
 - glass, 18
 - heat exchanger, 18
 - hopper, 18
 - soot removal, 17
- Clearances, 6
 - mobile home, 6
 - modular home, 6
 - to combustibles, 6, 7
 - to combustibles diagram, 7
- Control Functions, 15
- Dimensions
 - overall diagram, 6
- Distance to Openings, 7
- Electrical Schematic, 23
- Exhaust Fan Blade, 18
- Exhaust Pipe Location Diagram, 6
- Fan Guard, 18
- Fine Tuning, 27
- Firepot Assembly, 26
- Floor Protection, 7
- Fly Ash Removal, 17
- Heat Exchanger, 18
- High Temp/Flue Indicator Light, 16
- Hopper
 - clean out, 18
 - filling, 14
- Igniter Removal, 28
- Installation, 7
 - battery, 16
 - clean out tee, 7
 - distance to openings, 7
 - floor protection, 7
 - pipe configuration, 7
 - pipe connections, 11
 - venting requirements, 11
 - wall & remote thermostat, 12
- Introduction and Safety Information, 5
- Laboratory Listing Label, 4
- Lighting Instructions, 14
- Maintenance Procedures, 17
 - exhaust fan blade, 18
 - fan guard, 18
 - fly ash, 17
 - glass cleaning, 18
 - heat exchanger, 18
 - hopper clean out, 18
 - soot formation, 17
- Outside Air Kit, 5, 6
- Pellets, 14
- Pipe Configuration, 7
- Pipe Connections, 11
- Replacement Parts List, 21
- Routine Maintenance, 24
- Soot Removal, 17
- Start-Up and Operation, 14
 - control functions, 15
 - control knob, 15
 - filling the hopper, 14
 - lighting instructions, 14
- Stove Clean Out, 24
- Trim Button, 16
- Troubleshooting, 18
- Venting Requirements, 11
- Wall & Remote Thermostat Installation, 12
- Warranty Information, 29
- Wind Warning, 27
- Wiring Diagram, 25

FIGURES

| | |
|--|----|
| Figure 1 - Overall Dimensions..... | 8 |
| Figure 2 | 8 |
| Figure 3 | 10 |
| Figure 4 | 11 |
| Figure 5 | 12 |
| Figure 6 | 13 |
| Figure 7 | 14 |
| Figure 8 | 16 |
| Figure 9 | 17 |
| Figure 10 | 17 |
| Figure 11 | 18 |
| Figure 12 | 20 |
| Figure 13 – Replacement Parts List | 24 |
| Figure 14 - Circuit Board Diagram | 25 |
| Figure 15 - Electrical Schematic/Wiring Diagram | 26 |
| Figure 16 – Routine Stove Clean Out and Maintenance..... | 27 |

LABORATORY LISTING LABEL



DO NOT REMOVE THIS LABEL

Model/Modèle: Echo

DATE OF MFG. SERIAL NO.

16011

NE PAS ENLEVER CETTE ÉTIQUETTE



Pellet Fuel Room Heater, Also For Use In Mobile Homes/Appareil de chauffage à granulés de bois - Peut également s'utiliser dans les maisons mobiles

Install and use only in accordance with manufacturer's installation and operating instructions. Contact local building officials about restrictions and installation inspectors in your area. À installer et à utiliser uniquement conformément aux notices d'installation et d'utilisation. Contacter les services responsables de la construction sur les restrictions et l'inspection de montage dans votre région.

This pellet fired appliance has been tested and listed for use in manufactured homes in accordance with Oregon Administrative Rules 914-22-900 through 914-22-909, ASTM E1109-04, ULC 5627-03 and UL 1432-00. Install per A.R.D. 24CFR Sec. 3296.

Cet appareil à granulés de bois a été testé et certifié pour être utilisé dans des maisons préfabriquées conformément aux règlements - Oregon Administrative Rules- 914-22-900 à 914-22-909, ASTM E1109-04, ULC 5627-03 et UL 1432-00.

PREVENT HOUSE FIRES

- Install and use only in accordance with the owner's manual provided with this appliance.
- Contact local building or fire officials about restrictions and installation inspectors in your area.
- For use with pellets only. Use of other fuels will cause a hazardous condition.
- Do not connect this unit to a chimney flue serving another appliance.
- Keep venting and ash removal doors tightly closed during operation.
- Input Rating - 3.1 kw/hr

CAUTION: Special methods are required when passing chimney through a wall or ceiling. Refer to local building codes. Replace glass only with 3mm or more. Operate this unit only with the fuel hopper lid closed. Failure to do so may result in emission of products of combustion from the hopper under certain conditions. Maintain hopper seal in good condition. Do not overfill the hopper.

WARNING: (Mobile Home) An outside air inlet must be provided for combustion and be unobstructed while unit is in use. The structural integrity of the mobile home floor, walls, ceiling, and roof must be maintained.

DANGER: Risk of electrical shock. Disconnect power before servicing unit. Do not run power cord under appliance.

INSTALLATION REQUIREMENTS

Refer to local codes and the chimney manufacturer's instructions for precautions required for passing a chimney through a combustible wall or ceiling. Place a non-combustible floor protection which extends 6 inches to the front, and 6 inches to each side, of the back opening. See owner's manual for additional clearance information.

VENT TYPE: Use only type "PL" pellet vent and connectors (Size 3" / 75mm or 4" / 100mm).

ELECTRICAL RATING: 120 Volt/2.0 Amp/60Hz/1 Phase - U.K. 240V

ÉVITEZ LES INCENDIES

- À installer et à utiliser uniquement conformément au manuel d'utilisation fourni avec cet appareil.
- Contacter les autorités locales ou maires de feu ou de construction afin de connaître les restrictions et les inspecteurs de montage propres à votre région.
- À utiliser uniquement avec des bois de chauffage en granulés. Tout autre combustible causera un danger.
- Ne pas connecter cet appareil à un conduit de cheminée servant un autre appareil.
- S'assurer que la vente et la porte de retrait des cendres sont bien fermées lorsque l'appareil est en marche.
- Consommation Thermique - 3,1 kw/hr

ATTENTION: Des techniques spéciales sont nécessaires en cas de passage de la cheminée à travers un mur ou un plafond. Consulter les codes locaux du bâtiment. Remplacer le verre avec un verre en carreaux de 3mm uniquement. S'assurer que le couvercle de la trémie est bien fermé lorsque l'appareil est en marche. Il y a risque d'émission de produits de combustion de la trémie sous certaines conditions. S'assurer que le joint de la trémie est en bon état. Ne pas trop remplir la trémie.

AVERTISSEMENT: (Maison Mobile) Une arrivée d'air extérieure pour la combustion doit être installée et dégagée lorsque l'appareil est en marche. L'intégrité structurelle pour la plancher, les murs, du plafond et du toit de la maison mobile doit être maintenue.

DANGER: Risque de choc électrique. Débrancher l'appareil avant tout entretien ou réparation. Ne pas acheminer le cordon d'alimentation sous l'appareil.

CONDITIONS D'INSTALLATION

Consulter les codes locaux et les consignes du fabricant de la cheminée pour les précautions nécessaires en cas de passage d'une cheminée par un mur ou un plafond combustible. Placer sur un protecteur de plancher qui dépasse de 6 po vers l'avant et de 6 po de chaque côté de l'ouverture de la combustion. Consulter le manuel d'utilisation pour d'autres informations concernant les dégagements.

TYPE D'ÉVENT: Utiliser seulement un conduit d'évacuation et des raccords de type -PL- (Taille 3" / 75mm or 4" / 100mm).

CARACTÉRISTIQUES ÉLECTRIQUES: 120 Volt/2.0 Amp/60Hz/1 Phase - G.B. 240V

Emission of CO in combustion products: nominal heat output $\leq 0.04\%$
Reduced heat output $\leq 0.01\%$

Flue Gas Temperature: 188 Deg. C

Thermal Output: 6.9 kW

Energy Efficiency: nominal heat output 6.9kW 85%
Reduced heat output 3.7kW 80%

Fuel Types: Wood Pellets, 8mm diameter, 12mm to 25mm long



EN 14785:2007

Residential Space Heating appliance fired by wood pellets

Émission de CO dans les produits de combustion: Puissance calorifique nominale $\leq 0.04\%$
Puissance calorifique réduite $\leq 0.01\%$

Température du gaz de cheminée: 188 Deg. C

Puissance thermique: 6.9 kW

Rendement énergétique: Puissance calorifique nominale 6.9kW 85%
Puissance calorifique réduite 3.7kW 80%

Types de combustible: Granulés de bois, 8mm de diamètre, 12mm à 25mm de long

CLEARANCES TO COMBUSTIBLES - FREESTANDING HEATER / DÉGAGEMENT AUX COMBUSTIBLES - APPAREIL DE CHAUFFAGE AUTONOME

| | | | |
|--------------------------|-------------|-----------------|------------|
| A. UNIT TO BACKWALL | 3" / 75mm | ADJACENT WALL | 3" / 75mm |
| B. UNIT TO SIDEWALLS | 6" / 150mm | FLOOR PROTECTOR | 6" / 150mm |
| C. UNIT TO DIAGONAL WALL | 3.5" / 89mm | | |
| D. FLOOR PROTECTOR | 6" / 150mm | | |





| | | | |
|-----------------------|--------------|------------------------------|--------------|
| MINIMUM ALCOVE WIDTH | 38" / 965mm | LONGUEUR MINIMUM DE L'ALCÔVE | 38" / 965mm |
| MINIMUM ALCOVE HEIGHT | 48" / 1220mm | HAUTEUR MINIMUM DE L'ALCÔVE | 48" / 1220mm |

CAUTION: HOT WHILE IN OPERATION. DO NOT TOUCH. KEEP CHILDREN, CLOTHING, AND FURNITURE AWAY. CONTACT MAY CAUSE SKIN BURNS. SEE NAMEPLATE AND INSTRUCTIONS.



ATTENTION: L'APPAREIL EST CHAUD. NE PAS TOUCHER. GARDER LES ENFANTS, LES VÊTEMENTS ET LES MEUBLES LOIN DE L'APPAREIL. TOUT CONTACT PEUT CAUSER DES BRÛLURES. VOIR PLAQUE SIGNALÉTIQUE ET CONSIGNES.

U.S. ENVIRONMENTAL PROTECTION AGENCY
Certified to comply with EPA NSPS 2000 emission standards.

FOR USE WITH PELLETED WOOD FUEL ONLY

This appliance needs periodic inspection and repair for proper operation. Consult owner's manual for further information. It is against federal regulations to operate this appliance in a manner inconsistent with operating instructions in the owner's manual.

DATE OF MANUFACTURE SERIAL NO.

MODEL: PROVIDENCE INSERT/REPLACE
EMISSION RATE (GHR) 0.83 EFFICIENCY (CSA B415 I) 79%

PN 40 2975 0208

Congratulations on your purchase of Thelin™ Hearth Products Echo II™ pellet stove! In this manual you will find information on stove specifications, installation instructions, operating guide, how to perform scheduled maintenance, a troubleshooting guide, a detailed parts list and associated diagrams. Also included is your warranty information. Please take the time to read this manual and become familiar with your pellet stove.

If you have any questions or comments, please contact your local Thelin authorized dealer. Thelin dealers are qualified industry professionals who are able to address any questions or comments you might have regarding Thelin products. Thank you for choosing Thelin™.

Safety Information

FIRE RISK

Do not operate appliance before reading and understanding operating instructions. Failure to operate appliance properly may result in a house fire.

Inspect appliance and components for damage. Damaged parts may impair safe operation. DO NOT install damaged components.

DO NOT install incomplete components. DO NOT install substitute components. Report damaged parts to dealer.

DO NOT connect this unit into a chimney flue servicing another appliance. DO NOT connect to any air distribution or duct system.

THIS APPLIANCE NEEDS PERIODIC INSPECTION AND REPAIR FOR PROPER OPERATION. CONSULT OWNER'S MANUAL FOR FURTHER INFORMATION. IT IS AGAINST FEDERAL REGULATIONS TO OPERATE THIS APPLIANCE IN A MANNER INCONSISTENT WITH OPERATING INSTRUCTIONS IN THE OWNER'S MANUAL. PROPER OPERATION WILL MINIMIZE VISIBLE EMISSIONS. IF VISIBLE EMISSIONS ARE PRESENT DURING OPERATION HAVE THE APPLIANCE CLEANED AND INSPECTED.

WARNING

THELIN HEARTH PRODUCTS DISCLAIMS ANY RESPONSIBILITY FOR, AND THE WARRANTY WILL BE VOIDED BY THE FOLLOWING ACTIONS:

- MODIFICATION OF APPLIANCE
 - INSTALLATION OTHER THAN AS INSTRUCTED IN THIS MANUAL BY THELIN HEARTH PRODUCTS.
 - INSTALLATION AND/OR USE OF ANY COMPONENT PART NOT APPROVED BY THELIN HEARTH PRODUCTS.
 - OPERATING APPLIANCE WITHOUT FULLY ASSEMBLING ALL COMPONENTS CORRECTLY
-

DO NOT overfire. If any external part starts to glow, you are over firing. Reduce feed rate. Overfiring or any such action that may cause a fire hazard including failure to perform regular maintenance as outlined in these instructions will void warranty.
DO NOT store or use gasoline or other flammable vapors and liquids in the vicinity of this or any other appliance.

CAUTION

TESTED AND APPROVED FOR PFI APPROVED PREMIUM WOOD PELLETS OF HIGHEST BTU OUTPUT AND LOWEST % OF ASH CONTENT ONLY. BURNING ANY OTHER TYPE OF FUEL WILL VOID YOUR WARRANTY.

Fire Safety

Maintain the designated clearances to combustibles as diagramed in this manual. Insulation must not touch the chimney or venting system. You must maintain the designated airspace clearance around the chimney. This space around the chimney is necessary to allow heat to flow away from the chimney area. Insulation in this area will cause heat buildup, which could ignite wood framing. The following should be considered when installing any solid fuel appliance:

1. Install at least one smoke detector and CO detector on each floor of your home to ensure safety. They should be located away from the heating appliance and near the sleeping area.
2. Conveniently locate a Class A fire extinguisher near the appliance.
3. Write down and practice an evacuation plan with two escape routes.

Check with your local building code department before you begin your installation. Obtain a building permit in order to meet local building code requirements.

Contact your local dealer if assistance is required before, during and after installation.

Before Start-Up Check List

1. All Safety Warnings have been read and followed.
2. The Owner's Manual has been read.

3. Floor protection requirements have been adhered to.
4. All venting has been properly installed.
5. The proper clearances from the stove and chimney to combustible materials have been followed.
6. The masonry chimney has been inspected by a professional and is clean, or the factory built (metal) fireplace is installed according to the manufacturer's instructions.
7. A grounded power outlet with a surge protector is available nearby without having to use an extension cord.

General Information

Installation and repair should be done by a qualified service professional. The stove should be inspected before use and at least annually by a service professional. More frequent cleaning may be required due to fuel quality, excessive lint from carpeting, bedding material, etc. It is imperative that control compartments, burn pot and pot holder, and circulating air passageways of the stove be kept clean and free of ash buildup, lint, and dust.

The Echo Pellet Heater has been designed and approved for burning **PREMIUM WOOD PELLETS OF HIGHEST BTU OUTPUT AND LOWEST % OF ASH CONTENT ONLY.**

Burning biomass fuels in other forms or poor quality pellet fuel is not permitted and will void your warranty and/or could cause a burn back or house fire. **FOR BEST RESULTS THE WOOD PELLET FUEL SHOULD BE ¼" DIAMETER AND APPROXIMATELY 1" LONG.**

Store fuel in a covered, dry area. Pellet bags can absorb moisture and must be kept dry. Never place bags of fuel next to the heater. Keep fuel away from combustible materials and moisture. **NEVER** use gasoline, gasoline type lantern fuels, kerosene, charcoal lighter fluid, or similar liquids to start or "freshen up" a fire. Keep all such liquids well away from the stove while it is in use.

Pellet ashes should be placed in a metal container with a tight-fitting lid. The closed container of ashes should be placed on a non-combustible floor or the ground, well away from all combustible materials, pending final disposal. If the ashes are disposed of by burial in soil or otherwise locally disbursed, they should be retained in the closed container until all cinders have been thoroughly extinguished.

DO NOT BURN

- (1) Garbage;
- (2) Lawn clippings or yard waste;
- (3) Materials containing rubber, including tires;
- (4) Materials containing plastic;
- (5) Waste petroleum products, paints or paint thinners, or asphalt products;
- (6) Materials containing asbestos;
- (7) Construction or demolition debris;
- (8) Railroad ties or pressure-treated wood;
- (9) Manure or animal remains;
- (10) Salt water driftwood or other previously salt water saturated materials;
- (11) Unseasoned wood; or
- (12) Paper products, cardboard, plywood, or particleboard. The prohibition against burning these materials does not prohibit the use of fire starters made from paper, cardboard, saw dust, wax and similar substances for the purpose of starting a fire in an affected wood heater.

Burning these materials may result in release of toxic fumes or render the heater ineffective and cause smoke.”

NOTE: During the first few burns (up to 2–4 hours) the high-temperature paint and sealant used in the manufacture will emit some odor and smoke. Open doors and windows to the outside for proper ventilation during the first burn cycle and the curing of the paint.

SEE INITIAL FIRING PROCESS beginning on page 15.

Under specific test conditions this heater has been shown to deliver heat at rates ranging from *16,800* to *26,800* Btu/hr.

This stove must be electrically grounded according to local codes or, in the absence of local codes, with the **National Electrical Code, ANSI/NFPA 70-2020.**

Provide adequate clearances around air openings into the combustion chamber and provide adequate accessibility clearance for servicing and proper operation. Never obstruct the front opening of the heater.

THE ECHO REQUIRES OUTSIDE COMBUSTION AIR ON ALL INSTALLATIONS. NO EXCEPTIONS! (See Figure 2.)

CAUTION: Do not connect this unit to a chimney flue serving another appliance. Do not install flue damper in the exhaust venting system of the unit.

THIS APPLIANCE NEEDS PERIODIC INSPECTION AND REPAIR FOR PROPER OPERATION. CONSULT OWNER’S MANUAL FOR FURTHER INFORMATION. IT IS AGAINST FEDERAL REGULATIONS TO OPERATE THIS APPLIANCE IN A MANNER INCONSISTENT WITH OPERATING INSTRUCTIONS IN THE OWNER’S MANUAL

This wood heater has a manufacturer-set minimum low burn rate that must not be altered. It is against federal regulations to alter this setting or otherwise operate this wood heater in a manner inconsistent with operating instructions in this manual.

U.S. ENVIRONMENTAL PROTECTION AGENCY Certified to comply with 2020 particulate emission standards using **PFI APPROVED** wood pellet fuel.

It is recommended that smoke and carbon monoxide detectors be installed in the area where the heater is to be installed.

FURNITURE AWAY. CONTACT MAY CAUSE SKIN BURNS.




FIGURE 1 - OVERALL DIMENSIONS




FIGURE 2

CAUTION: HOT WHILE IN OPERATION. KEEP CHILDREN, CLOTHING, AND

CLEARANCES

CHECK WITH LOCAL BUILDING OFFICIALS FOR SPECIFIC CODE REQUIREMENTS. A LISTED, TYPE "L" PELLET VENT PIPE IS MANDATORY ON ALL INSTALLATIONS.

Clearance to Combustibles

Unit to Sidewall 5" (125 mm)
Unit to Backwall 3" (75 mm)
Unit to Diagonal Wall..... 3.5" (87.5 mm)

MOBILE OR MODULAR HOME

Mobile home installation should be in accordance with the Manufactured Home and Safety Standard (HUD), CFR 3280, Part 24.

WARNING: Outside combustion air is mandatory in mobile or modular installations. An outside air inlet **MUST** be provided for combustion and ventilation air. The air inlet must remain unrestricted while unit is in use. Outside air connection is made at the air intake located on the rear of the stove (see Figure 2). The Outside Air Kit is mandatory for mobile and modular home installations. The kit contains 3" flex tubing (part #60.0070.0003). Outside air kit includes flex tube, hose clamp, and rodent screen/cap. **Do not hook up unit without this kit.** Secure stove to the floor utilizing the holes provided on the bottom of the legs. Unit must be electrically grounded to steel frame of mobile home.

WARNING: THE STRUCTURAL INTEGRITY OF THE MOBILE HOME FLOOR, WALLS, AND CEILING/ROOF MUST BE MAINTAINED. DO NOT INSTALL IN SLEEPING ROOM.

Use only listed Type "L" pellet vent components for installation. Failure to use listed pellet vent pipe will void your warranty. See pipe manufacturer instructions for installation instructions.

INSTALLATION

- When deciding on the location of your heater and vent pipe, try to minimize the alteration and reframing of structural components of the building. Vent pipe must be installed so that access is provided for inspection and cleaning.
- Avoid installing heater in high-traffic areas. Keep children well away from heater when in operation.
- A 3-inch clearance to combustibles must be maintained for horizontal and vertical venting.** When passing through ceilings or walls, you must use a listed wall thimble, making sure all combustible materials and insulation products are a minimum of 3 inches away from the pellet vent pipe. If using the Pellet Pro, a 1" clearance is required.
- A non-combustible hearth pad must be used if installed on a carpet, wood floor, or other combustible material (see Figure 3). Maintain 6" (152mm) beyond the front and beyond each side of the fuel loading and ash removal opening.
- Keep front door of appliance thirty-six (36) inches from combustibles (drapery, furniture).
- When installing the exhaust vent into an existing chimney, a clean out tee must be installed behind the heater before going up into the chimney. This is necessary in order to remove the fly ash accumulation.
- Install vent at clearances specified by the vent manufacturer.
- Exit termination (distance to openings):
 - 3 feet minimum above any forced air inlet located within 10 feet.
 - 4 feet minimum below and horizontally or 1 foot minimum above any door, window, or gravity air inlet into any building.
 - 2 feet minimum to an adjacent building and 7 feet minimum above grade when located adjacent to public walkways.




FIGURE 3




FIGURE 4




FIGURE 5




FIGURE 6

9. The pellet heater must be operated with a power source and will not operate using natural draft. If there is a power failure the heater will shut down. If the 12-volt back-up system is installed, the heater will automatically switch to the 12-volt power.

Route the power supply cord so it does not touch any of the exterior components of the heater.

- a. When exiting through the wall with your Type "L" pellet vent pipe, you may go straight out through a wall thimble. You must connect a pellet vent tee at this point and extend the vent pipe at least 5 feet vertically outside to provide good draft and allow the gases to exit. The tee must have a clean out cap for inspection and regular cleaning (see Figure 4). Whenever the pipe run in any installation is 10 feet or more, the use of 4-inch Type "L" vent pipe is required.

Horizontal runs must be limited to 2 feet. A wall band is required for every 4 feet minimum on a vertical run at an exterior wall.

- b. All pellet vent pipe connections including exit at the rear of the heater should be secured with three screws and sealed with high temperature silicone (450 degrees) or metallic duct tape. This prevents smoke and soot leakage into the living area. If this is not done, there is a possibility that the room fan will pick up any leakage and blow it into the room. This requirement is waived if the new Dura Vent Pellet Pro pipe is used.
- c. Installation per Figure 7 requires 4" pellet pipe.

10. Outside Air Hook-up: Thelin Hearth Products recommends using a Dura Vent Wall Thimble with a built-in outside air hook-up and flex tubing.




FIGURE 7

WALL & REMOTE THERMOSTAT INSTALLATION FOR ECHO E.I.

The wall thermostat is designed to automatically regulate the room temperature by shutting the stove on and off or changing the output from High to Low. Remember to leave the control knob on the High or Medium position when utilizing the wall thermostat feature.

A wall or remote thermostat can be hooked to run the Echo 3000 E.I. automatically. The following is a step-by-step procedure for installing the optional thermostat. Note connection terminals on the bottom right side of the unit (see Figure 8). Use 18/2 thermostat wire for installation.

1. Unplug heater from the wall outlet!
2. Hook up the thermostat wires to terminals (see Figure 8). Remember to remove copper shunt. Replace shunt if thermostat hook-up is disconnected. If a remote thermostat is used you will have to mount the “receiver” to the bottom of the stove with Velcro and then hook up receiver wires to the terminal (see Figure 8). Follow thermostat manufacturer’s instructions.
3. Locate thermostat approximately 10 to 12 feet from heater or in an area that requires steady temperature. Run thermostat wires from heater to thermostat along wall or under carpet, etc., and hook wires to thermostat terminals. For the remote find a central location that will maintain room temperature and leave remote in that area.
4. Make sure all wiring is complete before plugging the Echo back into the wall outlet.

5. You have the option to have the thermostat run the stove either ON/OFF or Hi/Low. Factory setting is ON/OFF. By changing the Type setting jumper on the circuit board (see Figure 14), you can switch to the Hi/Low mode. This should be done in extremely cold climates so the house will maintain an even temperature and not be cycling on/off constantly.
6. Please be aware that the life of the igniter is affected by the ash build up in the fire pot and the number of times the stove is cycling on/off. If more than four or five times a day, then you should switch to the Hi/Low mode. Check fire pot frequently for ash build up.

IMPORTANT: Any electrical work performed on the Echo should be done by qualified personnel. **Always plug AC cord in before DC battery.**

Notice: First Burn is the Most Important

All Thelin Gas, Pellet, and Wood heaters are finished with high temperature paint that when properly cured provides years of service. We have found properly curing the paint during the initial fire is the single most important factor in preserving a long term finish.

Based on the initial curing process of 15 to 20 minutes and warming up on Low Setting, the stove body will heat and begin to cure the paint as a small amount of smoke is released.

If the unit is not turn off during this initial period and allowed to cool, the paint may become brittle and chip after many heat and cool cycles.

Once completed and 24 hours has passed the first burn should be about 15 minutes long. Start the unit on “Low” setting and once the starts to warm shut it off and allow to completely cool before using.




FIGURE 8




FIGURE 9




FIGURE 10

START-UP AND OPERATION

A. Filling the Hopper and Start-Up

CAUTION: Fuel hopper lid must be closed before operating the unit. The feed motor will not work if the hopper lid is open. **DO NOT OVERFILL THE HOPPER!** The Echo will hold approximately 50 pounds of pellets.

Open the top cover and fill the hopper with pellets (see Figure 9).

Use good-quality pellets that give you a vibrant, yellow flame with little or no soot. Poor quality pellets will burn rich with black sooty smoke and ash will accumulate quickly.

IMPORTANT: The quality of pellet varies from brand to brand. This will affect the efficiency of your heater. We suggest that you try several brands until you find one that provides a clean, efficient burn.

IMPORTANT: The fire pot must be seated flush and must sit even in the fire pot tray. Air leakage around the fire pot will create a poor burn (see Figure 10). Light the pellets in the fire pot using any approved lighting fluid.

B. Lighting Instructions

The Echo E.I. has automatic ignition. As a result you simply plug in the stove, fill with pellets and push the low, medium or high button on the control panel. When the button is pushed to low, medium or high the igniter will come on and in one minute the

feed motor will activate and begin feeding pellets. In three or four minutes you should see flame and in six minutes the igniter will shut off. The LED next to the button will blink during the six-minute start-up period. During the start-up period the heater will only run on "Low." If the fire does not reach operating temperature during the start up period the stove will shut down and you will have to repeat the process.

NOTE: Pellets do not feed in the "Fan" position.

If you choose to use a wall or remote thermostat follow the thermostat manufacturers instructions carefully and make sure you use the built in thermostat terminals on the bottom of the stove. (See Figure 8) We recommend you run the heater on "High" for about 30 minutes to get the heat exchanger hot before turning it to "Low." You will need to burn the heater for a few hours before deciding which setting is best for your particular needs.




FIGURE 11

C. Control Functions

The control functions on the Echo are as follows: OFF, FAN, LOW, MED, HIGH, and CLEAN (see Figure 11).

1. In the "Low" position, the Echo will feed approximately 1 to 1.5 pounds of pellets per hour. The flame will fluctuate between 1 inch and 6 inches in height.
2. In the "Med" position, the Echo will feed approximately 3 pounds of pellets per hour. The flame will fluctuate from 3 to 8 inches in height.
3. In the "High" position, the Echo will feed approximately 5 pounds of pellets per hour. The flame will fluctuate between 3 inches and a full flame. The fan speed will increase accordingly as the heater automatically adjusts itself based on the temperature inside the heater.
4. The "Clean" position is to be used only when the heater is not burning and you wish to clean out the combustion housing and fan blades. See the "Hopper Clean Out" section under "Maintenance Procedures."
5. After the heater is running for several hours and you wish to turn it off, simply push the button to "Off." If you use a remote or wall thermostat it will turn off the stove automatically when the desired room temperature is reached. **The heater will continue to run until it cools down and it will then automatically shut down at 58 degrees F. or in 25 minutes, whichever comes first.**
6. **REMEMBER:** Each feed position will fluctuate because the microprocessor automatically adjusts the feed and air based on temperature. This means the pellet feed rate and flame height will change accordingly based on quality of pellet and heat loss of dwelling.

HIGH TEMP/FLUE AND TRIM INDICATORS

High Temp/Flue: There is a small window to the left of the fan button that will blink red if the flue pipe becomes obstructed or there is a high wind condition, creating a back draft. If there is problem with the fan guard becoming blocked due to dust and lint build up then this light will come on and stay steady red. The feed will shut off and the stove will shut down when these two conditions are present. Maintenance is required and thorough cleaning and pipe check must be performed if these conditions persist.

Battery Light: When the green light is blinking the battery is charging. When the green light is steady the battery is fully charged. If this light is red, then the battery terminals are plugged in backward.

Trim Button: On the left side of the control panel there is a small, round button that will turn clockwise and counter-clockwise. This button allows you to control the feed rate in each setting—Low, Med, and High. By turning the button clockwise you can increase the feed rate in each setting. By turning the button counter-clockwise you can decrease the feed rate.

Move this button carefully! It is designed to fine-tune the heater in each position in the event you change brands of pellets and/or live at a higher elevation.

BATTERY OPERATION

Always plug AC cord in before DC battery.

1. The battery must be one foot from the stove to ensure that the terminal does not touch any part of stove.
2. The Echo Pellet 12V back-up can be purchased as an option and includes the following components:
 - a. Deep cycle seated 12-volt gel cell battery (available at most battery stores)

- b. Battery connector cables for hook-up to the heater (available from your dealer or Thelin Hearth Products)
3. To hook up the battery and engage the 12-volt back-up system, do the following:
 - a. Connect the red battery cable to the (+) positive terminal on the battery. Then plug the red banana plug into the red receptacle on the stove. **The red must be plugged in first before the black.**
 - b. Connect the black battery cable to the (-) negative terminal on the battery. Then plug the black banana plug into the black receptacle on the stove. If you hook up the cables correctly the LED light on the control panel come on and glow green. If hooked up improperly, this LED will glow.

WARNING: Make sure the red cable goes to the red terminal (positive connector) and the black cable goes to the black terminal (negative connector).

4. If you decide to purchase your own 12-volt back-up system, we recommend a sealed gel cell battery. **Failure to install the proper battery could cause physical harm to you and/or your property and will also void the heater warranty.**
5. When the battery is properly connected and the heater plugged in, the following will happen automatically:
 - a. The heater will automatically switch to 12-volt power if there is a power failure and switch back when power is restored.
 - b. The battery will be trickle charged as long as the heater is plugged into 110 AC wall outlet. **Do not use extension cords.** The trickle charge will not recharge a low or dead battery, but will keep a charged battery at maximum performance. **Do not unplug stove for the summer and keep battery attached. Battery will drain down and fail to recharge.**

6. If you choose to separate the battery from the heater by lengthening the cables, you must make sure the cable used will carry the current to the heater. For example, if the distance is 10 to 20 feet, then 12-gauge wire must be used. Check with your local electrical professional to make sure you have used the proper gauge wire/cable.
7. The automatic ignition feature will not work on DC power only. The stove can be lit manually with an approved starter material. Call Thelin Hearth Products if you need help with manual lighting.

MAINTENANCE PROCEDURES

CAUTION: Moving parts may cause injury. DO NOT operate with rear cover removed.

WARNING: Risk of electrical shock. Disconnect all power before servicing.

Always turn your heater off and let it cool before cleaning.

Your Echo Pellet Heater requires routine maintenance for maximum performance, and it is mandatory for the warranty to remain in effect.

The following procedures should be studied carefully and performed regularly as indicated.

- a. **Soot and Fly Ash: Formation and Need for Removal:** The products of combustion will contain small particles of fly ash. The fly ash will collect in the exhaust venting system and restrict the flow of the flue gases. Incomplete combustion, such that occurs during start-up, shutdown, or incorrect operation of the room heater, will lead to some soot formation which will collect in the exhaust venting system. The exhaust venting system should be inspected at least once every year to determine if cleaning is necessary.




FIGURE 12

Here are some other maintenance procedures that should be performed on a regular basis.

- b. Open door and remove clean out cover screws. To remove, simply unscrew and lift out from each side (see Figure 12). Clean one side at a time. With covers removed, leave the door open and push the “Clean” button. Let heater run 30 seconds, push to “Off,” and replace cover. Remove the remaining clean out cover and repeat procedure for other side.
- c. Vacuum inside stove ash pockets on both sides of fire pot and heat exchange tubes.
- d. Remove fire pot by lifting up and out. It may be brushed out or vacuumed. Fire pot should be cleaned regularly. Make sure slots in pot are not plugged. The area around and below the pot should be

checked every five or six days depending on how many hours a day you are burning your heater and the quality of the pellets being burned. After a few days you will be able to determine the frequency required for cleaning.

- e. Scrape pellet feed chute with putty knife to remove hardened material on which sawdust can accumulate.
 - f. The tee connector on the vent pipe must have a clean out cap and this must be checked every four to six weeks or whenever you utilize the "Clean" mode on the control dial.
 - g. Fly ash can also accumulate in the vent pipe. Inspect the exhaust system frequently to maintain free flow of exhaust fumes. This depends entirely on the quality of the pellets, so you will initially monitor the buildup in the vent pipe. Those installations going into an existing flue must be installed with a tee connector to allow access to clean the ash from the pellet vent pipe.
1. **Hopper Clean Out:** Vacuum the accumulated saw dust in the hopper weekly. Keep free of debris and foreign material. An accumulation of saw dust can cause irregular pellet feed. For best results this should be done on a regular basis depending on how often the heater is used. If you burn the heater all of the time, you should do this every eight to ten days.
 2. **Cleaning the Exhaust Fan Blade & Heat Exchanger:** The exhaust blower should be checked for excessive fly ash buildup. Regular and routine maintenance utilizing the clean out feature will keep the exhaust blower housing and fan blades clean. This cleaning can only be done when the heater is not burning. For best results, run the fan in the "Clean" position with the door open for approximately 45 seconds or until ash is no longer being picked up by the fan. Remember, you must always check the clean out cap on the tee after utilizing the clean

feature (see Figure 12). (See Figure 16 for routine stove clean out and maintenance.)

3. **Cleaning the Fan Guard:** The plastic fan guard on the rear of the stove must be kept free of lint and dust. Check weekly for lint build-up and vacuum as necessary. (See Figure 2)
4. **Keeping the Glass Clean:** If soot deposits accumulate on the glass, clean with window glass cleaner and a paper towel when glass is cold.

This Echo Pellet Heater has been tested and approved by Warnock Hersey Test Labs in Middleton, Wisconsin.

TROUBLESHOOTING

The following scenarios are provided in order to help you locate a difficulty if the heater performs in a manner which would seem to indicate a malfunction:

1. **Problem:** I loaded the heater for start-up, lit the fire starter and pellets, but the fire did not light.

Solution: Check power cord to see that it is plugged in tightly to the bottom of the stove. Is the LED light blinking when you push the Low, Medium, or High button? If not, check the fuse for the igniter located on the bottom of the stove in the red fuse holder. Remember that the timer on start-up runs about six minutes and if the pellets have not lit, then you may have to repeat the start-up sequence. Also, the stove only runs on one speed until a temperature is reached that activates the run mode. This usually takes 15 to 20 minutes, and in extremely cold climates, you might have to repeat the start-up procedure for the stove to reach this temperature.

2. **Problem:** The heater was lit and burning properly, then suddenly it stopped feeding pellets.

Solution: Check pellet supply in hopper. If empty, fill and follow start-up procedure. Occasionally, a foreign object, debris, or an excessive amount of sawdust can enter the feed

mechanism and jam the feed chute. If this happens, you must empty the hopper and check the feed chute to see what is causing the jam. Remove any foreign material or object and restart the heater. **CAUTION:** Keep fingers and hands clear of the feed mechanism when heater is on.

3. **Problem:** The fire was burning well and then it began to overfeed pellets and started backing up into the pellet feed chute, smothering the fire.

Solution: When the pellets are overfeeding, it usually means that the air flow has been reduced. Check the fire pot air intake holes to be sure they are clear. Check to see if fire pot was properly seated in the pot tray. If you use a low-grade pellet and clinkers (fused ash and dirt) form in the bottom of the fire pot and chock the air intake, you might consider changing the brand of pellets to one that burns cleaner. You must let the fire go out before removing and cleaning the fire pot. Never vacuum out the heater when the heater is in operation! The hot ashes can lodge in your vacuum cleaner and cause a fire! You must clean the heat exchanger tubes (see Figure 12) regularly to ensure a good air to fuel ration, thus allowing the heater to "breathe" properly. You must also check the tee and vent pipe to see that they are not clogged and full of ash.

4. **Problem:** The heater was burning well and then soot began forming on the door glass.

Solution: Black soot forming on the door glass means that the combustion is not right and the heater needs a good clean out. Some brands of pellets burn much richer than others and you might have to change brands of pellets and/or have the air/fuel settings readjusted by your dealer. It is normal to have the glass cloud up after several hours of burning, but it should wipe off with a good window cleaner. If the glass turns black quickly, then the heater needs a good clean out.

5. **Problem:** We had a power failure and the heater emitted smoke for about five minutes.

Solution: If the heater emits smoke during a power failure and you have frequent power failures, then we suggest you purchase the battery back-up system. If the vent pipe is installed according to these instructions, the smoke will siphon out of the pipe in most instances.

6. **Problem:** After several weeks of outstanding performance, the heater suddenly stopped and the red light under the control panel came on. This light is the High Temp/Flue indicator light.

Solution: The High Temp/Flue indicator light indicates that fly ash has built up in the exhaust system and/or there is a restriction in the exhaust/flue system or a high-wind condition. Check the pipe system for excessive ash and clogging, particularly the vent cap. Remove the clean out cap on the tee and make sure that ash has not blocked the exhaust air flow. This automatic shut down in case of flue clogging is a safety feature, and if the shut down occurs it means you have a problem and should consult a service technician and/or clean your pipe and heater thoroughly. If you feel the fly ash build-up is excessive, we suggest you try another pellet brand. In most climates the pellets and fly ash can absorb moisture from the air and create creosote and a severe clogging problem. Keep this in mind when you store and handle your pellets. The heater warranty does not cover the quality of the fuels used or the way they may be handled, either before or after you've purchased them. High-wind condition may require a high-wind cap. See Appendix A.

7. **Problem:** I turned off the switch and the heater continued running.

Solution: This is normal. The exhaust blower will keep running until it cools down and then it will automatically turn off. This can vary by the temperature the exhaust has reached and the temperature of the cooling air.

8. **Problem:** Fan motor speed varies, sometimes running low and sometimes surging. Will run on "High" or "Clean" but not on "Low."

Solution: Fan motor brushes are wearing out. Brushes in fan motor need to be replaced. Contact your dealer or call factory for replacement brushes.

9. **Problem:** Stove shuts off at night when running on low.

Solution: Feed is too low. Adjust feed trim button (turn clockwise) until feed can maintain fire.

10. **Problem:** I see a flashing green light behind the outer shield. What does this mean?

Solution: The flashing green light behind the outer shield means the circuit board is energized. This is okay. "Green means go." All systems are ready and operational.

FIGURE 13 – REPLACEMENT PARTS LIST




FIGURE 14 - CIRCUIT BOARD DIAGRAM




FIGURE 15 - ELECTRICAL SCHEMATIC/WIRING DIAGRAM






FIGURE 16 – ROUTINE STOVE CLEAN OUT AND MAINTENANCE



The following is a step-by-step procedure to clean out and maintain your pellet stove.

1. **Stove must be shut off and completely cold before performing this maintenance.**
2. Open door; remove fire pot and clean-out covers.
3. Vacuum entire inside area, including heat exchanger tubes (both sides), using a pellet vac or shop vac. **Do not use a household vacuum cleaner!**
4. Connect vinyl clean-out tube to pellet vac or shop vac. (An adaptor must be used to connect to a shop vac. These can be purchased at hardware stores or home centers.) Insert the clean-out tube down between the heat exchange tubes, and vacuum up the debris. Repeat the procedure for the other set of tubes on opposite side.
5. Turn control knob to “clean” position for about 45 seconds.
6. Replace clean-out covers and fire pot. The stove is now ready to use.

APPENDIX B – E.I. FIREPOT ASSEMBLY



APPENDIX C – FINE TUNING

Because of the variability of pellets (i.e., length thickness, density, quality of sawdust), you might have to—from time to time—fine tune your heater to compensate for pellet quality. Following are some suggestions for fine tuning.


There are three (3) fine-tuning adjustment components:

1. The Trim Button located on the control plate (see Figure 11) will allow you to change the feed rate on each setting (i.e., Hi, Med, Low). By turning the trim button clockwise you can increase the feed rate, and by turning the trim counterclockwise you can decrease the feed rate. For example, if the pellet you are using is a hardwood pellet and longer than 1”, then the stove could go out on the low setting for lack of fuel. Turn the trim clockwise to increase fuel and thus sustain the fire.
2. The Air Intake Damper control located on the air intake damper (see Figure 2) will allow you to regulate the amount of combustion air being fed to the pellet fire pot. If, for example, you have a high vertical

run of pipe (over 10’) then as the pipe warms up the draw can be intense enough to suck more heat out of the stove than is necessary. To make the stove run efficiently you need to close the damper about 60% and see if the heat output increases. If, on the other hand, you feel the pellets are not getting enough air, then opening the air damper could help. You can also increase combustion air utilizing the procedure in #3.

3. The Fan Trim Pot Adjustment is located on the circuit board (see Figure 14). Please note the two fan trim pots marked on the drawing (lower left hand corner). By using a small slot screwdriver you can adjust fan speeds to compensate for poor pellets or airflow. By turning the trim pots clockwise you can speed up the fan speed on both Hi and Low settings. You will have to experiment with the setting to determine the proper burn. A good, brisk flame that is yellow, not orange, is what indicates a good burn.

APPENDIX D – IGNITER REMOVAL



THELIN HEARTH PRODUCTS PELLET HEATER WARRANTY REPLACEMENT PROGRAM

EFFECTIVE January 1, 2020

NOTE: PLEASE READ THIS WARRANTY REPLACEMENT PROGRAM CAREFULLY BEFORE APPLYING FOR WARRANTY REPLACEMENTS OR CREDIT.

WARRANTY COVERAGE

Warranted for five years from the date of retail purchase against defects in workmanship to include heater cabinet and body. Warranted for one year from date of retail purchase to include drive mechanism and electronic components. Solely for the benefit of the original purchaser (retain your dated sales receipt as proof of purchase). **Some Dealers may require you to pay a service call or trip charge for any warranty work.**

COVERED

Replacement of defective parts and labor and product return to consumer.

NOT COVERED

Door glass, plating, paint, and gasket. Damages caused by abuse or failure to perform normal maintenance and any related expense. This warranty shall not apply to any defect, malfunction, or failure to conform with the warranty provisions if caused by damage (not resulting from defect or malfunction) due to unreasonable use by purchaser. Consequential damages, incidental damages, or incidental expenses, including damage to property. Some states do not allow the exclusions or limitation or incidental consequential damages, so the above limitation or exclusion may not apply to you. This warranty gives you specific legal rights that vary from state to state.

WARRANTY WORK

If you find this unit to be defective in material and/or workmanship within a period of five (5) years from the date of purchase, contact your local dealer from whom you purchased the heater. All warranty work must be authorized by the factory in advance of the repair and an authorization number assigned. A warranty claim form must be completed and signed by both the repair person and the customer. For prompt warranty service, please contact the authorized dealer in your area. Have the following information available to assist the repair person.

QUALIFICATION FOR WARRANTY PERFORMANCE

Return product or defective part with proof of purchase and narrative description of defect together with your name and address, freight prepaid to: Thelin Hearth Products, Warranty Division, 63 Laxalt Dr. Carson City, NV 89706. Returned part or product will be repaired or replaced at Thelin Hearth Products option and will be returned to you freight prepaid as soon as practical, but not later than 30 days after receipt.

HEATER PURCHASE INFORMATION

Date Purchased: _____ Serial Number: _____

Dealer/Retailer where Purchased: _____

Installer/Contractor used for Installation: _____



775-241-2586



QUALITY CONTROL SERVICES

LABORATORY EQUIPMENT • SALES • SERVICE • CALIBRATION • REPAIRS
2340 SE 11TH Ave. Portland, Oregon 97214 • Box 14831 Portland, Oregon 97293
(503) 236-2712 • FAX (503) 235-2535 • www.qc-services.com



PFS Teco
11785 SE Hwy 212 STE#305
Clackamas, OR 97015

Report Number: DIRI01A05026190611

A2LA ACCREDITED CERTIFICATE OF CALIBRATION WITH DATA

INSTRUMENT INFORMATION

| Item | Make | Model | Serial Number | Customer ID | Location |
|-------|-------------|-------------------|---------------|---------------|--------------|
| Scale | Rice Lake | IQ+355E-2A x 1000 | A05026 | #041 | Lab |
| Units | Readability | SOP | Cal Date | Last Cal Date | Cal Due Date |
| lbs | 0.1 | QC033 | 6/11/19 | 12/18/18 | 6/2020 |

FUNCTIONAL CHECKS

| SHIFT TEST | LINEARITY | REPEATABILITY | ENVIRONMENTAL CONDITIONS |
|---|---|---|--|
| Test Wt: 250 Tol: 1 | Test Wt: HB44 Tol: HB44 | Test Wt: 250 Tol: 1 | <input type="checkbox"/> Good <input checked="" type="checkbox"/> Fair <input type="checkbox"/> Poor |
| As-Found: Pass: <input checked="" type="checkbox"/> Fail: <input type="checkbox"/> | As-Found: Pass: <input checked="" type="checkbox"/> Fail: <input type="checkbox"/> | As-Found: Pass: <input checked="" type="checkbox"/> Fail: <input type="checkbox"/> | Temperature: 20.6°C |
| As-Left: Pass: <input checked="" type="checkbox"/> Fail: <input type="checkbox"/> | As-Left: Pass: <input checked="" type="checkbox"/> Fail: <input type="checkbox"/> | As-Left: Pass: <input checked="" type="checkbox"/> Fail: <input type="checkbox"/> | |

CALIBRATION DATA

| Standard | As-Found | As-Left | Expanded Uncertainty |
|----------|----------|---------|----------------------|
| 1000 | 1000.1 | 1000.1 | 0.12 |
| 700 | 700.1 | 700.1 | 0.12 |
| 500 | 500.0 | 500.0 | 0.08 |
| 300 | 299.9 | 299.9 | 0.08 |
| 100 | 100.0 | 100.0 | 0.05 |
| 50 | 50.0 | 50.0 | 0.05 |

CALIBRATION STANDARDS

| Item | Make | Model | Serial Number | Cal Date | Cal Due Date | NIST ID |
|--------------------|-----------|-------------|---------------|----------|--------------|----------|
| Avoirdupois Cast W | Rice Lake | 25 and 50lb | PWO990-CA | 11/24/17 | 11/2019 | 20172265 |

Permanent Information Concerning this Equipment:
12 month calibration cycle. 2000lb platform.

Comments/Information Concerning this Calibration
6/19 RH = 47%.

Report prepared/reviewed by: ServiceTech DC Date: 6/11/19

Technician: JJ Colacchio
Signature:

THIS CERTIFICATE SHALL NOT BE REPRODUCED, EXCEPT IN FULL, WITHOUT THE APPROVAL OF QUALITY CONTROL SERVICES, INC.

The uncertainty is calculated according to the ISO Guide to the Expression of Uncertainty in Measurement and includes the uncertainty of standards used combined with the observed standard deviation of the unit under test. The uncertainty is expanded with a k factor of 2 for an approximate 95% level of confidence. Instruments listed above were calibrated using standards traceable to the National Institute of Standards and Technology (NIST). Calibration data reflect results at the time and location of calibration. Calibration data should be reviewed to insure that the instrument is performing to its required accuracy.

Dry Gas Meter Calibration

Meter Manufacturer: Apex
 Model: XC-60-ED
 Lab ID #: 53
 Serial #: 1902130
 Calibration Date: 1/23/2020
 Calibration Expiration: 7/23/2020
 Barometric Pressure: 29.93 in. Hg



| Reference Standard DGM | |
|------------------------------|-----------|
| Manufacturer: | Apex |
| Model: | SK25DA |
| Lab ID#: | 47 |
| Serial #: | 1101001 |
| Calibration Expiration Date: | 3/13/2020 |
| Calibration γ Factor: | 0.998 |

| Unit Under Test Previous Calibration | |
|--------------------------------------|-----------|
| Date | 6/14/2019 |
| γ Factor: | 0.999 |
| Allowable Deviation ($\pm 5\%$): | 0.04995 |
| Actual Deviation: | 0.01 |
| Result: | PASS |

| Calibration Data | Run 1 | Run 2 | Run 3 |
|--|---------|---------|---------|
| Standard DGM Initial Volume (L) | 0.000 | 0.000 | 0.000 |
| Standard DGM Final Volume (L) | 162.364 | 142.013 | 148.622 |
| Standard DGM Temperature ($^{\circ}$ F) | 69.0 | 70.0 | 70.0 |
| Standard DGM Pressure (in H ₂ O) | 0.00 | 0.00 | 0.0 |
| DGM Initial Volume (ft ³) | 0.000 | 0.000 | 0.000 |
| DGM Final Volume (ft ³) | 5.814 | 5.147 | 5.409 |
| DGM Temperature ($^{\circ}$ F) | 88.0 | 94.0 | 96.0 |
| DGM Pressure (in H ₂ O) | 3.42 | 2.04 | 1.0 |
| Time (min) | 32.0 | 36.0 | 52.0 |
| Net Volume for Standard DGM (ft ³) | 5.734 | 5.015 | 5.249 |
| Net Volume for DGM (ft ³) | 5.814 | 5.147 | 5.409 |

| | | | |
|--|-------|-------|-------|
| Dry Gas Meter γ Factor | 1.011 | 1.011 | 1.013 |
| γ Factor Deviation From Average | 1.011 | 1.011 | 1.013 |

Average Gas Meter γ Factor

1.012

Calculations:

- Deviation = |Average value for all runs - current run value|
- $\gamma = [V_{std} \times (\gamma_{std}) \times (P_{bar} + P_{std}/13.6) \times (T_{DGM} + 460)] / [V_{DGM} \times (T_{std} + 460) \times (P_{bar} + P_{DGM}/13.6)]$

Standard Reference Meter is calibrated to NIST traceable standards. Uncertainty of measurement is $\pm 0.5\%$.

Dry Gas Meter Calibration

Meter Manufacturer: Apex
 Model: XC-60-ED
 Lab ID #: 54
 Serial #: 1902133
 Calibration Date: 1/23/2020
 Calibration Expiration: 7/23/2020
 Barometric Pressure: 23.93 in. Hg



| Reference Standard DGM | |
|------------------------------|-----------|
| Manufacturer: | Apex |
| Model: | SK25DA |
| Lab ID#: | 47 |
| Serial #: | 1101001 |
| Calibration Expiration Date: | 3/13/2020 |
| Calibration γ Factor: | 0.998 |

| Unit Under Test Previous Calibration | |
|--------------------------------------|-----------|
| Date | 6/14/2019 |
| γ Factor: | 0.996 |
| Allowable Deviation ($\pm 5\%$): | 0.0498 |
| Actual Deviation: | 0.01 |
| Result: | PASS |

| Calibration Data | Run 1 | Run 2 | Run 3 |
|--|---------|---------|---------|
| Standard DGM Initial Volume (L) | 0.000 | 0.000 | 0.000 |
| Standard DGM Final Volume (L) | 153.663 | 172.691 | 287.542 |
| Standard DGM Temperature ($^{\circ}$ F) | 69.0 | 69.0 | 69.0 |
| Standard DGM Pressure (in H ₂ O) | 0.00 | 0.00 | 0.0 |
| DGM Initial Volume (ft ³) | 0.000 | 0.000 | 0.000 |
| DGM Final Volume (ft ³) | 5.576 | 6.296 | 10.530 |
| DGM Temperature ($^{\circ}$ F) | 95.0 | 95.0 | 96.0 |
| DGM Pressure (in H ₂ O) | 3.60 | 2.00 | 1.0 |
| Time (min) | 30.0 | 45.0 | 99.0 |
| Net Volume for Standard DGM (ft ³) | 5.427 | 6.099 | 10.154 |
| Net Volume for DGM (ft ³) | 5.576 | 6.296 | 10.530 |
| Dry Gas Meter γ Factor | 1.008 | 1.008 | 1.008 |
| γ Factor Deviation From Average | 1.008 | 1.008 | 1.008 |

Average Gas Meter γ Factor 1.008

Calculations:

1. Deviation = |Average value for all runs - current run value|
2. $\gamma = [V_{std} \times (\gamma_{std}) \times (P_{bar} + P_{std}/13.6) \times (T_{DGM} + 460)] / [V_{DGM} \times (T_{std} + 460) \times (P_{bar} + P_{DGM}/13.6)]$

Standard Reference Meter is calibrated to NIST traceable standards. Uncertainty of measurement is $\pm 0.5\%$.

Technician:

Certificate of Calibration

Certificate Number: 712600



JJ Calibrations, Inc.

7724 SE Aspen Summit Drive

Portland, OR 97266-9217

Phone 503.786.3005

FAX 503.786.2994

PFS TECO

11785 SE Hwy 212

Suite 305

Clackamas, OR 97015

PO: john.steinst.PFSTECO.co

Order Date: 11/06/2019

Authorized By: N/A



Calibrated on: 11/15/2019

*Recommended Due: 11/15/2020

Environment: 21 °C 48 % RH

* As Received: **Within Tolerance**

* As Returned: **Within Tolerance**

Action Taken: **Calibrated**

Technician: 146

Property #: 064

User: N/A

Department: N/A

Make: **Control Company**

Model: 4198

Serial #: 80531676

Description: **Digital Temp. / Barometer**

Procedure: 404323

Accuracy: $\pm 1^{\circ}\text{C} \pm 0.2362\text{Hg}(\pm 8\text{mb})$

Remarks: * Many factors may cause the unit to drift out of calibration before the recommended due date. Any reported error is the absolute value between the reference and the unit. Uncertainties include the effects of the unit.

Standards Used

| Std ID | Manufacturer | Model | Nomenclature | Due Date | Trace ID |
|--------|--------------------|-------|---------------------------------|------------|----------|
| 644A | Thunder Scientific | 1200 | Two Pressure Humidity Generator | 10/14/2020 | 710583 |
| 847A | Fluke | RPM4 | Reference Pressure Monitor | 11/21/2019 | 688957 |

Parameter

Measurement Data

| Measurement Description | Range | Unit | Reference | Min | Max | *Error | UUT | Uncertainty |
|---------------------------------|-------|-------|-----------|--------|--------|---------|-------------|----------------|
| Before/After Temperature | | | | | | | | Accredited = ✓ |
| | | °C | 20.00 | 19.0 | 21.0 | 0.1 | 20.1 °C | 8.1E-02 ✓ |
| | | °C | 30.00 | 29.0 | 31.0 | 0.8 | 29.2 °C | 8.1E-02 ✓ |
| | °C | 40.00 | 39.0 | 41.0 | 0.2 | 39.8 °C | 8.1E-02 ✓ | |
| Barometer | | mbar | 1010.70 | 1002.7 | 1018.7 | 0.7 | 1010.0 mbar | |

This instrument has been calibrated in accordance with the JJ Calibrations Quality Assurance Manual and is traceable to either the SI or to National Institute of Standards and Technology (NIST). The quality system and this certificate are in compliance with ANSI/NCSL Z540-1-1994, ISO/IEC 17025-2017, ISO 10012-1, the ISO 9000 family and QS 9000. The expanded uncertainties of measurements for this calibration are based upon 95% (2 sigma) confidence limits. Unless stated in the comments, certificates reflect the "Simple Acceptance Rule" as specified by JCGM 106:2012. Unless otherwise stated, a test accuracy ration (TAR) of 4:1, if achievable, is maintained. The results reported herein apply only to the calibration of the item described above. This report may not be reproduced, except in full, without written approval of JJ Calibrations.


Reviewer

3 Issued 11/16/2019

Rev # 15


Inspector



QUALITY CONTROL SERVICES

LABORATORY EQUIPMENT • SALES • SERVICE • CALIBRATION • REPAIRS
2340 SE 11TH Ave. Portland, Oregon 97214 • Box 14831 Portland, Oregon 97293
(503) 236-2712 • FAX (503) 235-2535 • www.qc-services.com



PFS Teco
11785 SE Hwy 212 STE#305
Clackamas, OR 97015

Report Number: DIR10134307497200110

A2LA ACCREDITED CERTIFICATE OF CALIBRATION WITH DATA

INSTRUMENT INFORMATION

| Item | Make | Model | Serial Number | Customer ID | Location |
|---------|-------------|--------------|---------------|---------------|--------------|
| Balance | Sartorius | ENTRIS224-1S | 34307497 | #107 | Lab |
| Units | Readability | SOP | Cal Date | Last Cal Date | Cal Due Date |
| g | 0.0001 | QC012 | 1/10/20 | 6/10/19 | 6/2020 |

FUNCTIONAL CHECKS

| ECCENTRICITY | | LINEARITY | | STANDARD DEVIATION | | | ENVIRONMENTAL CONDITIONS |
|---|--------------------------------|---|--------------------------------|--------------------|-------------|---------------|---|
| Test Wt: | Tol: | Test Wt: | Tol: | Test Wt: | Tol: | | |
| 100 | 0.0003 | 50 x 4 | 0.0002 | 100 | 0.0001 | | <input type="checkbox"/> <input checked="" type="checkbox"/> <input type="checkbox"/> |
| As-Found: | | As-Found: | | 1. 100.0001 | 5. 99.9999 | 9. 100.0000 | Good Fair Poor |
| Pass: <input checked="" type="checkbox"/> | Fail: <input type="checkbox"/> | Pass: <input checked="" type="checkbox"/> | Fail: <input type="checkbox"/> | 2. 100.0000 | 6. 100.0000 | 10. 99.9999 | |
| As-Left: | | As-Left: | | 3. 100.0000 | 7. 100.0001 | Result | Temperature: 19.3°C |
| Pass: <input checked="" type="checkbox"/> | Fail: <input type="checkbox"/> | Pass: <input checked="" type="checkbox"/> | Fail: <input type="checkbox"/> | 4. 100.0000 | 8. 100.0000 | 0.00006 | |

A2LA ACCREDITED SECTION OF REPORT

| Standard | As-Found | As-Left | Expanded Uncertainty |
|----------|----------|----------|----------------------|
| 200 | 199.9997 | 200.0000 | 0.00019 |
| 100 | 100.0000 | 100.0001 | 0.00018 |
| 50 | 49.9999 | 50.0001 | 0.00018 |
| 20 | 20.0001 | 20.0000 | 0.00017 |
| 1 | 0.9998 | 0.9999 | 0.00017 |
| 0.1 | 0.0999 | 0.1000 | 0.00017 |

CALIBRATION STANDARDS

| Item | Make | Model | Serial Number | Cal Date | Cal Due Date | NIST ID |
|------------|-----------|-------------|---------------|----------|--------------|----------|
| Weight Set | Rice Lake | 20kg to 1mg | 7133 | 4/19/19 | 4/2020 | 20190811 |

Permanent Information Concerning this Equipment:

Comments/Info Concerning this Calibration:

01/20 RH= 49% Adjusted span.

Report prepared/reviewed by: R.B. Date: 1-10-20

Technician: R. Butcher

Signature: R. Butcher

THIS CERTIFICATE SHALL NOT BE REPRODUCED WITHOUT THE APPROVAL OF QUALITY CONTROL SERVICES, INC.

The uncertainty is calculated according to the ISO Guide to the Expression of Uncertainty in Measurement and includes the uncertainty of standards used combined with the observed standard deviation and readability of the unit under test. The uncertainty is expanded with a k factor of 2 for an approximate 95% level of confidence. Instruments listed above were calibrated using standards traceable to the National Institute of Standards and Technology (NIST). Calibration data reflect results at the time and location of calibration. Calibration data should be reviewed to insure that the instrument is performing to its required accuracy. Calibrations comply with ISO/IEC 17025 and ANSI/Z540-1-1994 quality standards.

Member: National Conference of Standards Laboratories and Weights & Measures

PT ID: DIR101



QUALITY CONTROL SERVICES

LABORATORY EQUIPMENT • SALES • SERVICE • CALIBRATION • REPAIRS
2340 SE 11TH Ave. Portland, Oregon 97214 • Box 14831 Portland, Oregon 97293
(503) 236-2712 • FAX (503) 235-2535 • www.qc-services.com



Report of Calibration

Firm: Dirigo Laboratories
Address: 11785 SE Hwy 212, Ste 305
City/State/Zip: Clackamas, OR 97015

Test Completed: 03/21/17
Submitted By: John Steiner
Traceable Number: 20170468

Test Item: 200mg and 100mg Individual Weights
Serial No.: Listed in Table

Manufacturer: Troemner

| <u>Material</u> | <u>Assumed Density</u> | <u>Range</u> | <u>Tolerance Class</u> |
|-----------------|------------------------|---------------|------------------------|
| Stainless Steel | 7.95 g/cm ³ | 200mg & 100mg | ASTM Class 1 |

Method and Traceability

The procedure used for this calibration is NIST IR 6969 SOP 4 Double Substitution Weighing Design. Standards used for comparison are traceable to the National Institute of Standards and Technology (reports on file) and are part of a comprehensive measurement assurance program for ensuring continued accuracy and traceability within the level of uncertainty reported. The Traceable Number listed above is Traceable to National Standards through an unbroken chain of comparison each having stated uncertainties.

Standards Used:

100g to 1mg Working Standards Were Calibrated: 03/03/17 Due: 03/31/18 Standards ID: 723318
Mass Comparators Used: MET-05 Tested by: D. Thompson

Conventional Mass: “The conventional value of the result of weighing a body in air is equal to the mass of a standard, of conventionally chosen density, at a conventionally chosen temperature, which balances this body at this reference temperature in air of conventionally chosen density. International Recommendation 33 (OIML IR 33 1973, 1979). “Conventional Value of the Result of Weighing in Air” (Previously known as “Apparent Mass vs. 8.0g/cm³”).

Uncertainty Statement: The uncertainty conforms to the ISO Guide to the Expressions of Uncertainty in Measurement. Uncertainty as reported is based on a coverage factor k=2 for an approximate 95 percent level of uncertainty. Uncertainty components include the standard deviation of the process, the uncertainty of the standard used, an uncertainty component associated with the potential drift of the standard used, and the estimated uncertainty related to measuring and determining the air buoyancy effect.

Conventional Mass Values are listed on page 2 of this report.

page 1 of 2

Quality Control Services, Inc.
Metrology Laboratory Manager
E-mail dthompson@qc-services.com

Date: 03/21/17

Signature David S. Thompson

This document shall not be reproduced, except in full, without the written approval of Quality Control Services Mass Laboratory.

Member: National Conference of Standards Laboratories and Weights & Measures



QUALITY CONTROL SERVICES

LABORATORY EQUIPMENT • SALES • SERVICE • CALIBRATION • REPAIRS
2340 SE 11TH Ave. Portland, Oregon 97214 • Box 14831 Portland, Oregon 97293
(503) 236-2712 • FAX (503) 235-2535 • www.qc-services.com



Report of Calibration

Firm: Dirigo Laboratories
Address: 11785 SE Hwy 212, Ste 305
City/State/Zip: Clackamas, OR 97015

Test Completed: 03/21/17
Submitted By: John Steiner
Traceable Number: 20170468

Test Item: 200mg and 100mg Individual Weights
Serial No.: Listed in Table

Manufacturer: Troemner

Laboratory Environment at time of test

| Temperature °C | Pressure mmHg | Humidity %RH |
|----------------|---------------|--------------|
| 21.967 | 753.44 | 49.44 |

Conventional Mass Value

| Nominal Value | As Found grams | As Found Correction* (mg) | Uncertainty (mg) | Tolerance (mg) |
|---------------------|----------------|---------------------------|------------------|----------------|
| 200mg SN 1000101395 | 0.2000061 | 0.0061 | 0.0026 | 0.01 |
| 100mg SN 1000126267 | 0.1000046 | 0.0046 | 0.0028 | 0.01 |

*Correction is the difference between the conventional mass value of a weight and its nominal value.

Comments: These weights were new from the manufacturer and were within ASTM Class 1 tolerances As Found. No adjustments or changes were made so As Found values should be considered to be As Left values.

Accredited by the American Association for Laboratory Accreditation (A2LA) under Calibration Laboratory Code 115953 and Certificate Number 1550.01. This laboratory meets the requirements of ISO/IEC 17025:2005 *General Requirements for the Competence of Testing and Calibration Laboratories*. This laboratory also meets the requirements of ANSI/NCSL Z540-1-1994 and any additional program requirements in the field of calibration.

page 2 of 2

Quality Control Services, Inc.
Metrology Laboratory Manager
E-mail dthompson@qc-services.com

Date: 03/21/17

Signature David S. Thompson



CERTIFICATE OF CALIBRATION

| | | | |
|----------------------------|--|----------------------------|------------------------|
| CUSTOMER: | PFS-TECO : CLACKAMAS, OR | CALIBRATION DATE: | 03/14/2019 |
| PO NUMBER: | N/A | CALIBRATION DUE: | 03/14/2020 |
| INST. MANUFACTURER: | DWYER | PROCEDURE: | T.O.33K6-4-1769-1 |
| INST. DESCRIPTION: | VELOMETER | CALIBRATION FLUID: | AIR @ 14.7 PSIA 70°F |
| MODEL NUMBER: | 471 | RECEIVED CONDITION: | WITHIN MFG. SPECS. |
| SERIAL NUMBER: | CP288559 (ID# 095) | LEFT CONDITION: | WITHIN MFG. SPECS. |
| RATED UNCERTAINTY: | SEE NOTES BELOW. | AMBIENT CONDITIONS: | 762 mm HGA 43% RH 69°F |
| UNCERTAINTY GIVEN: | ± .20% RD ; k=2 | CERTIFICATE FILE #: | 490265.2019 |
| NOTES: | ± 3% FS (0-500 / 0-1500) *** ± 4% F.S. (0-5000) *** ± 5% F.S. (0-15000) *** ± 2 °F | | |
| NOTES CONT. : | Q.MANUAL IM 1.5 REV 2017.1 DATED 7-18-2017 | | |

| UUT INDICATED FT/MIN | DM.STD. ACTUAL FT/MIN | UUT INDICATED DEG. F | DM STD. ACTUAL DEG. F |
|----------------------------|-----------------------------|----------------------------|-----------------------------|
| 64 | 65 | 0 TO 200°F | 0 TO 200°F |
| 110 | 112 | 43.4 | 43.5 |
| 206 | 210 | 69.0 | 68.9 |
| 498 | 509 | 99.4 | 99.2 |
| 503 | 505 | | |
| 1049 | 1058 | | |
| 1497 | 1514 | | |
| 509 | 513 | | |
| 3419 | 3460 | | |
| 4992 | 5068 | | |
| 5136 | 5235 | | |
| 13928 | 14232 | | |

STANDARDS USED:

| | | |
|---|-----|------------|
| A220: 12" WIND TUNNEL 0 - 8000 FPM CMC ± .203% RD TRACE# 1520423238 | DUE | 05/23/2019 |
| A24: HART SCIENTIFIC TEMP. STANDARD ± 0.24 F TRACE# 1520423238 | DUE | 03/07/2020 |

All instruments used in the performance of the shown calibration have traceability to the National Institute of Standards and Technology (NIST). The uncertainty ratio between the calibration standards (DM.STD.) used and the unit under test (UUT) is a minimum of 4:1, unless otherwise noted. Calibration has been performed per the shown procedure number, in accordance with ISO 10012:2003, ISO 17025:2005, ANSI/NCSSL-Z-540.3, and/or MIL-STD-45662A. Test methods: API2530-92 & ASME MFC-3M-1989.

Dick Munns Company • 11133 Winners Circle • Los Alamitos, CA 90720
Phone (714) 827-1215 • Fax (714) 827-0823

This Calibration Certificate shall not be reproduced, except in full, without approval by DICK MUNNS COMPANY. The data shown applies only to the instrument being calibrated and under the stated conditions of calibration.

Date:

3/14/2019

Approved By:

Calibration Technician:



QUALITY CONTROL SERVICES

LABORATORY EQUIPMENT • SALES • SERVICE • CALIBRATION • REPAIRS
2340 SE 11TH Ave. Portland, Oregon 97214 • Box 14831 Portland, Oregon 97293
(503) 236-2712 • FAX (503) 235-2535 • www.qc-services.com



Report of Calibration

Firm: Dirigo Laboratories
Address: 11785 SE Hwy 212, Ste 305
City/State/Zip: Clackamas, OR 97015

Test Completed: 01/15/16
Purchase Order: 1001
Traceable Number: 20152489

Test Item: 20lb and 10lb Individual Grip Handle Weights
Serial No.: Listed in Table

Manufacturer: Unknown

| <u>Material</u> | <u>Assumed Density</u> | <u>Range</u> | <u>Tolerance Class</u> |
|-----------------|------------------------|--------------|------------------------|
| Cast Iron | 7.2 g/cm ³ | 20lb to 10lb | NIST HB 105-1 (F) |

Method and Traceability

The procedure used for this calibration is NIST IR 6969 SOP 7 Single Substitution Weighing Design. Standards used for comparison are traceable to the National Institute of Standards and Technology (reports on file) and are part of a comprehensive measurement assurance program for ensuring continued accuracy and traceability within the level of uncertainty reported. The Traceable Number listed above is Traceable to National Standards through an unbroken chain of comparison each having stated uncertainties.

Standards Used:

Avoirdupois Working Standards were calibrated: 06/18/2014 Due: 06/18/2016 Standards ID: 34AA

Mass Comparators Used: MET-09, 20

Tested by: D. Thompson

Conventional Mass: "The conventional value of the result of weighing a body in air is equal to the mass of a standard, of conventionally chosen density, at a conventionally chosen temperature, which balances this body at this reference temperature in air of conventionally chosen density. International Recommendation 33 (OIML IR 33 1973, 1979). "Conventional Value of the Result of Weighing in Air" (Previously known as "Apparent Mass vs. 8.0g/cm³).

Uncertainty Statement: The uncertainty conforms to the ISO Guide to the Expressions of Uncertainty in Measurement. Uncertainty as reported is based on a coverage factor K=2 for an approximate 95 percent level of uncertainty. Uncertainty components include the standard deviation of the process, the uncertainty of the standard used, an uncertainty component associated with the potential drift of the standard used, and the estimated uncertainty related to measuring and determining the air buoyancy effect.

Conventional Mass Values are listed on page 2 of this report.

page 1 of 2

Quality Control Services, Inc.
Metrology Laboratory Manager
E-mail dthompson@qc-services.com

Date: 01/15/16


Signature David S. Thompson

This document shall not be reproduced, except in full, without the written approval of Quality Control Services Mass Laboratory.

Member: National Conference of Standards Laboratories and Weights & Measures



QUALITY CONTROL SERVICES

LABORATORY EQUIPMENT • SALES • SERVICE • CALIBRATION • REPAIRS
2340 SE 11TH Ave. Portland, Oregon 97214 • Box 14831 Portland, Oregon 97293
(503) 236-2712 • FAX (503) 235-2535 • www.qc-services.com



Report of Calibration

Firm: Dirigo Laboratories
Address: 11785 SE Hwy 212, Ste 305
City/State/Zip: Clackamas, OR 97015

Test Completed: 01/15/16
Purchase Order: 1001
Traceable Number: 20152489

Test Item: 20lb and 10lb Individual Grip Handle Weights
Serial No.: Listed in Table

Manufacturer: Unknown

Laboratory Environment at time of test

| Temperature °C | Pressure mmHg | Humidity %RH |
|----------------|---------------|--------------|
| 21.448 | 760.64 | 44.58 |

Conventional Mass Value

| Nominal Value | As Found pounds | As Found Correction* (mg) | Uncertainty (mg) | Tolerance (mg) |
|---------------|-----------------|---------------------------|------------------|----------------|
| 20lb #098 | 19.9995450 | -206.4 | 6.4 | 910 |
| 10lb #097 | 10.0006510 | 295.3 | 5.1 | 450 |
| 10lb #051 | 10.0003421 | 155.2 | 5.1 | 450 |

*Correction is the difference between the conventional mass value of a weight and its nominal value.

Comments: These weights were received in good condition and were within NIST Handbook 105-1 Class F tolerances As Found. No adjustments or changes were made so As Found values should be considered to be As Left values.

Accredited by the American Association for Laboratory Accreditation (A2LA) under Calibration Laboratory Code 115953 and Certificate Number 1550.01. This laboratory meets the requirements of ISO/IEC 17025:2005 *General Requirements for the Competence of Testing and Calibration Laboratories*. This laboratory also meets the requirements of ANSI/NCSL Z540-1-1994 and any additional program requirements in the field of calibration.

page 2 of 2

Quality Control Services, Inc.
Metrology Laboratory Manager
E-mail dthompson@qc-services.com

Date: 01/15/16


Signature David S. Thompson



Model 1430 Microtector® Electronic Point Gage

Bulletin D-57

Installation and Operating Instructions



Model 1430 Microtector® Portable Electronic Point Gage combines modern, solid-state integrated circuit electronics with a time-proven point gage manometer to provide fast, accurate pressure measurements.

SPECIFICATIONS AND FEATURES

- Accurate and repeatable to $\pm .00025$ inches water column
- Pressure range: 0 - 2" w.c., positive, negative, or differential pressures
- Non-toxic and inexpensive gage fluid consists of distilled water mixed with a small amount of fluorescein green color concentrate
- Convenient, portable, lightweight and self-contained, the unit requires no external power connections and is operated by a 1.5 volt penlight cell
- A.C. detector current eliminates point plating, fouling and erosion
- Micrometers are manufactured in accordance with ASME B89.1.13-2001, and are traceable to a standard at the National Institute of Standards and Technology
- Three-point mounting, dual leveling adjustment, and circular level vial assure rapid setup
- Durablock® precision-machined acrylic gage body
- Sensitive 0 - 50 microamp D.C. meter acts as a detector and also indicates battery and probe condition
- Heavy 2" thick steel base plate provides steady mounting
- Top-quality glass epoxy circuit board and solid-state, integrated circuit electronics
- Electronic enclosure of tough, molded styrene acrylonitrile provides maximum protection to components yet allows easy access to battery compartment
- Rugged sheet steel cover and carrying case protects the entire unit when not in use
- Accessories included are (2) 3-foot lengths Tygon® tubing, (2) 1/8" pipe thread adapters and 3/4 oz. bottle of fluorescein green color concentrate with wetting agent

Maximum pressure: 100 psig with optional pipe thread connections.

Tygon® is a registered trademark of Saint-Gobain Corporation

DWYER INSTRUMENTS, INC.
P.O. BOX 373
MICHIGAN CITY, INDIANA 46361, U.S.A

Phone: 219/879-8000
Fax: 219/872-9057

www.dwyer-inst.com
e-mail: info@dwyer-inst.com



CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information

PXPKG TUALATIN OR H
10450 SW TUALATIN SHERWOOD ROAD
TUALATIN OR 97062

Certificate Modification Date: 10/01/2018
Praxair Order Number: 70743165
Part Number: NI CD17CO8E-AS

Fill Date: 09/26/2018
Lot Number: 70086826911
Cylinder Style & Outlet: AS CGA 590
Cylinder Pressure and Volume: 1290 psig 140 ft3

Certified Concentration

| | | |
|------------------|-----------------|----------------------|
| Expiration Date: | 10/01/2026 | NIST Traceable |
| Cylinder Number: | SA17187 | Expanded Uncertainty |
| 17.00 % | Carbon dioxide | ± 0.3 % |
| 4.31 % | Carbon monoxide | ± 0.6 % |
| 16.99 % | Oxygen | ± 0.2 % |
| Balance | Nitrogen | |

ProSpec EZ Cert



Certification Information:

Certification Date: 10/01/2018 Term: 96 Months Expiration Date: 10/01/2026

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-600/R-12/531, using Procedure G1.
Do Not Use this Standard if Pressure is less than 100 PSIG.
CO2 responses have been corrected for Oxygen IR Broadening effect. O2 responses have been corrected for CO2 interference.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: Carbon dioxide
Requested Concentration: 17 %
Certified Concentration: 17.00 %
Instrument Used: Horiba VIA-510 S/N 20C194WK
Analytical Method: NDIR
Last Multipoint Calibration: 09/21/2018

| First Analysis Data: | | Date | |
|----------------------|---------------------|----------|-------------|
| Z: 0 | R: 20.1 | C: 17 | Conc: 17 |
| R: 20.1 | Z: 0 | C: 17 | Conc: 17 |
| Z: 0 | C: 17.01 | R: 20.11 | Conc: 17.01 |
| UOM: % | Mean Test Assay: 17 | | % |

Reference Standard: Type / Cylinder #: GMIS / CC187238
Concentration / Uncertainty: 20.10 % ±0.24%
Expiration Date: 06/07/2026
Traceable to: SRM # / Sample # / Cylinder #: RGM#CC193512 / NIA / RGM#CC193512
SRM Concentration / Uncertainty: 26.99% / ±0.05%
SRM Expiration Date: 05/15/2023

| Second Analysis Data: | | Date | |
|-----------------------|------------------|------|---------|
| Z: 0 | R: 0 | C: 0 | Conc: 0 |
| R: 0 | Z: 0 | C: 0 | Conc: 0 |
| Z: 0 | C: 0 | R: 0 | Conc: 0 |
| UOM: % | Mean Test Assay: | | % |

2. Component: Carbon monoxide
Requested Concentration: 4.25 %
Certified Concentration: 4.31 %
Instrument Used: Horiba VIA-510 S/N UB9UCSYX
Analytical Method: NDIR
Last Multipoint Calibration: 09/21/2018

| First Analysis Data: | | Date | |
|----------------------|-----------------------|---------|------------|
| Z: 0 | R: 5 | C: 4.31 | Conc: 4.31 |
| R: 5 | Z: 0 | C: 4.3 | Conc: 4.3 |
| Z: 0 | C: 4.32 | R: 5.01 | Conc: 4.32 |
| UOM: % | Mean Test Assay: 4.31 | | % |

Reference Standard: Type / Cylinder #: GMIS / CC242633
Concentration / Uncertainty: 5.00 % ±0.543%
Expiration Date: 04/03/2025
Traceable to: SRM # / Sample # / Cylinder #: SRM 2642a / 51-D-23 / FF23106
SRM Concentration / Uncertainty: 7.859% / ±0.039%
SRM Expiration Date: 07/15/2019

| Second Analysis Data: | | Date | |
|-----------------------|------------------|------|---------|
| Z: 0 | R: 0 | C: 0 | Conc: 0 |
| R: 0 | Z: 0 | C: 0 | Conc: 0 |
| Z: 0 | C: 0 | R: 0 | Conc: 0 |
| UOM: % | Mean Test Assay: | | % |

3. Component: Oxygen
Requested Concentration: 17 %
Certified Concentration: 16.99 %
Instrument Used: OXYMAT 5E
Analytical Method: Paramagnetic
Last Multipoint Calibration: 09/04/2018

| First Analysis Data: | | Date | |
|----------------------|------------------------|----------|-------------|
| Z: 0 | R: 20.86 | C: 16.99 | Conc: 16.99 |
| R: 20.86 | Z: 0 | C: 16.99 | Conc: 16.99 |
| Z: 0 | C: 16.99 | R: 20.86 | Conc: 16.99 |
| UOM: % | Mean Test Assay: 16.99 | | % |

Reference Standard: Type / Cylinder #: GMIS / CC75874
Concentration / Uncertainty: 20.86 % ±0.111%
Expiration Date: 11/07/2025
Traceable to: SRM # / Sample # / Cylinder #: SRM 2659a / 71-E-19 / FF22331
SRM Concentration / Uncertainty: 20.863% / ±0.021%
SRM Expiration Date: 08/23/2021

| Second Analysis Data: | | Date | |
|-----------------------|------------------|------|---------|
| Z: 0 | R: 0 | C: 0 | Conc: 0 |
| R: 0 | Z: 0 | C: 0 | Conc: 0 |
| Z: 0 | C: 0 | R: 0 | Conc: 0 |
| UOM: % | Mean Test Assay: | | % |

Analyzed By

Jose Vasquez

Certified By

Danielle Burns



CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information

PXPKG TUALATIN OR H
10450 SW TUALATIN SHERWOOD ROAD
TUALATIN OR 97062

Certificate Modification Date: 09/05/2018
Praxair Order Number: 70716136
Part Number: NI CD10CO33E-AS

Fill Date: 08/31/2018
Lot Number: 70086824308
Cylinder Style & Outlet: AS CGA 590
Cylinder Pressure and Volume: 2000 psig 140 ft3

Certified Concentration

ProSpec EZ Cert

| | | |
|------------------|-----------------|----------------------|
| Expiration Date: | 09/05/2026 | NIST Traceable |
| Cylinder Number: | CC170624 | Expanded Uncertainty |
| 10.00 % | Carbon dioxide | ± 0.3 % |
| 2.51 % | Carbon monoxide | ± 0.7 % |
| 10.50 % | Oxygen | ± 0.6 % |
| Balance | Nitrogen | |



Certification Information:

Certification Date: 09/05/2018 Term: 96 Months Expiration Date: 09/05/2026

This cylinder was certified according to the 2012 EPA Traceability Protocol, Document #EPA-600/R-12/531, using Procedure G1.

Do Not Use this Standard if Pressure is less than 100 PSIG.

CO responses have been corrected for CO2 interference. CO2 responses have been corrected for Oxygen IR Broadening effect. O2 responses have been corrected for CO2 interference.

Analytical Data:

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component:

Carbon dioxide

Requested Concentration: 10 %
Certified Concentration: 10.00 %
Instrument Used: Horiba VIA-510 S/N 20C194WK
Analytical Method: NDIR
Last Multipoint Calibration: 08/20/2018

Reference Standard: Type / Cylinder #: GMIS / CC141375
Concentration / Uncertainty: 14.02 % ± 0.3%
Expiration Date: 06/11/2026
Traceable to: SRM # / Sample # / Cylinder #: SRM 1675b / 6-F-51 / CAL014538
SRM Concentration / Uncertainty: 13.963% / ± 0.034%
SRM Expiration Date: 05/16/2022

| First Analysis Data: | | | | Date | | | |
|----------------------|-------|------------------|-------|------|-------|-------|----|
| Z: | 0 | R: | 14.02 | C: | 10 | Conc: | 10 |
| R: | 14.02 | Z: | 0 | C: | 10 | Conc: | 10 |
| Z: | 0 | C: | 10 | R: | 14.02 | Conc: | 10 |
| UOM: | % | Mean Test Assay: | | 10 | % | | |

| Second Analysis Data: | | | | Date | | | |
|-----------------------|---|------------------|---|------|---|-------|---|
| Z: | 0 | R: | 0 | C: | 0 | Conc: | 0 |
| R: | 0 | Z: | 0 | C: | 0 | Conc: | 0 |
| Z: | 0 | C: | 0 | R: | 0 | Conc: | 0 |
| UOM: | % | Mean Test Assay: | | | % | | |

2. Component:

Carbon monoxide

Requested Concentration: 2.5 %
Certified Concentration: 2.51 %
Instrument Used: Horiba VIA-510 S/N UB9UCSYX
Analytical Method: NDIR
Last Multipoint Calibration: 08/20/2018

Reference Standard: Type / Cylinder #: GMIS / CC102045
Concentration / Uncertainty: 2.48 % ± 0.448%
Expiration Date: 04/03/2025
Traceable to: SRM # / Sample # / Cylinder #: SRM 2641a / 52-D-30 / CAL017193
SRM Concentration / Uncertainty: 4.009% / ± 0.017%
SRM Expiration Date: 07/15/2019

| First Analysis Data: | | | | Date | | | |
|----------------------|------|------------------|------|------|------|-------|------|
| Z: | 0 | R: | 2.48 | C: | 2.51 | Conc: | 2.51 |
| R: | 2.48 | Z: | 0 | C: | 2.51 | Conc: | 2.51 |
| Z: | 0 | C: | 2.51 | R: | 2.48 | Conc: | 2.51 |
| UOM: | % | Mean Test Assay: | | 2.51 | % | | |

| Second Analysis Data: | | | | Date | | | |
|-----------------------|---|------------------|---|------|---|-------|---|
| Z: | 0 | R: | 0 | C: | 0 | Conc: | 0 |
| R: | 0 | Z: | 0 | C: | 0 | Conc: | 0 |
| Z: | 0 | C: | 0 | R: | 0 | Conc: | 0 |
| UOM: | % | Mean Test Assay: | | | % | | |

3. Component:

Oxygen

Requested Concentration: 10.5 %
Certified Concentration: 10.50 %
Instrument Used: OXYMAT 5E
Analytical Method: Paramagnetic
Last Multipoint Calibration: 09/04/2018

Reference Standard: Type / Cylinder #: NTRM / DT0010402
Concentration / Uncertainty: 9.88 % ± 0.4%
Expiration Date: 11/18/2022
Traceable to: SRM # / Sample # / Cylinder #: NTRM #170701 / N/A / NTRM #DT0010402
SRM Concentration / Uncertainty: 9.875% / ± 0.040%
SRM Expiration Date: 11/18/2022

| First Analysis Data: | | | | Date | | | |
|----------------------|------|------------------|------|------|-------|-------|-------|
| Z: | 0 | R: | 9.88 | C: | 10.49 | Conc: | 10.49 |
| R: | 9.88 | Z: | 0 | C: | 10.5 | Conc: | 10.5 |
| Z: | 0 | C: | 10.5 | R: | 9.88 | Conc: | 10.5 |
| UOM: | % | Mean Test Assay: | | 10.5 | % | | |

| Second Analysis Data: | | | | Date | | | |
|-----------------------|---|------------------|---|------|---|-------|---|
| Z: | 0 | R: | 0 | C: | 0 | Conc: | 0 |
| R: | 0 | Z: | 0 | C: | 0 | Conc: | 0 |
| Z: | 0 | C: | 0 | R: | 0 | Conc: | 0 |
| UOM: | % | Mean Test Assay: | | | % | | |

Analyzed By

Danielle Burns

Certified By

Jose Vasquez